

Article 90 Introduction	110.2 Approval
90.1 Purpose	110.3 Examination, Identification, Installation, Use, and Listing (Product Certification) of Equipment
(A) Practical Safeguarding	(A) Examination
(B) Adequacy	(B) Installation and Use
(C) Relation to Other International Standards	(C) Listing
90.2 Scope	110.4 Voltages
(A) Covered	110.5 Conductors
(B) Not Covered	110.6 Conductor Sizes
(C) Special Permission	110.7 Wiring Integrity
90.3 Code Arrangement	110.8 Wiring Methods
90.4 Enforcement	110.9 Interrupting Rating
90.5 Mandatory Rules, Permissive Rules, and Explanatory Material	110.10 Circuit Impedance, Short-Circuit Current Ratings, and Other Characteristics
(A) Mandatory Rules	110.11 Deteriorating Agents
(B) Permissive Rules	110.12 Mechanical Execution of Work
(C) Explanatory Material	(A) Unused Openings
(D) Informative Annexes	(B) Integrity of Electrical Equipment and Connections
90.6 Formal Interpretations	110.13 Mounting and Cooling of Equipment
90.7 Examination of Equipment for Safety	(A) Mounting
90.8 Wiring Planning	(B) Cooling
(A) Future Expansion and Convenience	110.14 Electrical Connections
(B) Number of Circuits in Enclosures	(A) Terminals
90.9 Units of Measurement	(B) Splices
(A) Measurement System of Preference	(C) Temperature Limitations
(B) Dual System of Units	(D) Installation
(C) Permitted Uses of Soft Conversion	110.15 High-Leg Marking
(D) Compliance	110.16 Arc-Flash Hazard Warning
Article 100 Definitions	(A) General
<u>Part I. General</u>	(B) Service Equipment
<u>Part II. Over 1000 Volts, Nominal</u>	110.18 Arcing Parts
Article 110 Requirements for Electrical Installations	110.19 Light and Power from Railway Conductors
<u>Part I. General</u>	110.21 Marking
110.1 Scope	

2017 NEC TABLE OF CONTENTS

(A) Equipment Markings	110.32 Work Space About Equipment
(B) Field-Applied Hazard Markings	110.33 Entrance to Enclosures and Access to Working Space
110.22 Identification of Disconnecting Means	(A) Entrance
(A) General	(B) Access
(B) Engineered Series Combination Systems	110.34 Work Space and Guarding
(C) Tested Series Combination Systems	(A) Working Space
110.23 Current Transformers	(B) Separation from Low-Voltage Equipment
110.24 Available Fault Current	(C) Locked Rooms or Enclosures
(A) Field Marking	(D) Illumination
(B) Modifications	(E) Elevation of Unguarded Live Parts
110.25 Lockable Disconnecting Means	(F) Protection of Service Equipment, Switchgear, and Industrial Control Assemblies
<u>Part II. 1000 Volts, Nominal, or Less</u>	110.36 Circuit Conductors
110.26 Spaces About Electrical Equipment	110.40 Temperature Limitations at Terminations
(A) Working Space	110.41 Inspections and Tests
(B) Clear Spaces	(A) Pre-energization and Operating Tests
(C) Entrance to and Egress from Working Space	(B) Test Report
(D) Illumination	<u>Part IV. Tunnel Installations over 1000 Volts, Nominal</u>
(E) Dedicated Equipment Space	110.51 General
(F) Locked Electrical Equipment Rooms or Enclosures	(A) Covered
110.27 Guarding of Live Parts	(B) Other Articles
(A) Live Parts Guarded Against Accidental Contact	(C) Protection Against Physical Damage
(B) Prevent Physical Damage	110.52 Overcurrent Protection
(C) Warning Signs	110.53 Conductors
110.28 Enclosure Types	110.54 Bonding and Equipment Grounding Conductors
<u>Part III. Over 1000 Volts, Nominal</u>	(A) Grounded and Bonded
110.30 General	(B) Equipment Grounding Conductors
110.31 Enclosure for Electrical Installations	110.55 Transformers, Switches, and Electrical Equipment
(A) Electrical Vaults	110.56 Energized Parts
(B) Indoor Installations	110.57 Ventilation System Controls
(C) Outdoor Installations	110.58 Disconnecting Means
(D) Enclosed Equipment Accessible to Unqualified Persons	110.59 Enclosures

Part V. Manholes and Other Electrical Enclosures

Intended for Personnel Entry

- 110.70 General
- 110.71 Strength
- 110.72 Cabling Work Space
- 110.73 Equipment Work Space
- 110.74 Conductor Installation
 - (A) 1000 Volts, Nominal, or Less
 - (B) Over 1000 Volts, Nominal
- 110.75 Access to Manholes
 - (A) Dimensions
 - (B) Obstructions
 - (C) Location
 - (D) Covers
 - (E) Marking
- 110.76 Access to Vaults and Tunnels
 - (A) Location
 - (B) Locks
- 110.77 Ventilation
- 110.78 Guarding
- 110.79 Fixed Ladders

Article 200 Use and Identification of Grounded Conductors

- 200.1 Scope
- 200.2 General
- 200.3 Connection to Grounded System
- 200.4 Neutral Conductors
 - (A) Installation
 - (B) Multiple Circuits
- 200.6 Means of Identifying Grounded Conductors
 - (A) Sizes 6 AWG or Smaller
 - (B) Sizes 4 AWG or Larger
 - (C) Flexible Cords

- (D) Grounded Conductors of Different Systems
- (E) Grounded Conductors of Multiconductor Cables
- 200.7 Use of Insulation of a White or Gray Color or with Three Continuous White or Gray Stripes
 - (A) General
 - (B) Circuits of Less Than 50 Volts
 - (C) Circuits of 50 Volts or More
- 200.9 Means of Identification of Terminals
- 200.10 Identification of Terminals
 - (A) Device Terminals
 - (B) Receptacles, Plugs, and Connectors
 - (C) Screw Shells
 - (D) Screw Shell Devices with Leads
 - (E) Appliances
- 200.11 Polarity of Connections

Article 210 Branch Circuits

Part I. General Provisions

- 210.1 Scope
- 210.3 Other Articles for Specific-Purpose Branch Circuits
- 210.4 Multiwire Branch Circuits
 - (A) General
 - (B) Disconnecting Means
 - (C) Line-to-Neutral Loads
 - (D) Grouping
- 210.5 Identification for Branch Circuits
 - (A) Grounded Conductor
 - (B) Equipment Grounding Conductor
 - (C) Identification of Ungrounded Conductors
- 210.6 Branch-Circuit Voltage Limitations
 - (A) Occupancy Limitation
 - (B) 120 Volts Between Conductors
 - (C) 277 Volts to Ground
 - (D) 600 Volts Between Conductors

2017 NEC TABLE OF CONTENTS

(E) Over 600 Volts Between Conductors	(D) Outlet Devices
210.7 Multiple Branch Circuits	210.21 Outlet Devices
210.8 Ground-Fault Circuit-Interrupter Protection for Personnel	(A) Lampholders
(A) Dwelling Units	(B) Receptacles
(B) Other Than Dwelling Units	210.22 Permissible Loads, Individual Branch Circuits
(C) Boat Hoists	210.23 Permissible Loads, Multiple-Outlet Branch Circuits
(D) Kitchen Dishwasher Branch Circuit	(A) 15- and 20-Ampere Branch Circuits
(E) Crawl Space Lighting Outlets	(B) 30-Ampere Branch Circuits
210.9 Circuits Derived from Autotransformers	(C) 40- and 50-Ampere Branch Circuits
210.10 Ungrounded Conductors Tapped from Grounded Systems	(D) Branch Circuits Larger Than 50 Amperes
210.11 Branch Circuits Required	210.24 Branch-Circuit Requirements — Summary
(A) Number of Branch Circuits	210.25 Branch Circuits in Buildings with More Than One Occupancy
(B) Load Evenly Proportioned Among Branch Circuits	(A) Dwelling Unit Branch Circuits
(C) Dwelling Units	(B) Common Area Branch Circuits
210.12 Arc-Fault Circuit-Interrupter Protection	<u>Part III. Required Outlets</u>
(A) Dwelling Units	210.50 General
(B) Dormitory Units	(A) Cord Pendants
(C) Guest Rooms and Guest Suites	(B) Cord Connections
(D) Branch Circuit Extensions or Modifications — Dwelling Units and Dormitory Units	(C) Appliance Receptacle Outlets
210.13 Ground-Fault Protection of Equipment	210.52 Dwelling Unit Receptacle Outlets
210.17 Guest Rooms and Guest Suites	(A) General Provisions
<u>Part II. Branch-Circuit Ratings</u>	(B) Small Appliances
210.18 Rating	(C) Countertops and Work Surfaces
210.19 Conductors — Minimum Ampacity and Size	(D) Bathrooms
(A) Branch Circuits Not More Than 600 Volts	(E) Outdoor Outlets
(B) Branch Circuits Over 600 Volts	(F) Laundry Areas
210.20 Overcurrent Protection	(G) Basements, Garages, and Accessory Buildings
(A) Continuous and Noncontinuous Loads	(H) Hallways
(B) Conductor Protection	(I) Foyers
(C) Equipment	210.60 Guest Rooms, Guest Suites, Dormitories, and Similar Occupancies
	(A) General

(B) Receptacle Placement	Article 220 Branch-Circuit, Feeder, and Service
210.62 Show Windows	Load Calculations
210.63 Heating, Air-Conditioning, and Refrigeration	<u>Part I. General</u>
Equipment Outlet	220.1 Scope
210.64 Electrical Service Areas	220.3 Other Articles for Specific-Purpose Calculations
210.70 Lighting Outlets Required	220.5 Calculations
(A) Dwelling Units	(A) Voltages
(B) Guest Rooms or Guest Suites	(B) Fractions of an Ampere
(C) All Occupancies	<u>Part II. Branch-Circuit Load Calculations</u>
210.71 Meeting Rooms	220.10 General
(A) General	220.12 Lighting Load for Specified Occupancies
(B) Receptacle Outlets Required	220.14 Other Loads — All Occupancies
Article 215 Feeders	(A) Specific Appliances or Loads
215.1 Scope	(B) Electric Dryers and Electric Cooking
215.2 Minimum Rating and Size	Appliances in Dwellings and Household
(A) Feeders Not More Than 600 Volts	Cooking Appliances Used in Instructional
(B) Feeders over 600 Volts	Programs
215.3 Overcurrent Protection	(C) Motor Outlets
215.4 Feeders with Common Neutral Conductor	(D) Luminaires
(A) Feeders with Common Neutral	(E) Heavy-Duty Lampholders
(B) In Metal Raceway or Enclosure	(F) Sign and Outline Lighting
215.5 Diagrams of Feeders	(G) Show Windows
215.6 Feeder Equipment Grounding Conductor	(H) Fixed Multioutlet Assemblies
215.7 Ungrounded Conductors Tapped from Grounded	(I) Receptacle Outlets
Systems	(J) Dwelling Occupancies
215.9 Ground-Fault Circuit-Interrupter Protection for	(K) Banks and Office Buildings
Personnel	(L) Other Outlets
215.10 Ground-Fault Protection of Equipment	220.16 Loads for Additions to Existing Installations
215.11 Circuits Derived from Autotransformers	(A) Dwelling Units
215.12 Identification for Feeders	(B) Other Than Dwelling Units
(A) Grounded Conductor	220.18 Maximum Loads
(B) Equipment Grounding Conductor	(A) Motor-Operated and Combination Loads
(C) Identification of Ungrounded Conductors	(B) Inductive and LED Lighting Loads

(C) Range Loads	220.83 Existing Dwelling Unit
<u>Part III. Feeder and Service Load Calculations</u>	(A) Where Additional Air-Conditioning Equipment or Electric Space-Heating Equipment Is Not to Be Installed
220.40 General	(B) Where Additional Air-Conditioning Equipment or Electric Space-Heating Equipment Is to Be Installed
220.42 General Lighting	220.84 Multifamily Dwelling
220.43 Show-Window and Track Lighting	(A) Feeder or Service Load
(A) Show Windows	(B) House Loads
(B) Track Lighting	(C) Calculated Loads
220.44 Receptacle Loads — Other Than Dwelling Units	220.85 Two Dwelling Units
220.50 Motors	220.86 Schools
220.51 Fixed Electric Space Heating	220.87 Determining Existing Loads
220.52 Small-Appliance and Laundry Loads — Dwelling Unit	220.88 New Restaurants
(A) Small-Appliance Circuit Load	<u>Part V. Farm Load Calculations</u>
(B) Laundry Circuit Load	220.100 General
220.53 Appliance Load — Dwelling Unit(s)	220.102 Farm Loads — Buildings and Other Loads
220.54 Electric Clothes Dryers — Dwelling Unit(s)	(A) Dwelling Unit
220.55 Electric Cooking Appliances in Dwelling Units and Household Cooking Appliances Used in Instructional Programs	(B) Other Than Dwelling Unit
220.56 Kitchen Equipment — Other Than Dwelling Unit(s)	220.103 Farm Loads — Total
220.60 Noncoincident Loads	Article 225 Outside Branch Circuits and Feeders
220.61 Feeder or Service Neutral Load	225.1 Scope
(A) Basic Calculation	225.3 Other Articles
(B) Permitted Reductions	<u>Part I. General</u>
(C) Prohibited Reductions	225.4 Conductor Covering
<u>Part IV. Optional Feeder and Service Load Calculations</u>	225.5 Size of Conductors 600 Volts, Nominal, or Less
220.80 General	225.6 Conductor Size and Support
220.82 Dwelling Unit	(A) Overhead Spans
(A) Feeder and Service Load	(B) Festoon Lighting
(B) General Loads	225.7 Lighting Equipment Installed Outdoors
(C) Heating and Air-Conditioning Load	(A) General
	(B) Common Neutral
	(C) 277 Volts to Ground

2017 NEC TABLE OF CONTENTS

(D) 1000 Volts Between Conductors	225.24 Outdoor Lampholders
225.8 Calculation of Loads 1000 Volts, Nominal, or Less	225.25 Location of Outdoor Lamps
(A) Branch Circuits	225.26 Vegetation as Support
(B) Feeders	225.27 Raceway Seal
225.10 Wiring on Buildings (or Other Structures)	<u>Part II. Buildings or Other Structures Supplied</u>
225.11 Feeder and Branch-Circuit Conductors Entering, Exiting, or Attached to Buildings or Structures	by a Feeder(s) or Branch Circuit(s)
225.12 Open-Conductor Supports	225.30 Number of Supplies
225.14 Open-Conductor Spacings	(A) Special Conditions
(A) 1000 Volts, Nominal, or Less	(B) Special Occupancies
(B) Over 1000 Volts, Nominal	(C) Capacity Requirements
(C) Separation from Other Circuits	(D) Different Characteristics
(D) Conductors on Poles	(E) Documented Switching Procedures
225.15 Supports over Buildings	(F) One- or Two-Family Dwelling Unit(s)
225.16 Attachment to Buildings	225.31 Disconnecting Means
(A) Point of Attachment	225.32 Location
(B) Means of Attachment	225.33 Maximum Number of Disconnects
225.17 Masts as Supports	(A) General
(A) Strength	(B) Single-Pole Units
(B) Attachment	225.34 Grouping of Disconnects
225.18 Clearance for Overhead Conductors and Cables	(A) General
225.19 Clearances from Buildings for Conductors of Not over 1000 Volts, Nominal	(B) Additional Disconnecting Means
(A) Above Roofs	225.35 Access to Occupants
(B) From Nonbuilding or Nonbridge Structures	225.36 Type of Disconnecting Means
(C) Horizontal Clearances	225.37 Identification
(D) Final Spans	225.38 Disconnect Construction
(E) Zone for Fire Ladders	(A) Manually or Power Operable
225.20 Protection Against Physical Damage	(B) Simultaneous Opening of Poles
225.21 Multiconductor Cables on Exterior Surfaces of Buildings (or Other Structures)	(C) Disconnection of Grounded Conductor
225.22 Raceways on Exterior Surfaces of Buildings or Other Structures	(D) Indicating
	225.39 Rating of Disconnect
	(A) One-Circuit Installation
	(B) Two-Circuit Installations
	(C) One-Family Dwelling

2017 NEC TABLE OF CONTENTS

(D) All Others	Supplied Through Another
225.40 Access to Overcurrent Protective Devices	230.6 Conductors Considered Outside the Building
<u>Part III. Over 1000 Volts</u>	230.7 Other Conductors in Raceway or Cable
225.50 Sizing of Conductors	230.8 Raceway Seal
225.51 Isolating Switches	230.9 Clearances on Buildings
225.52 Disconnecting Means	(A) Clearances
(A) Location	(B) Vertical Clearance
(B) Type	(C) Building Openings
(C) Locking	230.10 Vegetation as Support
(D) Indicating	<u>Part II. Overhead Service Conductors</u>
(E) Uniform Position	230.22 Insulation or Covering
(F) Identification	230.23 Size and Rating
225.56 Inspections and Tests	(A) General
(A) Pre-Energization and Operating Tests	(B) Minimum Size
(B) Test Report	(C) Grounded Conductors
225.60 Clearances over Roadways, Walkways, Rail, Water, and Open Land	230.24 Clearances
(A) 22 kV, Nominal, to Ground or Less	(A) Above Roofs
(B) Over 22 kV Nominal to Ground	(B) Vertical Clearance for Overhead Service Conductors
(C) Special Cases	(C) Clearance from Building Openings
225.61 Clearances over Buildings and Other Structures	(D) Clearance from Swimming Pools
(A) 22 kV Nominal to Ground or Less	(E) Clearance from Communication Wires and Cables
(B) Over 22 kV Nominal to Ground	230.26 Point of Attachment
Article 230 Services	230.27 Means of Attachment
230.1 Scope	230.28 Service Masts as Supports
<u>Part I. General</u>	(A) Strength
230.2 Number of Services	(B) Attachment
(A) Special Conditions	230.29 Supports over Buildings
(B) Special Occupancies	<u>Part III. Underground Service Conductors</u>
(C) Capacity Requirements	230.30 Installation
(D) Different Characteristics	(A) Insulation
(E) Identification	(B) Wiring Methods
230.3 One Building or Other Structure Not to Be	230.31 Size and Rating
	(A) General

2017 NEC TABLE OF CONTENTS

(B) Minimum Size	(G) Arranged That Water Will Not Enter Service Raceway or Equipment
(C) Grounded Conductors	
230.32 Protection Against Damage	230.56 Service Conductor with the Higher Voltage to Ground
230.33 Spliced Conductors	
<u>Part IV. Service-Entrance Conductors</u>	<u>Part V. Service Equipment — General</u>
230.40 Number of Service-Entrance Conductor Sets	230.62 Service Equipment — Enclosed or Guarded
230.41 Insulation of Service-Entrance Conductors	(A) Enclosed
230.42 Minimum Size and Rating	(B) Guarded
(A) General	230.66 Marking
(B) Specific Installations	<u>Part VI. Service Equipment — Disconnecting Means</u>
(C) Grounded Conductors	230.70 General
230.43 Wiring Methods for 1000 Volts, Nominal, or Less	(A) Location
230.44 Cable Trays	(B) Marking
230.46 Spliced Conductors	(C) Suitable for Use
230.50 Protection Against Physical Damage	230.71 Maximum Number of Disconnects
(A) Underground Service-Entrance Conductors	(A) General
(B) All Other Service-Entrance Conductors	(B) Single-Pole Units
230.51 Mounting Supports	230.72 Grouping of Disconnects
(A) Service-Entrance Cables	(A) General
(B) Other Cables	(B) Additional Service Disconnecting Means
(C) Individual Open Conductors	(C) Access to Occupants
230.52 Individual Conductors Entering Buildings or Other Structures	230.74 Simultaneous Opening of Poles
230.53 Raceways to Drain	230.75 Disconnection of Grounded Conductor
230.54 Overhead Service Locations	230.76 Manually or Power Operable
(A) Service Head	230.77 Indicating
(B) Service-Entrance Cables Equipped with Service Head or Gooseneck	230.79 Rating of Service Disconnecting Means
(C) Service Heads and Goosenecks Above Service-Drop or Overhead Service Attachment	(A) One-Circuit Installations
(D) Secured	(B) Two-Circuit Installations
(E) Separately Bushed Openings	(C) One-Family Dwellings
(F) Drip Loops	(D) All Others
	230.80 Combined Rating of Disconnects
	230.81 Connection to Terminals
	230.82 Equipment Connected to the Supply Side

of Service Disconnect	230.210 Service Equipment — General Provisions
<u>Part VII. Service Equipment — Overcurrent Protection</u>	230.211 Switchgear
230.90 Where Required	230.212 Over 35,000 Volts
(A) Ungrounded Conductor	Article 240 Overcurrent Protection
(B) Not in Grounded Conductor	<u>Part I. General</u>
230.91 Location	240.1 Scope
230.92 Locked Service Overcurrent Devices	240.2 Definitions
230.93 Protection of Specific Circuits	240.3 Other Articles
230.94 Relative Location of Overcurrent Device and Other Service Equipment	240.4 Protection of Conductors
230.95 Ground-Fault Protection of Equipment	(A) Power Loss Hazard
(A) Setting	(B) Overcurrent Devices Rated 800 Amperes or Less
(B) Fuses	(C) Overcurrent Devices Rated over 800 Amperes
(C) Performance Testing	(D) Small Conductors
<u>Part VIII. Services Exceeding 1000 Volts, Nominal</u>	(E) Tap Conductors
230.200 General	(F) Transformer Secondary Conductors
230.202 Service-Entrance Conductors	(G) Overcurrent Protection for Specific Conductor Applications
(A) Conductor Size	240.5 Protection of Flexible Cords, Flexible Cables, and Fixture Wires
(B) Wiring Methods	(A) Ampacities
230.204 Isolating Switches	(B) Branch-Circuit Overcurrent Device
(A) Where Required	240.6 Standard Ampere Ratings
(B) Fuses as Isolating Switch	(A) Fuses and Fixed-Trip Circuit Breakers
(C) Accessible to Qualified Persons Only	(B) Adjustable-Trip Circuit Breakers
(D) Connection to Ground	(C) Restricted Access Adjustable-Trip Circuit Breakers
230.205 Disconnecting Means	240.8 Fuses or Circuit Breakers in Parallel
(A) Location	240.9 Thermal Devices
(B) Type	240.10 Supplementary Overcurrent Protection
(C) Remote Control	240.12 Electrical System Coordination
230.206 Overcurrent Devices as Disconnecting Means	240.13 Ground-Fault Protection of Equipment
230.208 Protection Requirements	240.15 Ungrounded Conductors
(A) Equipment Type	(A) Overcurrent Device Required
(B) Enclosed Overcurrent Devices	(B) Circuit Breaker as Overcurrent Device
230.209 Surge Arresters	

<u>Part II. Location</u>	(B) Marking
240.21 Location in Circuit	(C) Hexagonal Configuration
(A) Branch-Circuit Conductors	(D) No Energized Parts
(B) Feeder Taps	(E) Screw Shell
(C) Transformer Secondary Conductors	240.51 Edison-Base Fuses
(D) Service Conductors	(A) Classification
(E) Busway Taps	(B) Replacement Only
(F) Motor Circuit Taps	240.52 Edison-Base Fuseholders
(G) Conductors from Generator Terminals	240.53 Type S Fuses
(H) Battery Conductors	(A) Classification
240.22 Grounded Conductor	(B) Noninterchangeable
240.23 Change in Size of Grounded Conductor	240.54 Type S Fuses, Adapters, and Fuseholders
240.24 Location in or on Premises	(A) To Fit Edison-Base Fuseholders
(A) Accessibility	(B) To Fit Type S Fuses Only
(B) Occupancy	(C) Nonremovable
(C) Not Exposed to Physical Damage	(D) Nontamperable
(D) Not in Vicinity of Easily Ignitable Material	(E) Interchangeability
(E) Not Located in Bathrooms	<u>Part VI. Cartridge Fuses and Fuseholders</u>
(F) Not Located over Steps	240.60 General
<u>Part III. Enclosures</u>	(A) Maximum Voltage — 300-Volt Type
240.30 General	(B) Noninterchangeable — 0–6000-Ampere Cartridge Fuseholders
(A) Protection from Physical Damage	(C) Marking
(B) Operating Handle	(D) Renewable Fuses
240.32 Damp or Wet Locations	240.61 Classification
240.33 Vertical Position	240.67 Arc Energy Reduction
<u>Part IV. Disconnecting and Guarding</u>	(A) Documentation
240.40 Disconnecting Means for Fuses	(B) Method to Reduce Clearing Time
240.41 Arcing or Suddenly Moving Parts	<u>Part VII. Circuit Breakers</u>
(A) Location	240.80 Method of Operation
(B) Suddenly Moving Parts	240.81 Indicating
<u>Part V. Plug Fuses, Fuseholders, and Adapters</u>	240.82 Nontamperable
240.50 General	240.83 Marking
(A) Maximum Voltage	

2017 NEC TABLE OF CONTENTS

(A) Durable and Visible	(A) Rating or Setting of Overcurrent Protective Devices
(B) Location	(B) Feeder Taps
(C) Interrupting Rating	Article 250 Grounding and Bonding
(D) Used as Switches	<u>Part I. General</u>
(E) Voltage Marking	250.1 Scope
240.85 Applications	250.2 Definition
240.86 Series Ratings	250.3 Application of Other Articles
(A) Selected Under Engineering Supervision in Existing Installations	250.4 General Requirements for Grounding and Bonding
(B) Tested Combinations	(A) Grounded Systems
(C) Motor Contribution	(B) Ungrounded Systems
240.87 Arc Energy Reduction	250.6 Objectionable Current
(A) Documentation	(A) Arrangement to Prevent Objectionable Current
(B) Method to Reduce Clearing Time	(B) Alterations to Stop Objectionable Current
<u>Part VIII. Supervised Industrial Installations</u>	(C) Temporary Currents Not Classified as Objectionable Currents
240.90 General	(D) Limitations to Permissible Alterations
240.91 Protection of Conductors	(E) Isolation of Objectionable Direct-Current Ground Currents
(A) General	250.8 Connection of Grounding and Bonding Equipment
(B) Devices Rated Over 800 Amperes	(A) Permitted Methods
240.92 Location in Circuit	(B) Methods Not Permitted
(A) Feeder and Branch-Circuit Conductors	250.10 Protection of Ground Clamps and Fittings
(B) Feeder Taps	250.12 Clean Surfaces
(C) Transformer Secondary Conductors of Separately Derived Systems	<u>Part II. System Grounding</u>
(D) Outside Feeder Taps	250.20 Alternating-Current Systems to Be Grounded
(E) Protection by Primary Overcurrent Device	(A) Alternating-Current Systems of Less Than 50 Volts
<u>Part IX. Overcurrent Protection over 1000 Volts, Nominal</u>	(B) Alternating-Current Systems of 50 Volts to 1000 Volts
240.100 Feeders and Branch Circuits	(C) Alternating-Current Systems of over 1000 Volts
(A) Location and Type of Protection	(D) Impedance Grounded Neutral Systems
(B) Protective Devices	250.21 Alternating-Current Systems of 50 Volts to 1000 Volts Not Required to Be Grounded
(C) Conductor Protection	(A) General
240.101 Additional Requirements for Feeders	(B) Ground Detectors

2017 NEC TABLE OF CONTENTS

(C) Marking	250.35 Permanently Installed Generators
250.22 Circuits Not to Be Grounded	(A) Separately Derived System
250.24 Grounding Service-Supplied Alternating-Current Systems	(B) Nonseparately Derived System
(A) System Grounding Connections	250.36 High-Impedance Grounded Neutral Systems
(B) Main Bonding Jumper	(A) Location
(C) Grounded Conductor Brought to Service Equipment	(B) Conductor Insulation and Ampacity
(D) Grounding Electrode Conductor	(C) System Grounding Connection
(E) Ungrounded System Grounding Connections	(D) Conductor Routing
250.26 Conductor to Be Grounded — Alternating-Current Systems	(E) Equipment Bonding Jumper
250.28 Main Bonding Jumper and System Bonding Jumper	(F) Grounding Electrode Conductor Connection Location
(A) Material	(G) Equipment Bonding Jumper Size
(B) Construction	<u>Part III. Grounding Electrode System and Grounding Electrode Conductor</u>
(C) Attachment	250.50 Grounding Electrode System
(D) Size	250.52 Grounding Electrodes
250.30 Grounding Separately Derived Alternating Current Systems	(A) Electrodes Permitted for Grounding
(A) Grounded Systems	(B) Not Permitted for Use as Grounding Electrodes
(B) Ungrounded Systems	250.53 Grounding Electrode System Installation
(C) Outdoor Source	(A) Rod, Pipe, and Plate Electrodes
250.32 Buildings or Structures Supplied by a Feeder(s) or Branch Circuit(s)	(B) Electrode Spacing
(A) Grounding Electrode	(C) Bonding Jumper
(B) Grounded Systems	(D) Metal Underground Water Pipe
(C) Ungrounded Systems	(E) Supplemental Electrode Bonding Connection Size
(D) Disconnecting Means Located in Separate Building or Structure on the Same Premises	(F) Ground Ring
(E) Grounding Electrode Conductor	(G) Rod and Pipe Electrodes
250.34 Portable and Vehicle-Mounted Generators	(H) Plate Electrode
(A) Portable Generators	250.54 Auxiliary Grounding Electrodes
(B) Vehicle-Mounted Generators	250.58 Common Grounding Electrode
(C) Grounded Conductor Bonding	250.60 Use of Strike Termination Devices
	250.62 Grounding Electrode Conductor Material
	250.64 Grounding Electrode Conductor Installation
	(A) Aluminum or Copper-Clad Aluminum Conductors
	(B) Securing and Protection Against Physical Damage

2017 NEC TABLE OF CONTENTS

(C) Continuous	(A) General
(D) Building or Structure with Multiple Disconnecting Means in Separate Enclosures	(B) Isolated Grounding Circuits
(E) Raceways and Enclosures for Grounding Electrode Conductors	250.97 Bonding for Over 250 Volts
(F) Installation to Electrode(s)	250.98 Bonding Loosely Jointed Metal Raceways
250.66 Size of Alternating-Current Grounding Electrode Conductor	250.100 Bonding in Hazardous (Classified) Locations
(A) Connections to a Rod, Pipe, or Plate Electrode(s)	250.102 Grounded Conductor, Bonding Conductors, and Jumpers
(B) Connections to Concrete-Encased Electrodes	(A) Material
(C) Connections to Ground Rings	(B) Attachment
250.68 Grounding Electrode Conductor and Bonding Jumper Connection to Grounding Electrodes	(C) Size — Supply-Side Bonding Jumper
(A) Accessibility	(D) Size — Equipment Bonding Jumper on Load Side of an Overcurrent Device
(B) Effective Grounding Path	(E) Installation
(C) Grounding Electrode Conductor Connections	250.104 Bonding of Piping Systems and Exposed Structural Metal
250.70 Methods of Grounding and Bonding Conductor Connection to Electrodes	(A) Metal Water Piping
<u>Part IV. Enclosure, Raceway, and Service Cable Connections</u>	(B) Other Metal Piping
250.80 Service Raceways and Enclosures	(C) Structural Metal
250.84 Underground Service Cable or Raceway	(D) Separately Derived Systems
(A) Underground Service Cable	<u>250. Part VI. Equipment Grounding and Equipment Grounding Conductors</u>
(B) Underground Service Raceway Containing Cable	250.110 Equipment Fastened in Place (Fixed) or Connected by Permanent Wiring Methods
250.86 Other Conductor Enclosures and Raceways	250.112 Specific Equipment Fastened in Place (Fixed) or Connected by Permanent Wiring Methods
<u>Part V. Bonding</u>	(A) Switchgear and Switchboard Frames and Structures
250.90 General	(B) Pipe Organs
250.92 Services	(C) Motor Frames
(A) Bonding of Equipment for Services	(D) Enclosures for Motor Controllers
(B) Method of Bonding at the Service	(E) Elevators and Cranes
250.94 Bonding for Communication Systems	(F) Garages, Theaters, and Motion Picture Studios
(A) The Intersystem Bonding Termination Device	(G) Electric Signs
(B) Other Means	(H) Motion Picture Projection Equipment
250.96 Bonding Other Enclosures	

2017 NEC TABLE OF CONTENTS

(I) Remote-Control, Signaling, and Fire Alarm Circuits	(B) For Ungrounded Systems
(J) Luminaires	(C) Nongrounding Receptacle Replacement or Branch Circuit Extensions
(K) Skid-Mounted Equipment	250.132 Short Sections of Raceway
(L) Motor-Operated Water Pumps	250.134 Equipment Fastened in Place or Connected by Permanent Wiring Methods (Fixed) — Grounding
(M) Metal Well Casings	(A) Equipment Grounding Conductor Types
250.114 Equipment Connected by Cord and Plug	(B) With Circuit Conductors
250.116 Nonelectrical Equipment	250.136 Equipment Considered Grounded
250.118 Types of Equipment Grounding Conductors	(A) Equipment Secured to Grounded Metal Supports
250.119 Identification of Equipment Grounding Conductors	(B) Metal Car Frames
(A) Conductors 4 AWG and Larger	250.138 Cord-and-Plug-Connected Equipment
(B) Multiconductor Cable	(A) By Means of an Equipment Grounding Conductor
(C) Flexible Cord	(B) By Means of a Separate Flexible Wire or Strap
250.120 Equipment Grounding Conductor Installation	250.140 Frames of Ranges and Clothes Dryers
(A) Raceway, Cable Trays, Cable Armor, Cablebus, or Cable Sheaths	250.142 Use of Grounded Circuit Conductor for Grounding Equipment
(B) Aluminum and Copper-Clad Aluminum Conductors	(A) Supply-Side Equipment
(C) Equipment Grounding Conductors Smaller Than 6 AWG	(B) Load-Side Equipment
250.121 Use of Equipment Grounding Conductors	250.144 Multiple Circuit Connections
250.122 Size of Equipment Grounding Conductors	250.146 Connecting Receptacle Grounding Terminal to Box
(A) General	(A) Surface-Mounted Box
(B) Increased in Size	(B) Contact Devices or Yokes
(C) Multiple Circuits	(C) Floor Boxes
(D) Motor Circuits	(D) Isolated Ground Receptacles
(E) Flexible Cord and Fixture Wire	250.148 Continuity and Attachment of Equipment Grounding Conductors to Boxes
(F) Conductors in Parallel	(A) Connections
(G) Feeder Taps	(B) Grounding Continuity
250.124 Equipment Grounding Conductor Continuity	(C) Metal Boxes
(A) Separable Connections	(D) Nonmetallic Boxes
(B) Switches	(E) Solder
250.126 Identification of Wiring Device Terminals	<u>Part VIII. Direct-Current Systems</u>
<u>Part VII. Methods of Equipment Grounding</u>	
250.130 Equipment Grounding Conductor Connections	
(A) For Grounded Systems	

2017 NEC TABLE OF CONTENTS

250.160 General	250.178 Instrument Equipment Grounding Conductor
250.162 Direct-Current Circuits and Systems to Be Grounded	<u>Part X. Grounding of Systems and Circuits of over 1000 Volts</u>
(A) Two-Wire, Direct-Current Systems	250.180 General
(B) Three-Wire, Direct-Current Systems	250.182 Derived Neutral Systems
250.164 Point of Connection for Direct-Current Systems	250.184 Solidly Grounded Neutral Systems
(A) Off-Premises Source	(A) Neutral Conductor
(B) On-Premises Source	(B) Single-Point Grounded Neutral System
250.166 Size of the Direct-Current Grounding Electrode Conductor	(C) Multigrounded Neutral Systems
(A) Not Smaller Than the Neutral Conductor	250.186 Grounding Service-Supplied Alternating-Current Systems
(B) Not Smaller Than the Largest Conductor	(A) Systems with a Grounded Conductor at the Service Point
(C) Connected to Rod, Pipe, or Plate Electrodes	(B) Systems Without a Grounded Conductor at the Service Point
(D) Connected to a Concrete-Encased Electrode	250.187 Impedance Grounded Neutral Systems
(E) Connected to a Ground Ring ¹⁰⁶ Lightning Protection Systems	(A) Location
250.167 Direct-Current Ground-Fault Detection	(B) Identified and Insulated
(A) Ungrounded Systems	(C) System Neutral Conductor Connection
(B) Grounded Systems	(D) Equipment Grounding Conductors
(C) Marking	250.188 Grounding of Systems Supplying Portable or Mobile Equipment
250.168 Direct-Current System Bonding Jumper	(A) Portable or Mobile Equipment
250.169 Ungrounded Direct-Current Separately Derived Systems	(B) Exposed Non–Current-Carrying Metal Parts
<u>Part IX. Instruments, Meters, and Relays</u>	(C) Ground-Fault Current
250.170 Instrument Transformer Circuits	(D) Ground-Fault Detection and Relaying
250.172 Instrument Transformer Cases	(E) Isolation
250.174 Cases of Instruments, Meters, and Relays Operating at 1000 Volts or Less	(F) Trailing Cable and Couplers
(A) Not on Switchgear or Switchboards	250.190 Grounding of Equipment
(B) On Switchgear or Dead-Front Switchboards	(A) Equipment Grounding
(C) On Live-Front Switchboards	(B) Grounding Electrode Conductor
250.176 Cases of Instruments, Meters, and Relays — Operating at 1000 Volts and Over	(C) Equipment Grounding Conductor
	250.191 Grounding System at Alternating-Current

Substations	285.11 Location
250.194 Grounding and Bonding of Fences and Other Metal Structures	285.12 Routing of Connections
(A) Metal Fences	285.13 Type 4 and Other Component Type SPDs
(B) Metal Structures	<u>Part III. Connecting SPDs</u>
Article 280 Surge Arresters, Over 1000 Volts	285.21 Connection
<u>Part I. General</u>	285.23 Type 1 SPDs
280.1 Scope	(A) Installation
280.3 Number Required	(B) At the Service
280.4 Surge Arrester Selection	285.24 Type 2 SPDs
(A) Rating	(A) Service-Supplied Building or Structure
(B) Silicon Carbide Types	(B) Feeder-Supplied Building or Structure
<u>Part II. Installation</u>	(C) Separately Derived System
280.12 Uses Not Permitted	285.25 Type 3 SPDs
280.14 Routing of Surge Arrester Grounding Conductors	285.26 Conductor Size
Part III. Connecting Surge Arresters	285.27 Connection Between Conductors
280.21 Connection	285.28 Grounding Electrode Conductor Connections and Enclosures
280.23 Surge-Arrester Conductors	Article 300 General Requirements for Wiring Methods and Materials
280.24 Interconnections	<u>Part I. General Requirements</u>
(A) Metal Interconnections	300.1 Scope
(B) Through Spark Gap or Device	(A) All Wiring Installations
(C) By Special Permission	(B) Integral Parts of Equipment
280.25 Grounding Electrode Conductor Connections and Enclosures	(C) Metric Designators and Trade Sizes
Article 285 Surge-Protective Devices (SPDs), 1000 Volts or Less	300.2 Limitations
<u>Part I. General</u>	(A) Voltage
285.1 Scope	(B) Temperature
285.3 Uses Not Permitted	300.3 Conductors
285.4 Number Required	(A) Single Conductors
285.6 Listing	(B) Conductors of the Same Circuit
285.7 Short-Circuit Current Rating	(C) Conductors of Different Systems
<u>Part II. Installation</u>	300.4 Protection Against Physical Damage
	(A) Cables and Raceways Through Wood Members

2017 NEC TABLE OF CONTENTS

<p>(B) Nonmetallic-Sheathed Cables and Electrical Nonmetallic Tubing Through Metal Framing Members</p> <p>(C) Cables Through Spaces Behind Panels Designed to Allow Access</p> <p>(D) Cables and Raceways Parallel to Framing Members and Furring Strips</p> <p>(E) Cables, Raceways, or Boxes Installed in or Under Roof Decking</p> <p>(F) Cables and Raceways Installed in Shallow Grooves</p> <p>(G) Insulated Fittings</p> <p>(H) Structural Joints</p> <p>300.5 Underground Installations</p> <p>(A) Minimum Cover Requirements</p> <p>(B) Wet Locations</p> <p>(C) Underground Cables and Conductors Under Buildings</p> <p>(D) Protection from Damage</p> <p>(E) Splices and Taps</p> <p>(F) Backfill</p> <p>(G) Raceway Seals</p> <p>(H) Bushing</p> <p>(I) Conductors of the Same Circuit</p> <p>(J) Earth Movement</p> <p>(K) Directional Boring</p> <p>300.6 Protection Against Corrosion and Deterioration</p> <p>(A) Ferrous Metal Equipment</p> <p>(B) Aluminum Metal Equipment</p> <p>(C) Nonmetallic Equipment</p> <p>(D) Indoor Wet Locations</p> <p>300.7 Raceways Exposed to Different Temperatures</p> <p>(A) Sealing</p> <p>(B) Expansion, Expansion-Deflection, and Deflection Fittings</p> <p>300.8 Installation of Conductors with Other Systems</p>	<p>300.9 Raceways in Wet Locations Abovegrade</p> <p>300.10 Electrical Continuity of Metal Raceways and Enclosures</p> <p>300.11 Securing and Supporting</p> <p>(A) Secured in Place</p> <p>(B) Wiring Systems Installed Above Suspended Ceilings</p> <p>(C) Raceways Used as Means of Support</p> <p>(D) Cables Not Used as Means of Support</p> <p>300.12 Mechanical Continuity — Raceways and Cables</p> <p>300.13 Mechanical and Electrical Continuity — Conductors</p> <p>(A) General</p> <p>(B) Device Removal</p> <p>300.14 Length of Free Conductors at Outlets, Junctions, and Switch Points</p> <p>300.15 Boxes, Conduit Bodies, or Fittings — Where Required</p> <p>(A) Wiring Methods with Interior Access</p> <p>(B) Equipment</p> <p>(C) Protection</p> <p>(D) Type MI Cable</p> <p>(E) Integral Enclosure</p> <p>(F) Fitting</p> <p>(G) Direct-Buried Conductors</p> <p>(H) Insulated Devices</p> <p>(I) Enclosures</p> <p>(J) Luminaires</p> <p>(K) Embedded</p> <p>(L) Manholes and Handhole Enclosures</p> <p>300.16 Raceway or Cable to Open or Concealed Wiring</p> <p>(A) Box, Conduit Body, or Fitting</p> <p>(B) Bushing</p> <p>300.17 Number and Size of Conductors in Raceway</p>
---	--

2017 NEC TABLE OF CONTENTS

300.18 Raceway Installations	Cables
(A) Complete Runs	300.45 Warning Signs
(B) Welding	300.50 Underground Installations
300.19 Supporting Conductors in Vertical Raceways	(A) General
(A) Spacing Intervals — Maximum	(B) Wet Locations
(B) Fire-Rated Cables and Conductors	(C) Protection from Damage
(C) Support Methods	(D) Splices
300.20 Induced Currents in Ferrous Metal Enclosures or Ferrous Metal Raceways	(E) Backfill
(A) Conductors Grouped Together	(F) Raceway Seal
(B) Individual Conductors	Article 310 Conductors for General Wiring
300.21 Spread of Fire or Products of Combustion	<u>Part I. General</u>
300.22 Wiring in Ducts Not Used for Air Handling, Fabricated Ducts for Environmental Air, and Other Spaces for Environmental Air (Plenums)	310.1 Scope
(A) Ducts for Dust, Loose Stock, or Vapor Removal	310.2 Definitions
(B) Ducts Specifically Fabricated for Environmental Air	<u>Part II. Installation</u>
(C) Other Spaces Used for Environmental Air (Plenums)	310.10 Uses Permitted
(D) Information Technology Equipment	(A) Dry Locations
300.23 Panels Designed to Allow Access	(B) Dry and Damp Locations
<u>Part II. Requirements for over 1000 Volts, Nominal</u>	(C) Wet Locations
300.31 Covers Required	(D) Locations Exposed to Direct Sunlight
300.32 Conductors of Different Systems	(E) Shielding
300.34 Conductor Bending Radius	(F) Direct-Burial Conductors
300.35 Protection Against Induction Heating	(G) Corrosive Conditions
300.37 Aboveground Wiring Methods	(H) Conductors in Parallel
300.38 Raceways in Wet Locations Above Grade	310.15 Ampacities for Conductors Rated 0–2000 Volts
300.39 Braid-Covered Insulated Conductors — Exposed Installation	(A) General
300.40 Insulation Shielding	(B) Tables
300.42 Moisture or Mechanical Protection for Metal Sheathed	(C) Engineering Supervision
	310.60 Conductors Rated 2001 to 35,000 Volts
	(A) Ampacities of Conductors Rated 2001 to 35,000 Volts
	(B) Engineering Supervision
	(C) Tables
	<u>Part III. Construction Specifications</u>

2017 NEC TABLE OF CONTENTS

310.104 Conductor Constructions and Applications	(A) Splices, Taps, and Feed-Through Conductors
310.106 Conductors	(B) Power Monitoring Equipment
(A) Minimum Size of Conductors	312.9 Side or Back Wiring Spaces or Gutters
(B) Conductor Material	<u>Part II. Construction Specifications</u>
(C) Stranded Conductors	312.10 Material
(D) Insulated	(A) Metal Cabinets and Cutout Boxes
310.110 Conductor Identification	(B) Strength
(A) Grounded Conductors	(C) Nonmetallic Cabinets
(B) Equipment Grounding Conductors	312.11 Spacing
(C) Ungrounded Conductors	(A) General
310.120 Marking	(B) Switch Clearance
(A) Required Information	(C) Wiring Space
(B) Method of Marking	(D) Wiring Space — Enclosure
(C) Suffixes to Designate Number of Conductors	Article 314 Outlet, Device, Pull, and Junction
(D) Optional Markings	Boxes; Conduit Bodies; Fittings;
Article 312 Cabinets, Cutout Boxes,	and Handhole Enclosures
and Meter Socket Enclosures	<u>Part I. Scope and General</u>
<u>Part I. Scope and Installation</u>	314.1 Scope
312.1 Scope	314.2 Round Boxes
312.2 Damp and Wet Locations	314.3 Nonmetallic Boxes
312.3 Position in Wall	314.4 Metal Boxes
312.4 Repairing Noncombustible Surfaces	<u>Part II. Installation</u>
312.5 Cabinets, Cutout Boxes, and Meter Socket Enclosure	314.15 Damp or Wet Locations
(A) Openings to Be Closed	314.16 Number of Conductors in Outlet, Device, and
(B) Metal Cabinets, Cutout Boxes, and Meter	Junction Boxes, and Conduit Bodies
Socket Enclosures	(A) Box Volume Calculations
(C) Cables	(B) Box Fill Calculations
312.6 Deflection of Conductors	(C) Conduit Bodies
(A) Width of Wiring Gutters	314.17 Conductors Entering Boxes, Conduit Bodies,
(B) Wire-Bending Space at Terminals	or Fittings
(C) Conductors 4 AWG or Larger	(A) Openings to Be Closed
312.7 Space in Enclosures	(B) Metal Boxes and Conduit Bodies
312.8 Switch and Overcurrent Device Enclosures	(C) Nonmetallic Boxes and Conduit Bodies

2017 NEC TABLE OF CONTENTS

(D) Conductors 4 AWG or Larger	(B) Conductors in Pull or Junction Boxes
314.19 Boxes Enclosing Flush Devices	(C) Covers
314.20 Flush-Mounted Installations	(D) Permanent Barriers
314.21 Repairing Noncombustible Surfaces	(E) Power Distribution Blocks
314.22 Surface Extensions	314.29 Boxes, Conduit Bodies, and Handhole Enclosures to Be Accessible
314.23 Supports	314.30 Handhole Enclosures
(A) Surface Mounting	(A) Size
(B) Structural Mounting	(B) Wiring Entries
(C) Mounting in Finished Surfaces	(C) Enclosed Wiring
(D) Suspended Ceilings	(D) Covers
(E) Raceway-Supported Enclosure, Without Devices, Luminaires, or Lampholders	<u>Part III. Construction Specifications</u>
(F) Raceway-Supported Enclosures, with Devices, Luminaires, or Lampholders	314.40 Metal Boxes, Conduit Bodies, and Fittings
(G) Enclosures in Concrete or Masonry	(A) Corrosion Resistant
(H) Pendant Boxes	(B) Thickness of Metal
314.24 Depth of Boxes	(C) Metal Boxes Over 1650 cm ³ (100 in. ³)
(A) Outlet Boxes Without Enclosed Devices or Utilization Equipment	(D) Grounding Provisions
(B) Outlet and Device Boxes with Enclosed Devices or Utilization Equipment	314.41 Covers
314.25 Covers and Canopies	314.42 Bushings
(A) Nonmetallic or Metal Covers and Plates	314.43 Nonmetallic Boxes
(B) Exposed Combustible Wall or Ceiling Finish	314.44 Marking
(C) Flexible Cord Pendants	<u>Part IV. Pull and Junction Boxes, Conduit Bodies, and Handhole Enclosures for Use on Systems over 1000 Volts, Nominal</u>
314.27 Outlet Boxes	314.70 General
(A) Boxes at Luminaire or Lampholder Outlets	(A) Pull and Junction Boxes
(B) Floor Boxes	(B) Conduit Bodies
(C) Boxes at Ceiling-Suspended (Paddle) Fan Outlets	(C) Handhole Enclosures
(D) Utilization Equipment	314.71 Size of Pull and Junction Boxes, Conduit Bodies, and Handhole Enclosures
(E) Separable Attachment Fittings	(A) For Straight Pulls
314.28 Pull and Junction Boxes and Conduit Bodies	(B) For Angle or U Pulls
(A) Minimum Size	

(C) Removable Sides	320.104 Conductors
314.72 Construction and Installation Requirements	320.108 Equipment Grounding Conductor
(A) Corrosion Protection	320.120 Marking
(B) Passing Through Partitions	Article 322 Flat Cable Assemblies: Type FC
(C) Complete Enclosure	<u>Part I. General</u>
(D) Wiring Is Accessible	322.1 Scope
(E) Suitable Covers	322.2 Definition
(F) Suitable for Expected Handling	322.6 Listing Requirements
Article 320 Armored Cable: Type AC	<u>Part II. Installation</u>
<u>Part I. General</u>	322.10 Uses Permitted
320.1 Scope	322.12 Uses Not Permitted
320.2 Definition	322.30 Securing and Supporting
320.6 Listing Requirements	322.40 Boxes and Fittings
<u>Part II. Installation</u>	(A) Dead Ends
320.10 Uses Permitted	(B) Luminaire Hangers
320.12 Uses Not Permitted	(C) Fittings
320.15 Exposed Work	(D) Extensions
320.17 Through or Parallel to Framing Members	322.56 Splices and Taps
320.23 In Accessible Attics	(A) Splices
(A) Cables Run Across the Top of Floor Joists	(B) Taps
(B) Cable Installed Parallel to Framing Members	<u>Part III. Construction Specifications</u>
320.24 Bending Radius	322.100 Construction
320.30 Securing and Supporting	322.104 Conductors
(A) General	322.112 Insulation
(B) Securing	322.120 Marking
(C) Supporting	(A) Temperature Rating
(D) Unsupported Cables	(B) Identification of Grounded Conductor
320.40 Boxes and Fittings	(C) Terminal Block Identification
320.80 Ampacity	Article 324 Flat Conductor Cable: Type FCC
(A) Thermal Insulation	<u>Part I. General</u>
(B) Cable Tray	324.1 Scope
<u>Part III. Construction Specifications</u>	324.2 Definitions
320.100 Construction	324.6 Listing Requirements

Part II. Installation

324.10 Uses Permitted

(A) Branch Circuits

(B) Branch-Circuit Ratings

(C) Floors

(D) Walls

(E) Damp Locations

(F) Heated Floors

(G) System Height

324.12 Uses Not Permitted

324.18 Crossings

324.30 Securing and Supporting

324.40 Boxes and Fittings

(A) Cable Connections and Insulating Ends

(B) Polarization of Connections

(C) Shields

(D) Connection to Other Systems

(E) Metal-Shield Connectors

324.41 Floor Coverings

324.42 Devices

(A) Receptacles

(B) Receptacles and Housings

324.56 Splices and Taps

(A) FCC Systems Alterations

(B) Transition Assemblies

324.60 Grounding

Part III. Construction Specifications

324.100 Construction

(A) Type FCC Cable

(B) Shields

324.101 Corrosion Resistance

324.112 Insulation

324.120 Markings

(A) Cable Marking

(B) Conductor Identification

Article 326 Integrated Gas Spacer Cable: Type IGSPart I. General

326.1 Scope

326.2 Definition

Part II. Installation

326.10 Uses Permitted

326.12 Uses Not Permitted

326.24 Bending Radius

326.26 Bends

326.40 Fittings

326.80 Ampacity

Part III. Construction Specifications

326.104 Conductors

326.112 Insulation

326.116 Conduit

326.120 Marking

Article 328 Medium Voltage Cable: Type MVPart I. General

328.1 Scope

328.2 Definition

328.6 Listing Requirements

Part II. Installation

328.10 Uses Permitted

328.12 Uses Not Permitted

328.14 Installation

328.30 Support

328.80 Ampacity

Part III. Construction Specifications

328.100 Construction

328.120 Marking

Article 330 Metal-Clad Cable: Type MC

Part I. General

330.1 Scope

330.2 Definition

330.6 Listing Requirements

Part II. Installation

330.10 Uses Permitted

(A) General Uses

(B) Specific Uses

330.12 Uses Not Permitted

330.15 Exposed Work

330.17 Through or Parallel to Framing Members

330.23 In Accessible Attics

330.24 Bending Radius

(A) Smooth Sheath

(B) Interlocked-Type Armor or Corrugated Sheath

(C) Shielded Conductors

330.30 Securing and Supporting

(A) General

(B) Securing

(C) Supporting

(D) Unsupported Cables

330.31 Single Conductors

330.80 Ampacity

(A) Type MC Cable Installed in Cable Tray

(B) Single Type MC Conductors Grouped Together

Part III. Construction Specifications

330.104 Conductors

330.108 Equipment Grounding Conductor

330.112 Insulation

(A) 1000 Volts or Less

(B) Over 1000 Volts

330.116 Sheath

Article 332 Mineral-Insulated, Metal-Sheathed

Cable: Type MI

Part I. General

332.1 Scope

332.2 Definition

332.6 Listing Requirements

Part II. Installation

332.10 Uses Permitted

332.12 Uses Not Permitted

332.17 Through or Parallel to Framing Members

332.24 Bending Radius

332.30 Securing and Supporting

(A) Horizontal Runs Through Holes and Notches

(B) Unsupported Cable

(C) Cable Trays

332.31 Single Conductors

332.40 Boxes and Fittings

(A) Fittings

(B) Terminal Seals

332.80 Ampacity

(A) Type MI Cable Installed in Cable Tray

(B) Single Type MI Conductors Grouped Together

Part III. Construction Specifications

332.104 Conductors

332.108 Equipment Grounding Conductor

332.112 Insulation

332.116 Sheath

Article 334 Nonmetallic-Sheathed Cable:

Types NM, NMC, and NMS

Part I. General

334.1 Scope

334.2 Definitions

334.6 Listing Requirements

Part II. Installation

2017 NEC TABLE OF CONTENTS

334.10 Uses Permitted	<u>Part I. General</u>
(A) Type NM	336.1 Scope
(B) Type NMC	336.2 Definition
(C) Type NMS	336.6 Listing Requirements
334.12 Uses Not Permitted	<u>Part II. Installation</u>
(A) Types NM, NMC, and NMS	336.10 Uses Permitted
(B) Types NM and NMS	336.12 Uses Not Permitted
334.15 Exposed Work	336.24 Bending Radius
(A) To Follow Surface	336.80 Ampacity
(B) Protection from Physical Damage	<u>Part III. Construction Specifications</u>
(C) In Unfinished Basements and Crawl Spaces	336.100 Construction
334.17 Through or Parallel to Framing Members	336.104 Conductors
334.23 In Accessible Attics	(A) Fire Alarm Systems
334.24 Bending Radius	(B) Thermocouple Circuits
334.30 Securing and Supporting	(C) Class 1 Circuit Conductors
(A) Horizontal Runs Through Holes and Notches	336.116 Jacket
(B) Unsupported Cables	336.120 Marking
(C) Wiring Device Without a Separate Outlet Box	Article 338 Service-Entrance Cable: Types SE
334.40 Boxes and Fittings	and USE
(A) Boxes of Insulating Material	<u>Part I. General</u>
(B) Devices of Insulating Material	338.1 Scope
(C) Devices with Integral Enclosures	338.2 Definitions
334.80 Ampacity	338.6 Listing Requirements
<u>Part III. Construction Specifications</u>	<u>Part II. Installation</u>
334.100 Construction	338.10 Uses Permitted
334.104 Conductors	(A) Service-Entrance Conductors
334.108 Equipment Grounding Conductor	(B) Branch Circuits or Feeders
334.112 Insulation	338.12 Uses Not Permitted
334.116 Sheath	(A) Service-Entrance Cable
(A) Type NM	(B) Underground Service-Entrance Cable
(B) Type NMC	338.24 Bending Radius
(C) Type NMS	<u>Part III. Construction Specifications</u>
Article 336 Power and Control Tray Cable: Type TC	338.100 Construction

338.120 Marking

Article 340 Underground Feeder and

Branch-Circuit Cable: Type UF

Part I. General

340.1 Scope

340.2 Definition

340.6 Listing Requirements

Part II. Installation

340.10 Uses Permitted

340.12 Uses Not Permitted

340.24 Bending Radius

340.80 Ampacity

Part III. Construction Specifications

340.104 Conductors

340.108 Equipment Grounding Conductor

340.112 Insulation

340.116 Sheath

Article 342 Intermediate Metal Conduit: Type IMC

Part I. General

342.1 Scope

342.2 Definition

342.6 Listing Requirements

Part II. Installation

342.10 Uses Permitted

(A) All Atmospheric Conditions and Occupancies

(B) Corrosion Environments

(C) Cinder Fill

(D) Wet Locations

342.14 Dissimilar Metals

342.20 Size

(A) Minimum

(B) Maximum

342.22 Number of Conductors

342.24 Bends — How Made

342.26 Bends — Number in One Run

342.28 Reaming and Threading

342.30 Securing and Supporting

(A) Securely Fastened

(B) Supports

342.42 Couplings and Connectors

(A) Threadless

(B) Running Threads

342.46 Bushings

342.56 Splices and Taps

342.60 Grounding

342.100 Construction

Part III. Construction Specifications

342.120 Marking

342.130 Standard Lengths

Article 344 Rigid Metal Conduit: Type RMC

Part I. General

344.1 Scope

344.2 Definition

344.6 Listing Requirements

Part II. Installation

344.10 Uses Permitted

(A) Atmospheric Conditions and Occupancies

(B) Corrosive Environments

(C) Cinder Fill

(D) Wet Locations

344.14 Dissimilar Metals

344.20 Size

(A) Minimum

(B) Maximum

344.22 Number of Conductors

344.24 Bends — How Made

344.26 Bends — Number in One Run

344.28 Reaming and Threading

344.30 Securing and Supporting

(A) Securely Fastened

(B) Supports

344.42 Couplings and Connectors

(A) Threadless

(B) Running Threads

344.46 Bushings

344.56 Splices and Taps

344.60 Grounding

Part III. Construction Specifications

344.100 Construction

344.120 Marking

344.130 Standard Lengths

Article 348 Flexible Metal Conduit: Type FMC

Part I. General

348.1 Scope

348.2 Definition

348.6 Listing Requirements

Part II. Installation

348.10 Uses Permitted

348.12 Uses Not Permitted

348.20 Size

(A) Minimum

(B) Maximum

348.22 Number of Conductors

348.24 Bends — How Made

348.26 Bends — Number in One Run

348.28 Trimming

348.30 Securing and Supporting

(A) Securely Fastened

(B) Supports

348.42 Couplings and Connectors

348.56 Splices and Taps

348.60 Grounding and Bonding

**Article 350 Liquidtight Flexible Metal Conduit:
Type LFMC**

Part I. General

350.1 Scope

350.2 Definition

350.6 Listing Requirements

Part II. Installation

350.10 Uses Permitted

350.12 Uses Not Permitted

350.20 Size

(A) Minimum

(B) Maximum

350.22 Number of Conductors or Cables

(A) Metric Designators 16 through 103
(Trade Sizes 1/2 through 4)

(B) Metric Designator 12 (Trade Size 3/8)

350.24 Bends — How Made

350.26 Bends — Number in One Run

350.28 Trimming

350.30 Securing and Supporting

(A) Securely Fastened

(B) Supports

350.42 Couplings and Connectors

350.56 Splices and Taps

350.60 Grounding and Bonding

Part III. Construction Specifications

350.120 Marking

Article 352 Rigid Polyvinyl Chloride Conduit: Type PVC

Part I. General

352.1 Scope

352.2 Definition	352.60 Grounding
352.6 Listing Requirements	<u>Part III. Construction Specifications</u>
<u>Part II. Installation</u>	352.100 Construction
352.10 Uses Permitted	352.120 Marking
(A) Concealed	Article 353 High Density Polyethylene Conduit:
(B) Corrosive Influences	Type HDPE Conduit
(C) Cinders	<u>Part I. General</u>
(D) Wet Locations	353.1 Scope
(E) Dry and Damp Locations	353.2 Definition
(F) Exposed	353.6 Listing Requirements
(G) Underground Installations	<u>Part II. Installation</u>
(H) Support of Conduit Bodies	353.10 Uses Permitted
(I) Insulation Temperature Limitations	353.12 Uses Not Permitted
352.12 Uses Not Permitted	353.20 Size
(A) Hazardous (Classified) Locations	(A) Minimum
(B) Support of Luminaires	(B) Maximum
(C) Physical Damage	353.22 Number of Conductors
(D) Ambient Temperatures	353.24 Bends — How Made
(E) Theaters and Similar Locations	353.26 Bends — Number in One Run
352.20 Size	353.28 Trimming
(A) Minimum	353.46 Bushings
(B) Maximum	353.48 Joints
352.22 Number of Conductors	353.56 Splices and Taps
352.24 Bends — How Made	353.60 Grounding
352.26 Bends — Number in One Run	<u>Part III. Construction Specifications</u>
352.28 Trimming	353.100 Construction
352.30 Securing and Supporting	353.120 Marking
(A) Securely Fastened	Article 354 Nonmetallic Underground Conduit
(B) Supports	with Conductors: Type NUCC
352.44 Expansion Fittings	<u>Part I. General</u>
352.46 Bushings	354.1 Scope
352.48 Joints	354.2 Definition
352.56 Splices and Tap	354.6 Listing Requirements

Part II. Installation

354.10 Uses Permitted

354.12 Uses Not Permitted

354.20 Size

(A) Minimum

(B) Maximum

354.22 Number of Conductors

354.24 Bends — How Made

354.26 Bends — Number in One Run

354.28 Trimming

354.46 Bushings

354.48 Joints

354.50 Conductor Terminations

354.56 Splices and Taps

354.60 Grounding

Part III. Construction Specifications

354.100 Construction

(A) General

(B) Nonmetallic Underground Conduit

(C) Conductors and Cables

(D) Conductor Fill

354.120 Marking

Article 355 Reinforced Thermosetting Resin

Conduit: Type RTRC

Part I. General

355.1 Scope

355.2 Definition

355.6 Listing Requirements

Part II. Installation

355.10 Uses Permitted

(A) Concealed

(B) Corrosive Influences

(C) Cinders

(D) Wet Locations

(E) Dry and Damp Locations

(F) Exposed

(G) Underground Installations

(H) Support of Conduit Bodies

(I) Insulation Temperature Limitations

355.12 Uses Not Permitted

(A) Hazardous (Classified) Locations

(B) Support of Luminaires

(C) Physical Damage

(D) Ambient Temperatures

(E) Theaters and Similar Locations

355.20 Size

(A) Minimum

(B) Maximum

355.22 Number of Conductors

355.24 Bends — How Made

355.26 Bends — Number in One Run

355.28 Trimming

355.30 Securing and Supporting

(A) Securely Fastened

(B) Supports

355.44 Expansion Fittings

355.46 Bushings

355.48 Joints

355.56 Splices and Taps

355.60 Grounding

Part III. Construction Specifications

355.100 Construction

355.120 Marking

Article 356 Liquidtight Flexible Nonmetallic

Conduit: Type LFNC

Part I. General

356.1 Scope	358.20 Size
356.2 Definition	(A) Minimum
356.6 Listing Requirements	(B) Maximum
<u>Part II. Installation</u>	358.22 Number of Conductors
356.10 Uses Permitted	358.24 Bends — How Made
356.12 Uses Not Permitted	358.26 Bends — Number in One Run
356.20 Size	358.28 Reaming and Threading
(A) Minimum	(A) Reaming
(B) Maximum	(B) Threading
356.22 Number of Conductors	358.30 Securing and Supporting
356.24 Bends — How Made	(A) Securely Fastened
356.26 Bends — Number in One Run	(B) Supports
356.28 Trimming	358.42 Couplings and Connectors
356.30 Securing and Supporting	358.56 Splices and Taps
356.42 Couplings and Connectors	358.60 Grounding
356.56 Splices and Taps	<u>Part III. Construction Specifications</u>
356.60 Grounding	358.100 Construction
<u>Part III. Construction Specifications</u>	358.120 Marking
356.100 Construction	Article 360 Flexible Metallic Tubing: Type FMT
356.120 Marking	<u>Part I. General</u>
Article 358 Electrical Metallic Tubing: Type EMT	360.1 Scope.
<u>Part I. General</u>	360.2 Definition.
358.1 Scope	360.6 Listing Requirements.
358.2 Definition	<u>Part II. Installation</u>
358.6 Listing Requirements	360.10 Uses Permitted.
<u>Part II. Installation</u>	360.12 Uses Not Permitted.
358.10 Uses Permitted	360.20 Size.
(A) Exposed and Concealed	(A) Minimum.
(B) Corrosive Environments	(B) Maximum.
(C) Cinder Fill	360.22 Number of Conductors.
(D) Wet Locations	(A) FMT — Metric Designators 16 and 21 (Trade
358.12 Uses Not Permitted	Sizes 1/2 and 3/4).
358.14 Dissimilar Metals	(B) FMT — Metric Designator 12 (Trade Size 3/8).

2017 NEC TABLE OF CONTENTS

360.24 Bends.	<u>Part I. General</u>
(A) Infrequent Flexing Use.	366.1 Scope
(B) Fixed Bends.	366.2 Definitions
360.56 Splices and Taps.	366.6 Listing Requirements
360.60 Grounding.	(A) Outdoors
<u>Part III. Construction Specifications</u>	(B) Indoors
360.120 Marking.	<u>Part II. Installation</u>
Article 362 Electrical Nonmetallic Tubing: Type ENT	366.10 Uses Permitted
<u>Part I. General</u>	(A) Sheet Metal Auxiliary Gutters
362.1 Scope	(B) Nonmetallic Auxiliary Gutters
362.2 Definition	366.12 Uses Not Permitted
362.6 Listing Requirements	366.20 Conductors Connected in Parallel
<u>Part II. Installation</u>	366.22 Number of Conductors
362.10 Uses Permitted	(A) Sheet Metal Auxiliary Gutters
362.12 Uses Not Permitted	(B) Nonmetallic Auxiliary Gutters
362.20 Size	366.23 Ampacity of Conductors
(A) Minimum	(A) Sheet Metal Auxiliary Gutters
(B) Maximum	(B) Nonmetallic Auxiliary Gutters
362.22 Number of Conductors	366.30 Securing and Supporting
362.24 Bends — How Made	(A) Sheet Metal Auxiliary Gutters
362.26 Bends — Number in One Run	(B) Nonmetallic Auxiliary Gutters
362.28 Trimming	366.44 Expansion Fittings
362.30 Securing and Supporting	366.56 Splices and Taps
(A) Securely Fastened	(A) Within Gutters
(B) Supports	(B) Bare Conductors
362.46 Bushings	(C) Suitably Identified
362.48 Joints	(D) Overcurrent Protection
362.56 Splices and Taps	366.58 Insulated Conductors
362.60 Grounding	(A) Deflected Insulated Conductors
<u>Part III. Construction Specifications</u>	(B) Auxiliary Gutters Used as Pull Boxes
362.100 Construction	366.60 Grounding
362.120 Marking	<u>Part III. Construction Specifications</u>
Article 366 Auxiliary Gutters	366.100 Construction

(A) Electrical and Mechanical Continuity	(C) Branches from Trolley-Type Busways
(B) Substantial Construction	368.58 Dead Ends
(C) Smooth Rounded Edges	368.60 Grounding
(D) Covers	<u>Part III. Construction</u>
(E) Clearance of Bare Live Parts	368.120 Marking
366.120 Marking	Part IV. Requirements for Over 1000 Volts, Nominal
(A) Outdoors	368.214 Adjacent and Supporting Structures
(B) Indoors	368.234 Barriers and Seals
Article 368 Busways	(A) Vapor Seals
<u>Part I. General Requirements</u>	(B) Fire Barriers
368.1 Scope	368.236 Drain Facilities
368.2 Definition	368.237 Ventilated Bus Enclosures
<u>Part II. Installation</u>	368.238 Terminations and Connections
368.10 Uses Permitted	368.239 Switches
(A) Exposed	368.240 Wiring 1000 Volts or Less, Nominal
(B) Behind Access Panels	368.244 Expansion Fittings
(C) Through Walls and Floors	368.258 Neutral Conductor
368.12 Uses Not Permitted	368.260 Grounding
(A) Physical Damage	368.320 Marking
(B) Hoistways	Article 370 Cablebus
(C) Hazardous Locations	<u>Part I. General</u>
(D) Wet Locations	370.1 Scope
(E) Working Platform	370.2 Definition
368.17 Overcurrent Protection	<u>Part II. Installation</u>
(A) Rating of Overcurrent Protection — Feeders	370.10 Uses Permitted
(B) Reduction in Ampacity Size of Busway	370.12 Uses Not Permitted
(C) Feeder or Branch Circuits	370.18 Cablebus Installation
(D) Rating of Overcurrent Protection — Branch Circuits	(A) Transversely Routed
368.30 Support	(B) Through Dry Floors and Platforms
368.56 Branches from Busways	(C) Through Floors and Platforms in Wet Locations
(A) General	370.20 Conductor Size and Termination
(B) Cord and Cable Assemblies	(A) Conductors
	(B) Termination

370.22 Number of Conductors	374.1 Scope
370.23 Overcurrent Protection	374.2 Definitions
370.30 Securing and Supporting	<u>Part II. Installation</u>
(A) Cablebus Supports	374.12 Uses Not Permitted
(B) Conductor Supports	374.18 Cellular Metal Floor Raceways Installations
370.42 Fittings	(A) Connection to Cabinets and Extensions from Cells
370.60 Grounding	(B) Junction Boxes
370.80 Ampacity of Conductors	(C) Inserts
(A) Ampacity of Single Insulated Conductors	(D) Markers
(B) Ampacity of Cables Rated 2000 Volts or Less	374.20 Size of Conductors
(C) Ampacity of Type MV and Type MC Cables Rated 2001 Volts or Over	374.22 Maximum Number of Conductors in Raceway
<u>Part III. Construction Specifications</u>	374.23 Ampacity of Conductors
370.120 Marking	374.56 Splices and Taps
Article 372 Cellular Concrete Floor Raceways	374.58 Discontinued Outlets
<u>Part I. General</u>	<u>Part III. Construction Specifications</u>
372.1 Scope	374.100 General
372.2 Definitions	Article 376 Metal Wireways
<u>Part II. Installations</u>	<u>Part I. General</u>
372.12 Uses Not Permitted	376.1 Scope
372.18 Cellular Concrete Floor Raceways Installation	376.2 Definition
(A) Header	<u>Part II. Installation</u>
(B) Connection to Cabinets and Other Enclosures	376.10 Uses Permitted
(C) Junction Boxes	376.12 Uses Not Permitted
(D) Inserts	376.20 Conductors Connected in Parallel
(E) Markers	376.21 Size of Conductors
372.20 Size of Conductors	376.22 Number of Conductors and Ampacity
372.22 Maximum Number of Conductors	(A) Cross-Sectional Areas of Wireway
372.23 Ampacity of Conductors	(B) Adjustment Factors
372.56 Splices and Taps	376.23 Insulated Conductors
372.58 Discontinued Outlets	(A) Deflected Insulated Conductors
Article 374 Cellular Metal Floor Raceways	(B) Metal Wireways Used as Pull Boxes
<u>Part I. General</u>	376.30 Securing and Supporting

2017 NEC TABLE OF CONTENTS

(A) Horizontal Support	378.58 Dead Ends
(B) Vertical Support	378.60 Grounding
376.56 Splices, Taps, and Power Distribution Blocks	378.70 Extensions from Nonmetallic Wireways
(A) Splices and Taps	<u>Part III. Construction Specifications</u>
(B) Power Distribution Blocks	378.120 Marking
376.58 Dead Ends	Article 380 Multioutlet Assembly
376.70 Extensions from Metal Wireways	<u>Part I. General</u>
<u>Part III. Construction Specifications</u>	380.1 Scope
376.100 Construction	<u>Part II. Installation</u>
(A) Electrical and Mechanical Continuity	380.10 Uses Permitted
(B) Substantial Construction	380.12 Uses Not Permitted
(C) Smooth Rounded Edges	380.23 Insulated Conductors
(D) Covers	(A) Deflected Insulated Conductors
376.120 Marking	(B) Multioutlet Assemblies Used as Pull Boxes
Article 378 Nonmetallic Wireways	380.76 Metal Multioutlet Assembly Through Dry Partitions
<u>Part I. General</u>	Article 382 Nonmetallic Extensions
378.1 Scope	<u>Part I. General</u>
378.2 Definition	382.1 Scope
378.6 Listing Requirements	382.2 Definitions
<u>Part II. Installation</u>	382.6 Listing Requirements
378.10 Uses Permitted	<u>Part II. Installation</u>
378.12 Uses Not Permitted	382.10 Uses Permitted
378.20 Conductors Connected in Parallel	(A) From an Existing Outlet
378.21 Size of Conductors	(B) Exposed and in a Dry Location
378.22 Number of Conductors	(C) Residential or Offices
378.23 Insulated Conductors	382.12 Uses Not Permitted
(A) Deflected Insulated Conductors	382.15 Exposed
(B) Nonmetallic Wireways Used as Pull Boxes	(A) Nonmetallic Extensions
378.30 Securing and Supporting	(B) Concealable Nonmetallic Extensions
(A) Horizontal Support	382.26 Bends
(B) Vertical Support	(A) Nonmetallic Extensions
378.44 Expansion Fittings	(B) Concealable Nonmetallic Extensions
378.56 Splices and Taps	

382.30 Securing and Supporting

(A) Nonmetallic Extensions

(B) Concealable Nonmetallic Extensions

382.40 Boxes and Fittings

382.42 Devices

(A) Receptacles

(B) Receptacles and Housings

382.56 Splices and Taps

Part III. Construction Specifications (Concealable

Nonmetallic Extensions Only)

382.100 Construction

382.104 Flat Conductors

(A) Ungrounded Conductor (Center Layer)

(B) Grounded Conductor (Inner Sectioned Layers)

(C) Grounding Conductor (Outer Sectioned Layers)

382.112 Insulation

382.120 Marking

(A) Cable

(B) Conductor Identification

Article 384 Strut-Type Channel Raceway

Part I. General

384.1 Scope

384.2 Definition

384.6 Listing Requirements

Part II. Installation

384.10 Uses Permitted

384.12 Uses Not Permitted

384.21 Size of Conductors

384.22 Number of Conductors

384.30 Securing and Supporting

(A) Surface Mount

(B) Suspension Mount

384.56 Splices and Taps

384.60 Grounding

Part III. Construction Specifications

384.100 Construction

(A) Material

(B) Corrosion Protection

(C) Cover

384.120 Marking

Article 386 Surface Metal Raceways

Part I. General

386.1 Scope

386.2 Definition

386.6 Listing Requirements

Part II. Installation

386.10 Uses Permitted

386.12 Uses Not Permitted

386.21 Size of Conductors

386.22 Number of Conductors or Cables

386.30 Securing and Supporting

386.56 Splices and Taps

386.60 Grounding

386.70 Combination Raceways

Part III. Construction Specifications

386.100 Construction

386.120 Marking

Article 388 Surface Nonmetallic Raceways

Part I. General

388.1 Scope

388.2 Definition

388.6 Listing Requirements

Part II. Installation

388.10 Uses Permitted

388.12 Uses Not Permitted

2017 NEC TABLE OF CONTENTS

388.21 Size of Conductors	<u>Part I. General</u>
388.22 Number of Conductors or Cables	392.1 Scope
388.30 Securing and Supporting	392.2 Definition
388.56 Splices and Taps	<u>Part II. Installation</u>
388.60 Grounding	392.10 Uses Permitted
388.70 Combination Raceways	(A) Wiring Methods
<u>Part III. Construction Specifications</u>	(B) In Industrial Establishments
388.100 Construction	(C) Hazardous (Classified) Locations
388.120 Marking	(D) Nonmetallic Cable Tray
Article 390 Underfloor Raceways	(E) Airfield Lighting Cable Tray
390.1 Scope	392.12 Uses Not Permitted
390.2 Definition	392.18 Cable Tray Installation
390.3 Use	(A) Complete System
(A) Permitted	(B) Completed Before Installation
(B) Not Permitted	(C) Covers
390.4 Covering	(D) Through Partitions and Walls
(A) Raceways Not over 100 mm (4 in.) Wide	(E) Exposed and Accessible
(B) Raceways over 100 mm (4 in.) Wide But Not over 200 mm (8 in.) Wide	(F) Adequate Access
(C) Trench-Type Raceways Flush with Concrete	(G) Raceways, Cables, Boxes, and Conduit Bodies Supported from Cable Tray Systems
(D) Other Raceways Flush with Concrete	(H) Marking
390.5 Size of Conductors	392.20 Cable and Conductor Installation
390.6 Maximum Number of Conductors in Raceway	(A) Multiconductor Cables Operating at 1000 Volts or Less
390.7 Splices and Taps	(B) Cables Operating at Over 1000 Volts
390.8 Discontinued Outlets	(C) Connected in Parallel
390.9 Laid in Straight Lines	(D) Single Conductors
390.10 Markers at Ends	392.22 Number of Conductors or Cables
390.11 Dead Ends	(A) Number of Multiconductor Cables, Rated 2000 Volts or Less, in Cable Trays
390.13 Junction Boxes	(B) Number of Single-Conductor Cables, Rated 2000 Volts or Less, in Cable Trays
390.14 Inserts	(C) Number of Type MV and Type MC Cables
390.15 Connections to Cabinets and Wall Outlets	
390.17 Ampacity of Conductors	
Article 392 Cable Trays	

(2001 Volts or Over) in Cable Trays	393.12 Uses Not Permitted
392.30 Securing and Supporting	393.14 Installation
(A) Cable Trays	(A) General Requirements
(B) Cables and Conductors	(B) Insulated Conductors
392.46 Bushed Conduit and Tubing	393.21 Disconnecting Means
392.56 Cable Splices	(A) Location
392.60 Grounding and Bonding	(B) Multiwire Branch Circuits
(A) Metal Cable Trays	393.30 Securing and Supporting
(B) Steel or Aluminum Cable Tray Systems	(A) Attached to Building Structure
(C) Transitions	(B) Attachment of Power Grid Rails
392.80 Ampacity of Conductors	393.40 Connectors and Enclosures
(A) Ampacity of Cables, Rated 2000 Volts or Less, in Cable Trays	(A) Connectors
(B) Ampacity of Type MV and Type MC Cables	(B) Enclosures
(2001 Volts or Over) in Cable Trays	393.45 Overcurrent and Reverse Polarity (Backfeed) Protection
<u>Part III. Construction Specifications</u>	(A) Overcurrent Protection
392.100 Construction	(B) Interconnection of Power Sources
(A) Strength and Rigidity	(C) Reverse Polarity (Backfeed) Protection of Direct-Current Systems
(B) Smooth Edges	393.56 Splices
(C) Corrosion Protection	393.57 Connections
(D) Side Rails	393.60 Grounding
(E) Fittings	(A) Grounding of Supply Side of Class 2 Power Source
(F) Nonmetallic Cable Tray	(B) Grounding of Load Side of Class 2 Power Source
Article 393 Low-Voltage Suspended Ceiling	<u>Part III. Construction Specifications</u>
Power Distribution Systems	393.104 Sizes and Types of Conductors
<u>Part I. General</u>	(A) Load Side Utilization Conductor Size
393.1 Scope	(B) Power Feed Bus Rail Conductor Size
393.2 Definitions	Article 394 Concealed Knob-and-Tube Wiring
393.6 Listing Requirements	<u>Part I. General</u>
(A) Listed System	394.1 Scope
(B) Assembly of Listed Parts	394.2 Definition
<u>Part II. Installation</u>	<u>Part II. Installation</u>
393.10 Uses Permitted	

394.10 Uses Permitted

394.12 Uses Not Permitted

394.17 Through or Parallel to Framing Members

394.19 Clearances

(A) General

(B) Limited Conductor Space

(C) Clearance from Piping, Exposed Conductors,
and So Forth

394.23 In Accessible Attics

(A) Accessible by Stairway or Permanent Ladder

(B) Not Accessible by Stairway or Permanent Ladder

394.30 Securing and Supporting

(A) Supporting

(B) Securing

394.42 Devices

394.56 Splices and Taps

Part III. Construction Specifications

394.104 Conductors

Article 396 Messenger-Supported Wiring

Part I. General

396.1 Scope

396.2 Definitions

Part II. Installation

396.10 Uses Permitted

(A) Cable Types

(B) In Industrial Establishments

(C) Hazardous (Classified) Locations

396.12 Uses Not Permitted

396.30 Messenger

(A) Support

(B) Neutral Conductor

(C) Equipment Grounding Conductor

396.56 Conductor Splices and Taps

396.60 Grounding

Article 398 Open Wiring on Insulators

Part I. General

398.1 Scope

398.2 Definition

Part II. Installation

398.10 Uses Permitted

398.12 Uses Not Permitted

398.15 Exposed Work

(A) Dry Locations

(B) Entering Spaces Subject to Dampness,
Wetness, or Corrosive Vapors

(C) Exposed to Physical Damage

398.17 Through or Parallel to Framing Members

398.19 Clearances

398.23 In Accessible Attics

(A) Accessible by Stairway or Permanent Ladder

(B) Not Accessible by Stairway or Permanent Ladder

398.30 Securing and Supporting

(A) Conductor Sizes Smaller Than 8 AWG

(B) Conductor Sizes 8 AWG and Larger

(C) Industrial Establishments

(D) Mounting of Conductor Supports

(E) Tie Wires

398.42 Devices

Part III. Construction Specifications

398.104 Conductors

**Article 399 Outdoor Overhead Conductors
over 1000 Volts**

399.1 Scope

399.2 Definition

399.10 Uses Permitted

399.30 Support

(A) Conductors	(C) Colored Insulation
(B) Structures	(D) Colored Separator
(C) Insulators	(E) Tinned Conductors
Article 400 Flexible Cords and Flexible Cables	(F) Surface Marking
<u>Part I. General</u>	400.23 Equipment Grounding Conductor Identification
400.1 Scope	(A) Colored Braid
400.2 Other Articles	(B) Colored Insulation or Covering
400.3 Suitability	400.24 Attachment Plugs
400.4 Types	<u>Part III. Portable Cables Over 600 Volts, Nominal</u>
400.5 Ampacities for Flexible Cords and Flexible Cables	400.30 Scope
(A) Ampacity Tables	400.31 Construction
(B) Ultimate Insulation Temperature	(A) Conductors
(C) Engineering Supervision	(B) Equipment Grounding Conductor(s)
400.6 Markings	400.32 Shielding
(A) Standard Markings	400.33 Equipment Grounding Conductors
(B) Optional Markings	400.34 Minimum Bending Radii
400.10 Uses Permitted	400.35 Fittings
(A) Uses	400.36 Splices and Terminations
(B) Attachment Plugs	Article 402 Fixture Wires
400.12 Uses Not Permitted	402.1 Scope
400.13 Splices	402.2 Other Articles
400.14 Pull at Joints and Terminals	402.3 Types
400.15 In Show Windows and Showcases	402.5 Allowable Ampacities for Fixture Wires
400.16 Overcurrent Protection	402.6 Minimum Size
400.17 Protection from Damage	402.7 Number of Conductors in Conduit or Tubing
<u>Part II. Construction Specifications</u>	402.8 Grounded Conductor Identification
400.20 Labels	402.9 Marking
400.21 Construction	(A) Method of Marking
(A) Conductors	(B) Optional Marking
(B) Nominal Insulation Thickness	402.10 Uses Permitted
400.22 Grounded-Conductor Identification	402.12 Uses Not Permitted
(A) Colored Braid	402.14 Overcurrent Protection
(B) Tracer in Braid	Article 404 Switches

Part I. Installation

- 404.1 Scope
- 404.2 Switch Connections
 - (A) Three-Way and Four-Way Switches
 - (B) Grounded Conductors
 - (C) Switches Controlling Lighting Loads
- 404.3 Enclosure
 - (A) General
 - (B) Used as a Raceway
- 404.4 Damp or Wet Locations
 - (A) Surface-Mounted Switch or Circuit Breaker
 - (B) Flush-Mounted Switch or Circuit Breaker
 - (C) Switches in Tub or Shower Spaces
- 404.5 Time Switches, Flashers, and Similar Devices
- 404.6 Position and Connection of Switches
 - (A) Single-Throw Knife Switches
 - (B) Double-Throw Knife Switches
 - (C) Connection of Switches
- 404.7 Indicating
- 404.8 Accessibility and Grouping
 - (A) Location
 - (B) Voltage Between Adjacent Devices
 - (C) Multipole Snap Switches
- 404.9 Provisions for General-Use Snap Switches
 - (A) Faceplates
 - (B) Grounding
 - (C) Construction
- 404.10 Mounting of Snap Switches
 - (A) Surface Type
 - (B) Box Mounted
- 404.11 Circuit Breakers as Switches
- 404.12 Grounding of Enclosures
- 404.13 Knife Switches

- (A) Isolating Switches
- (B) To Interrupt Currents
- (C) General-Use Switches
- (D) Motor-Circuit Switches
- 404.14 Rating and Use of Switches
 - (A) Alternating-Current General-Use Snap Switch
 - (B) Alternating-Current or Direct-Current General-Use Snap Switch
 - (C) CO/ALR Snap Switches
 - (D) Alternating-Current Specific-Use Snap Switches Rated for 347 Volts
 - (E) Dimmer Switches
 - (F) Cord- and Plug-Connected Loads

Part II. Construction Specifications

- 404.20 Marking
 - (A) Ratings
 - (B) Off Indication
- 404.22 Electronic Lighting Control Switches
- 404.26 Knife Switches Rated 600 to 1000 Volts
- 404.27 Fused Switches
- 404.28 Wire-Bending Space
- Article 406 Receptacles, Cord Connectors, and Attachment Plugs (Caps)**
- 406.1 Scope
- 406.2 Definitions
- 406.3 Receptacle Rating and Type
 - (A) Receptacles
 - (B) Rating
 - (C) Receptacles for Aluminum Conductors
 - (D) Isolated Ground Receptacles
 - (E) Controlled Receptacle Marking
 - (F) Receptacle with USB Charger
- 406.4 General Installation Requirements

(A) Grounding Type	(C) Bathtub and Shower Space
(B) To Be Grounded	(D) Protection for Floor Receptacles
(C) Methods of Grounding	(E) Flush Mounting with Faceplate
(D) Replacements	406.10 Grounding-Type Receptacles, Adapters, Cord Connectors, and Attachment Plugs
(E) Cord- and Plug-Connected Equipment	(A) Grounding Poles
(F) Noninterchangeable Types	(B) Grounding-Pole Identification
406.5 Receptacle Mounting	(C) Grounding Terminal Use
(A) Boxes That Are Set Back	(D) Grounding-Pole Requirements
(B) Boxes That Are Flush	(E) Use
(C) Receptacles Mounted on Covers	406.11 Connecting Receptacle Grounding Terminal to Box
(D) Position of Receptacle Faces	406.12 Tamper-Resistant Receptacles
(E) Receptacles in Countertops	Article 408 Switchboards, Switchgear, and Panelboards
(F) Receptacles in Work Surfaces	<u>Part I. General</u>
(G) Receptacle Orientation	408.1 Scope
(H) Receptacles in Seating Areas and Other Similar Surfaces	408.2 Other Articles
(I) Exposed Terminals	408.3 Support and Arrangement of Busbars and Conductors
(J) Voltage Between Adjacent Devices	(A) Conductors and Busbars on a Switchboard, Switchgear, or Panelboard
406.6 Receptacle Faceplates (Cover Plates)	(B) Overheating and Inductive Effects
(A) Thickness of Metal Faceplates	(C) Used as Service Equipment
(B) Grounding	(D) Terminals
(C) Faceplates of Insulating Material	(E) Bus Arrangement
(D) Receptacle Faceplate (Cover Plates) with Integral Night Light and/or USB Charger	(F) Switchboard, Switchgear, or Panelboard Identification
406.7 Attachment Plugs, Cord Connectors, and Flanged Surface Devices	(G) Minimum Wire-Bending Space
(A) Construction of Attachment Plugs and Cord Connectors	408.4 Field Identification Required
(B) Connection of Attachment Plugs	(A) Circuit Directory or Circuit Identification
(C) Attachment Plug Ejector Mechanisms	(B) Source of Supply
(D) Flanged Surface Inlet	408.5 Clearance for Conductor Entering Bus Enclosures
406.8 Noninterchangeability	408.7 Unused Openings
406.9 Receptacles in Damp or Wet Locations	<u>Part II. Switchboards and Switchgear</u>
(A) Damp Locations	
(B) Wet Locations	

408.16 Switchboards and Switchgear in Damp or Wet Locations

408.17 Location Relative to Easily Ignitable Material

408.18 Clearances

(A) From Ceiling

(B) Around Switchboards and Switchgear

408.19 Conductor Insulation

408.20 Location of Switchboards and Switchgear

408.22 Grounding of Instruments, Relays, Meters, and Instrument Transformers on Switchboards and Switchgear

Part III. Panelboards

408.30 General

408.36 Overcurrent Protection

(A) Snap Switches Rated at 30 Amperes or Less

(B) Supplied Through a Transformer

(C) Delta Breakers

(D) Back-Fed Devices

408.37 Panelboards in Damp or Wet Locations

408.38 Enclosure

408.39 Relative Arrangement of Switches and Fuses

408.40 Grounding of Panelboards

408.41 Grounded Conductor Terminations

Part IV. Construction Specifications

408.50 Panels

408.51 Busbars

408.52 Protection of Instrument Circuits

408.53 Component Parts

408.54 Maximum Number of Overcurrent Devices

408.55 Wire-Bending Space Within an Enclosure Containing a Panelboard

(A) Top and Bottom Wire-Bending Space

(B) Side Wire-Bending Space

(C) Back Wire-Bending Space

408.56 Minimum Spacings

408.58 Panelboard Marking

Article 409 Industrial Control Panels

Part I. General

409.1 Scope

409.3 Other Articles

Part II. Installation

409.20 Conductor — Minimum Size and Ampacity

409.21 Overcurrent Protection

(A) General

(B) Location

(C) Rating

409.22 Short-Circuit Current Rating

(A) Installation

(B) Documentation

409.30 Disconnecting Means

409.60 Grounding

Part III. Construction Specifications

409.100 Enclosures

409.102 Busbars and Conductors

(A) Support and Arrangement

(B) Phase Arrangement

409.104 Wiring Space

(A) General

(B) Wire Bending Space

409.106 Spacings

409.108 Service Equipment

409.110 Marking

Article 410 Luminaires, Lampholders, and Lamps

Part I. General

410.1 Scope

410.2 Definition

410.5 Live Parts	(B) Metal or Nonmetallic Poles Supporting
410.6 Listing Required	Luminaires
410.8 Inspection	410.36 Means of Support
<u>Part II. Luminaire Locations</u>	(A) Outlet Boxes
410.10 Luminaires in Specific Locations	(B) Suspended Ceilings
(A) Wet and Damp Locations	(C) Luminaire Studs
(B) Corrosive Locations	(D) Insulating Joints
(C) In Ducts or Hoods	(E) Raceway Fittings
(D) Bathtub and Shower Areas	(F) Busways
(E) Luminaires in Indoor Sports, Mixed-Use, and All-Purpose Facilities	(G) Trees
(F) Luminaires Installed in or Under Roof Decking	<u>Part V. Grounding</u>
410.11 Luminaires Near Combustible Material	410.40 General
410.12 Luminaires over Combustible Material	410.42 Luminaire(s) with Exposed Conductive Parts
410.14 Luminaires in Show Windows	410.44 Methods of Grounding
410.16 Luminaires in Clothes Closets	410.46 Equipment Grounding Conductor Attachment
(A) Luminaire Types Permitted	<u>Part VI. Wiring of Luminaires</u>
(B) Luminaire Types Not Permitted	410.48 Luminaire Wiring — General
(C) Location	410.50 Polarization of Luminaires
410.18 Space for Cove Lighting	410.52 Conductor Insulation
<u>Part III. Provisions at Luminaire Outlet Boxes, Canopies, and Pans</u>	410.54 Pendant Conductors for Incandescent Filament Lamps
410.20 Space for Conductors	(A) Support
410.21 Temperature Limit of Conductors in Outlet Boxes	(B) Size
410.22 Outlet Boxes to Be Covered	(C) Twisted or Cabled
410.23 Covering of Combustible Material at Outlet Boxes	410.56 Protection of Conductors and Insulation
410.24 Connection of Electric-Discharge and LED Luminaires	(A) Properly Secured
(A) Independent of the Outlet Box	(B) Protection Through Metal
(B) Access to Boxes	(C) Luminaire Stems
<u>Part IV. Luminaire Supports</u>	(D) Splices and Taps
410.30 Supports	(E) Stranding
(A) General	(F) Tension
	410.59 Cord-Connected Showcases
	(A) Cord Requirements

2017 NEC TABLE OF CONTENTS

(B) Receptacles, Connectors, and Attachment Plugs	<u>Part X. Special Provisions for Flush and Recessed</u>
(C) Support	<u>Luminaires</u>
(D) No Other Equipment	410.110 General
(E) Secondary Circuit(s)	410.115 Temperature
410.62 Cord-Connected Lampholders and Luminaires	(A) Combustible Material
(A) Lampholders	(B) Fire-Resistant Construction
(B) Adjustable Luminaires	(C) Recessed Incandescent Luminaires
(C) Electric-Discharge and LED Luminaires	410.116 Clearance and Installation
410.64 Luminaires as Raceways	(A) Clearance
(A) Listed	(B) Installation
(B) Through-Wiring	410.117 Wiring
(C) Luminaires Connected Together	(A) General
410.68 Feeder and Branch-Circuit Conductors	(B) Circuit Conductors
and Ballasts	(C) Tap Conductors
<u>Part VII. Construction of Luminaires</u>	<u>Part XI. Construction of Flush and Recessed Luminaires</u>
410.70 Combustible Shades and Enclosures	410.118 Temperature
410.74 Luminaire Rating	410.120 Lamp Wattage Marking
(A) Marking	410.121 Solder Prohibited
(B) Electrical Rating	410.122 Lampholders
410.82 Portable Luminaires	<u>Part XII. Special Provisions for Electric-Discharge</u>
(A) General	<u>Lighting Systems of 1000 Volts or Less</u>
(B) Portable Handlamps	410.130 General
410.84 Cord Bushings	(A) Open-Circuit Voltage of 1000 Volts or Less
<u>Part VIII. Installation of Lampholders</u>	(B) Considered as Energized
410.90 Screw Shell Type	(C) Transformers of the Oil-Filled Type
410.93 Double-Pole Switched Lampholders	(D) Additional Requirements
410.96 Lampholders in Wet or Damp Locations	(E) Thermal Protection — Fluorescent Luminaires
410.97 Lampholders Near Combustible Material	(F) High-Intensity Discharge Luminaires
<u>Part IX. Lamps and Auxiliary Equipment</u>	(G) Disconnecting Means
410.103 Bases, Incandescent Lamps	410.134 Direct-Current Equipment
410.104 Electric-Discharge Lamp Auxiliary Equipment	410.135 Open-Circuit Voltage Exceeding 300 Volts
(A) Enclosures	410.136 Luminaire Mounting
(B) Switching	(A) Exposed Components

(B) Combustible Low-Density Cellulose Fiberboard

410.137 Equipment Not Integral with Luminaire

(A) Metal Cabinets

(B) Separate Mounting

(C) Wired Luminaire Sections

410.138 Autotransformers

410.139 Switches

Part XIII. Special Provisions for Electric-Discharge

Lighting Systems of More than 1000 Volts

410.140 General

(A) Listing

(B) Dwelling Occupancies

(C) Live Parts

(D) Additional Requirements

410.141 Control

(A) Disconnection

(B) Within Sight or Locked Type

410.142 Lamp Terminals and Lampholders

410.143 Transformers

(A) Type

(B) Voltage

(C) Rating

(D) Secondary Connections

410.144 Transformer Locations

(A) Accessible

(B) Secondary Conductors

(C) Adjacent to Combustible Materials

410.145 Exposure to Damage

410.146 Marking

Part XIV. Lighting Track

410.151 Installation

(A) Lighting Track

(B) Connected Load

(C) Locations Not Permitted

(D) Support

410.153 Heavy-Duty Lighting Track

410.154 Fastening

410.155 Construction Requirements

(A) Construction

(B) Grounding

Part XV. Decorative Lighting and Similar Accessories

410.160 Listing of Decorative Lighting

Article 411 Low-Voltage Lighting

411.1 Scope

411.3 Low-Voltage Lighting Systems

411.4 Listing Required

(A) Listed System

(B) Assembly of Listed Parts

411.5 Specific Location Requirements

(A) Walls, Floors, and Ceilings

(B) Pools, Spas, Fountains, and Similar Locations

411.6 Secondary Circuits

(A) Grounding

(B) Isolation

(C) Bare Conductors

(D) Insulated Conductors

411.7 Branch Circuit

411.8 Hazardous (Classified) Locations

Article 422 Appliances

Part I. General

422.1 Scope

422.3 Other Articles

422.4 Live Parts

422.5 Ground-Fault Circuit-Interrupter (GFCI) Protection
for Personnel

(A) General

2017 NEC TABLE OF CONTENTS

(B) Type	422.30 General
422.6 Listing Required	422.31 Disconnection of Permanently Connected Appliances
<u>Part II. Installation</u>	
422.10 Branch-Circuit Rating	(A) Rated at Not over 300 Volt-Amperes or 1/8 Horsepower
(A) Individual Circuits	(B) Appliances Rated over 300 Volt-Amperes
(B) Circuits Supplying Two or More Loads	(C) Motor-Operated Appliances Rated over 1/8 Horsepower
422.11 Overcurrent Protection	422.33 Disconnection of Cord-and-Plug-Connected or Attachment Fitting-Connected Appliances
(A) Branch-Circuit Overcurrent Protection	(A) Separable Connector or an Attachment Plug (or Attachment Fitting) and Receptacle
(B) Household-Type Appliances with Surface Heating Elements	(B) Connection at the Rear Base of a Range
(C) Infrared Lamp Commercial and Industrial Heating Appliances	(C) Rating
(D) Open-Coil or Exposed Sheathed-Coil Types of Surface Heating Elements in Commercial-Type Heating Appliances	422.34 Unit Switch(es) as Disconnecting Means
(E) Single Non-Motor-Operated Appliance	(A) Multifamily Dwellings
(F) Electric Heating Appliances Employing Resistance-Type Heating Elements Rated More Than 48 Amperes	(B) Two-Family Dwellings
(G) Motor-Operated Appliances	(C) One-Family Dwellings
422.12 Central Heating Equipment	(D) Other Occupancies
422.13 Storage-Type Water Heaters	422.35 Switch and Circuit Breaker to Be Indicating
422.15 Central Vacuum Outlet Assemblies	<u>Part IV. Construction</u>
422.16 Flexible Cords	422.40 Polarity in Cord-and Plug-Connected Appliances
(A) General	422.41 Cord-and Plug-Connected Appliances Subject to Immersion
(B) Specific Appliances	422.42 Signals for Heated Appliances
422.17 Protection of Combustible Material	422.43 Flexible Cords
422.18 Support of Ceiling-Suspended (Paddle) Fans	(A) Heater Cords
422.19 Space for Conductors	(B) Other Heating Appliances
422.20 Outlet Boxes to Be Covered	422.44 Cord-and Plug-Connected Immersion Heaters
422.21 Covering of Combustible Material at Outlet Boxes	422.45 Stands for Cord-and Plug-Connected Appliances
422.22 Other Installation Methods	422.46 Flatirons
<u>Part III. Disconnecting Means</u>	422.47 Water Heater Controls
	422.48 Infrared Lamp Industrial Heating Appliances
	(A) 300 Watts or Less

(B) Over 300 Watts	(C) Unit Switch(es) as Disconnecting Means
422.50 Cord-and-Plug-Connected Pipe Heating Assemblies	424.20 Thermostatically Controlled Switching Devices
<u>Part V. Marking</u>	(A) Serving as Both Controllers and Disconnecting Means
422.60 Nameplate	(B) Thermostats That Do Not Directly Interrupt
(A) Nameplate Marking	All Ungrounded Conductors
(B) To Be Visible	424.21 Switch and Circuit Breaker to Be Indicating
422.61 Marking of Heating Elements	424.22 Overcurrent Protection
422.62 Appliances Consisting of Motors and Other Loads	(A) Branch-Circuit Devices
(A) Nameplate Horsepower Markings	(B) Resistance Elements
(B) Additional Nameplate Markings	(C) Overcurrent Protective Devices
Article 424 Fixed Electric Space-Heating Equipment	(D) Branch-Circuit Conductors
<u>Part I. General</u>	(E) Conductors for Subdivided Loads
424.1 Scope	<u>Part IV. Marking of Heating Equipment</u>
424.2 Other Articles	424.28 Nameplate
424.3 Branch Circuits	(A) Marking Required
(A) Branch-Circuit Requirements	(B) Location
(B) Branch-Circuit Sizing	424.29 Marking of Heating Elements
424.6 Listed Equipment	<u>Part V. Electric Space-Heating Cables</u>
<u>Part II. Installation</u>	424.34 Heating Cable Construction
424.9 General	424.35 Marking of Heating Cables
424.10 Special Permission	424.36 Clearances of Wiring in Ceilings
424.11 Supply Conductors	424.38 Area Restrictions
424.12 Locations	(A) Extending Beyond the Room or Area
(A) Exposed to Physical Damage	(B) Uses Not Permitted
(B) Damp or Wet Locations	(C) In Closet Ceilings as Low-Temperature Heat
424.13 Spacing from Combustible Materials	Sources to Control Relative Humidity
<u>Part III. Control and Protection of Fixed Electric</u>	424.39 Clearance from Other Objects and Openings
Space-Heating Equipment	424.40 Splices
424.19 Disconnecting Means	424.41 Ceiling Installation of Heating Cables on Dry
(A) Heating Equipment with Supplementary	Board, in Plaster, and on Concrete
Overcurrent Protection	(A) In Walls
(B) Heating Equipment Without Supplementary	(B) Adjacent Runs
Overcurrent Protection	(C) Surfaces to Be Applied

2017 NEC TABLE OF CONTENTS

(D) Splices	424.61 Installation of Duct Heaters with Heat Pumps and Air Conditioners
(E) Ceiling Surface	
(F) Secured	424.62 Condensation
(G) Dry Board Installations	424.63 Fan Circuit Interlock
(H) Free from Contact with Conductive Surfaces	424.64 Limit Controls
(I) Joists	424.65 Location of Disconnecting Means
(J) Crossing Joists	424.66 Installation
424.42 Finished Ceilings	<u>Part VII. Resistance-Type Boilers</u>
424.43 Installation of Nonheating Leads of Cables	424.70 Scope
(A) Free Nonheating Leads	424.71 Identification
(B) Leads in Junction Box	424.72 Overcurrent Protection
(C) Excess Leads	(A) Boiler Employing Resistance-Type Immersion Heating Elements in an ASME Rated and Stamped Vessel
424.44 Installation of Cables in Concrete or Poured Masonry Floors	(B) Boiler Employing Resistance-Type Heating Elements Rated More Than 48 Amperes and Not Contained in an ASME-Rated and Stamped Vessel
(A) Adjacent Runs	(C) Supplementary Overcurrent Protective Devices
(B) Secured in Place	(D) Conductors Supplying Supplementary Overcurrent Protective Devices
(C) Leads Protected	(E) Conductors for Subdivided Loads
(D) Bushings or Approved Fittings	424.73 Overtemperature Limit Control
(E) Ground-Fault Circuit-Interrupter Protection	424.74 Overpressure Limit Control
424.45 Installation of Cables Under Floor Coverings	<u>Part VIII. Electrode-Type Boilers</u>
(A) Identification	424.80 Scope
(B) Expansion Joints	424.81 Identification
(C) Connection to Conductors	424.82 Branch-Circuit Requirements
(D) Anchoring	424.83 Overtemperature Limit Control
(E) Ground-Fault Circuit-Interrupter Protection	424.84 Overpressure Limit Control
(F) Grounding Braid or Sheath	424.85 Grounding
424.46 Inspection and Tests	424.86 Markings
424.47 Label Provided by Manufacturer	<u>Part IX. Electric Radiant Heating Panels and Heating</u>
<u>Part VI. Duct Heaters</u>	
424.57 General	
424.58 Identification	
424.59 Airflow	
424.60 Elevated Inlet Temperature	

<u>Panel Sets</u>	(A) Power Unit
424.90 Scope	(B) Alternate Energy Sources
424.91 Definitions	424.102 Listed Equipment
424.92 Markings	424.103 Installation
(A) Location	(A) General
(B) Identified as Suitable	(B) Ground
(C) Required Markings	(C) Ground-Fault Protection
424.93 Installation	424.104 Branch Circuit
(A) General	Article 425 Fixed Resistance and Electrode
(B) Heating Panel Sets	Industrial Process Heating Equipment
424.94 Clearances of Wiring in Ceilings	<u>Part I. General</u>
424.95 Location of Branch-Circuit and Feeder Wiring in Walls	425.1 Scope
(A) Exterior Walls	425.2 Other Articles
(B) Interior Walls	425.3 Branch Circuits
424.96 Connection to Branch-Circuit Conductors	(A) Branch-Circuit Requirements
(A) General	(B) Branch-Circuit Sizing
(B) Heating Panels	425.6 Listed Equipment
(C) Heating Panel Sets	<u>Part II. Installation</u>
424.97 Nonheating Leads	425.8 General
424.98 Installation in Concrete or Poured Masonry	(A) Location
(A) Secured in Place and Identified as Suitable	(B) Working Space
(B) Expansion Joints	(C) Above Grade Level, Floor, or Work Platform
(C) Spacings	425.9 Approval
(D) Protection of Leads	425.10 Special Permission
(E) Bushings or Fittings Required	425.11 Supply Conductors
424.99 Installation Under Floor Covering	425.12 Locations
(A) Identification	(A) Exposed to Physical Damage
(B) Installation	(B) Damp or Wet Locations
<u>Part X. Low-Voltage Fixed Electric Space-Heating Equipment</u>	425.13 Spacing from Combustible Materials
424.100 Scope	425.14 Infrared Lamp Industrial Heating Equipment
424.101 Energy Source	<u>Part III. Control and Protection of Fixed Industrial Process Heating Equipment</u>
	425.19 Disconnecting Means

2017 NEC TABLE OF CONTENTS

(A) Heating Equipment with Supplementary Overcurrent Protection	(B) Boiler Employing Resistance-Type Heating Elements Rated More Than 48 Amperes and Not Contained in an ASME-Rated and Stamped Vessel
(B) Heating Equipment Without Supplementary Overcurrent Protection	(C) Supplementary Overcurrent Protective Devices
(C) Unit Switch(es) as Disconnecting Means	(D) Suitable for Branch-Circuit Protection
425.21 Switch and Circuit Breaker to Be Indicating	(E) Conductors Supplying Supplementary Overcurrent Protective Devices
425.22 (A) Branch-Circuit Devices	(F) Conductors for Subdivided Loads
(B) Resistance Elements	425.73 Overtemperature Limit Control
(C) Overcurrent Protective Devices	425.74 Overpressure Limit Control
(D) Branch-Circuit Conductors	<u>Part VII. Fixed Industrial Process Electrode-Type Boilers</u>
(E) Conductors for Subdivided Loads	425.80 Scope
<u>Part IV. Marking of Heating Equipment</u>	425.81 Identification
425.28 Nameplate	425.82 Branch-Circuit Requirements
(A) Marking Required	425.83 Overtemperature Limit Control
(B) Location	425.84 Overpressure Limit Control
425.29 Marking of Heating Elements	425.85 Grounding
425.45 Concealed Fixed Industrial Heating Equipment — Inspection and Tests	425.86 Markings
<u>Part V. Fixed Industrial Process Duct Heaters</u>	Article 426 Fixed Outdoor Electric Deicing and Snow-Melting Equipment
425.57 General	<u>Part I. General</u>
425.58 Identification	426.1 Scope
425.59 Airflow	(A) Embedded
425.60 Elevated Inlet Temperature	(B) Exposed
425.63 Fan Circuit Interlock	426.2 Definitions
425.64 Limit Controls	426.3 Application of Other Articles
425.65 Location of Disconnecting Means	426.4 Continuous Load
<u>Part VI. Fixed Industrial Process Resistance-Type Boilers</u>	<u>Part II. Installation</u>
425.70 Scope	426.10 General
425.71 Identification	426.11 Use
425.72 Overcurrent Protection	426.12 Thermal Protection
(A) Boiler Employing Resistance-Type Immersion Heating Elements in an ASME-Rated and Stamped Vessel	426.13 Identification

426.14 Special Permission	426.31 Isolation Transformer
<u>Part III. Resistance Heating Elements</u>	426.32 Voltage Limitations
426.20 Embedded Deicing and Snow-Melting Equipment	426.33 Induced Currents
(A) Watt Density	426.34 Grounding
(B) Spacing	<u>Part V. Skin-Effect Heating</u>
(C) Cover	426.40 Conductor Ampacity
(D) Secured	426.41 Pull Boxes
(E) Expansion and Contraction	426.42 Single Conductor in Enclosure
426.21 Exposed Deicing and Snow-Melting Equipment	426.43 Corrosion Protection
(A) Secured	426.44 Grounding
(B) Overtemperature	<u>Part VI. Control and Protection</u>
(C) Expansion and Contraction	426.50 Disconnecting Means
(D) Flexural Capability	(A) Disconnection
426.22 Installation of Nonheating Leads for Embedded Equipment	(B) Cord-and-Plug-Connected Equipment
(A) Grounding Sheath or Braid	426.51 Controllers
(B) Raceways	(A) Temperature Controller with “Off” Position
(C) Bushings	(B) Temperature Controller Without “Off” Position
(D) Expansion and Contraction	(C) Remote Temperature Controller
(E) Leads in Junction Boxes	(D) Combined Switching Devices
426.23 Installation of Nonheating Leads for Exposed Equipment	426.54 Cord-and-Plug-Connected Deicing and Snow-Melting Equipment
(A) Nonheating Leads	Article 427 Fixed Electric Heating Equipment for Pipelines and Vessels
(B) Protection	<u>Part I. General</u>
426.24 Electrical Connection	427.1 Scope
(A) Heating Element Connections	427.2 Definitions
(B) Circuit Connections	427.3 Application of Other Articles
426.25 Marking	427.4 Continuous Load
426.26 Corrosion Protection	<u>Part II. Installation</u>
426.27 Grounding Braid or Sheath	427.10 General
426.28 Ground-Fault Protection of Equipment	427.11 Use
<u>Part IV. Impedance Heating</u>	
426.30 Personnel Protection	

427.12 Thermal Protection	427.47 Single Conductor in Enclosure
427.13 Identification	427.48 Grounding
<u>Part III. Resistance Heating Elements</u>	<u>Part VII. Control and Protection</u>
427.14 Secured	427.55 Disconnecting Means
427.15 Not in Direct Contact	(A) Switch or Circuit Breaker
427.16 Expansion and Contraction	(B) Cord-and-Plug-Connected Equipment
427.17 Flexural Capability	427.56 Controls
427.18 Power Supply Leads	(A) Temperature Control with “Off” Position
(A) Nonheating Leads	(B) Temperature Control Without “Off” Position
(B) Power Supply Leads Protection	(C) Remote Temperature Controller
(C) Interconnecting Leads	(D) Combined Switching Devices
427.19 Electrical Connections	427.57 Overcurrent Protection
(A) Nonheating Interconnections	Article 430 Motors, Motor Circuits, and Controllers
(B) Circuit Connections	<u>Part I. General</u>
427.20 Marking	430.1 Scope
427.22 Ground-Fault Protection of Equipment	430.2 Definitions
427.23 Grounded Conductive Covering	430.4 Part-Winding Motors
(A) Heating Wires or Cables	430.5 Other Articles
(B) Heating Panels	430.6 Ampacity and Motor Rating Determination
<u>Part IV. Impedance Heating</u>	(A) General Motor Applications
427.25 Personnel Protection	(B) Torque Motors
427.26 Isolation Transformer	(C) Alternating-Current Adjustable Voltage Motors
427.27 Voltage Limitations	(D) Valve Actuator Motor Assemblies
427.28 Induced Currents	430.7 Marking on Motors and Multimotor Equipment
427.29 Grounding	(A) Usual Motor Applications
427.30 Secondary Conductor Sizing	(B) Locked-Rotor Indicating Code Letters
<u>Part V. Induction Heating</u>	(C) Torque Motors
427.35 Scope	(D) Multimotor and Combination-Load Equipment
427.36 Personnel Protection	430.8 Marking on Controllers
427.37 Induced Current	430.9 Terminals
<u>Part VI. Skin-Effect Heating</u>	(A) Markings
427.45 Conductor Ampacity	(B) Conductors
427.46 Pull Boxes	

2017 NEC TABLE OF CONTENTS

(C) Torque Requirements	430.25 Multimotor and Combination-Load Equipment
430.10 Wiring Space in Enclosures	430.26 Feeder Demand Factor
(A) General	430.27 Capacitors with Motors
(B) Wire-Bending Space in Enclosures	430.28 Feeder Taps
430.11 Protection Against Liquids	430.29 Constant Voltage Direct-Current Motors — Power Resistors
430.12 Motor Terminal Housings	<u>Part III. Motor and Branch-Circuit Overload Protection</u>
(A) Material	430.31 General
(B) Dimensions and Space — Wire-to-Wire Connections	430.32 Continuous-Duty Motors
(C) Dimensions and Space — Fixed Terminal Connections	(A) More Than 1 Horsepower
(D) Large Wire or Factory Connections	(B) One Horsepower or Less, Automatically Started
(E) Equipment Grounding Connections	(C) Selection of Overload Device
430.13 Bushing	(D) One Horsepower or Less, Nonautomatically Started
430.14 Location of Motors	(E) Wound-Rotor Secondaries
(A) Ventilation and Maintenance	430.33 Intermittent and Similar Duty
(B) Open Motors	430.35 Shunting During Starting Period
430.16 Exposure to Dust Accumulations	(A) Nonautomatically Started
430.17 Highest Rated or Smallest Rated Motor	(B) Automatically Started
430.18 Nominal Voltage of Rectifier Systems	430.36 Fuses — In Which Conductor
<u>Part II. Motor Circuit Conductors</u>	430.37 Devices Other Than Fuses — In Which Conductor
430.21 General	430.38 Number of Conductors Opened by Overload Device
430.22 Single Motor	430.39 Motor Controller as Overload Protection
(A) Direct-Current Motor-Rectifier Supplied	430.40 Overload Relays
(B) Multispeed Motor	430.42 Motors on General-Purpose Branch Circuits
(C) Wye-Start, Delta-Run Motor	(A) Not over 1 Horsepower
(D) Part-Winding Motor	(B) Over 1 Horsepower
(E) Other Than Continuous Duty	(C) Cord-and Plug-Connected
(F) Separate Terminal Enclosure	(D) Time Delay
(G) Conductors for Small Motors	430.43 Automatic Restarting
430.23 Wound-Rotor Secondary	430.44 Orderly Shutdown
(A) Continuous Duty	<u>Part IV. Motor Branch-Circuit Short-Circuit and Ground-Fault Protection</u>
(B) Other Than Continuous Duty	
(C) Resistor Separate from Controller	
430.24 Several Motors or a Motor(s) and Other Load(s)	

2017 NEC TABLE OF CONTENTS

430.51 General	(A) General
430.52 Rating or Setting for Individual Motor Circuit	(B) Control Transformer in Controller Enclosure
(A) General	<u>Part VII. Motor Controllers</u>
(B) All Motors	430.81 General
(C) Rating or Setting	(A) Stationary Motor of 1/8 Horsepower or Less
(D) Torque Motors	(B) Portable Motor of 1/3 Horsepower or Less
430.53 Several Motors or Loads on One Branch Circuit	430.82 Controller Design
(A) Not Over 1 Horsepower	(A) Starting and Stopping
(B) If Smallest Rated Motor Protected	(B) Autotransformer
(C) Other Group Installations	(C) Rheostats
(D) Single Motor Taps	430.83 Ratings
430.54 Multimotor and Combination-Load Equipment	(A) General
430.55 Combined Overcurrent Protection	(B) Small Motors
430.56 Branch-Circuit Protective Devices — In Which Conductor	(C) Stationary Motors of 2 Horsepower or Less
430.57 Size of Fuseholder	(D) Torque Motors
430.58 Rating of Circuit Breaker	(E) Voltage Rating
<u>Part V. Motor Feeder Short-Circuit and Ground-Fault Protection</u>	430.84 Need Not Open All Conductors
430.61 General	430.85 In Grounded Conductors
430.62 Rating or Setting — Motor Load	430.87 Number of Motors Served by Each Controller
(A) Specific Load	430.88 Adjustable-Speed Motors
(B) Other Installations	430.89 Speed Limitation
430.63 Rating or Setting — Motor Load and Other Load(s)	430.90 Combination Fuseholder and Switch as Controller
<u>Part VI. Motor Control Circuits</u>	<u>Part VIII. Motor Control Centers</u>
430.71 General	430.92 General
430.72 Overcurrent Protection	430.94 Overcurrent Protection
(A) General	430.95 Service Equipment
(B) Conductor Protection	430.96 Grounding
(C) Control Circuit Transformer	430.97 Busbars and Conductors
430.73 Protection of Conductors from Physical Damage	(A) Support and Arrangement
430.74 Electrical Arrangement of Control Circuits	(B) Phase Arrangement
430.75 Disconnection	(C) Minimum Wire-Bending Space
	(D) Spacings
	(E) Barriers

2017 NEC TABLE OF CONTENTS

430.98 Marking	430.120 General
(A) Motor Control Centers	430.122 Conductors — Minimum Size and Ampacity
(B) Motor Control Units	(A) Branch/Feeder Circuit Conductors
430.99 Available Fault Current	(B) Bypass Device
<u>Part IX. Disconnecting Means</u>	430.124 Overload Protection
430.101 General	(A) Included in Power Conversion Equipment
430.102 Location	(B) Bypass Circuits
(A) Controller	(C) Multiple Motor Applications
(B) Motor	430.126 Motor Overtemperature Protection
430.103 Operation	(A) General
430.104 To Be Indicating	(B) Multiple Motor Applications
430.105 Grounded Conductors	(C) Automatic Restarting and Orderly Shutdown
430.107 Readily Accessible	430.128 Disconnecting Means
430.108 Every Disconnecting Means	430.130 Branch-Circuit Short-Circuit and Ground-Fault Protection for Single Motor Circuits Containing Power Conversion Equipment
430.109 Type	(A) Circuits Containing Power Conversion Equipment
(A) General	(B) Bypass Circuit/Device
(B) Stationary Motors of 1/8 Horsepower or Less	430.131 Several Motors or Loads on One Branch Circuit Including Power Conversion Equipment
(C) Stationary Motors of 2 Horsepower or Less	<u>Part XI. Over 1000 Volts, Nominal</u>
(D) Autotransformer-Type Controlled Motors	430.221 General
(E) Isolating Switches	430.222 Marking on Controllers
(F) Cord-and-Plug-Connected Motors	430.223 Raceway Connection to Motors
(G) Torque Motors	430.224 Size of Conductors
430.110 Ampere Rating and Interrupting Capacity	430.225 Motor-Circuit Overcurrent Protection
(A) General	(A) General
(B) For Torque Motors	(B) Overload Protection
(C) For Combination Loads	(C) Fault-Current Protection
430.111 Switch or Circuit Breaker as Both Controller and Disconnecting Means	430.226 Rating of Motor Control Apparatus
(A) General	430.227 Disconnecting Means
(B) Type	<u>Part XII. Protection of Live Parts — All Voltages</u>
430.112 Motors Served by Single Disconnecting Means	430.231 General
430.113 Energy from More Than One Source	
<u>Part X. Adjustable-Speed Drive Systems</u>	

430.232 Where Required	(A) Installation
430.233 Guards for Attendants	(B) Documentation
<u>Part XIII. Grounding — All Voltages</u>	<u>Part II. Disconnecting Means</u>
430.241 General	440.11 General
430.242 Stationary Motors	440.12 Rating and Interrupting Capacity
430.243 Portable Motors	(A) Hermetic Refrigerant Motor-Compressor
430.244 Controllers	(B) Combination Loads
430.245 Method of Grounding	(C) Small Motor-Compressors
(A) Grounding Through Terminal Housings	(D) Disconnecting Means
(B) Separation of Junction Box from Motor	(E) Disconnecting Means Rated in Excess
(C) Grounding of Controller-Mounted Devices	of 100 Horsepower
<u>Part XIV. Tables</u>	440.13 Cord-Connected Equipment
Article 440 Air-Conditioning and Refrigerating Equipment	440.14 Location
<u>Part I. General</u>	<u>Part III. Branch-Circuit Short-Circuit</u>
440.1 Scope	and Ground-Fault Protection
440.2 Definitions	440.21 General
440.3 Other Articles	440.22 Application and Selection
(A) Article 430	(A) Rating or Setting for Individual
(B) Articles 422, 424, or 430	Motor-Compressor
(C) Article 422	(B) Rating or Setting for Equipment
(D) Other Applicable Articles	(C) Protective Device Rating Not to Exceed
440.4 Marking on Hermetic Refrigerant	the Manufacturer’s Values
Motor-Compressors and Equipment	<u>Part IV. Branch-Circuit Conductors</u>
(A) Hermetic Refrigerant Motor-Compressor Nameplate	440.31 General
(B) Multimotor and Combination-Load Equipment	440.32 Single Motor-Compressor
(C) Branch-Circuit Selection Current	440.33 Motor-Compressor(s) With or Without Additional
440.5 Marking on Controllers	Motor Loads
440.6 Ampacity and Rating	440.34 Combination Load
(A) Hermetic Refrigerant Motor-Compressor	440.35 Multimotor and Combination-Load Equipment
(B) Multimotor Equipment	<u>Part V. Controllers for Motor-Compressors</u>
440.7 Highest Rated (Largest) Motor	440.41 Rating
440.8 Single Machine	(A) Motor-Compressor Controller
440.9 Grounding and Bonding	(B) Controller Serving More Than One Load
440.10 Short-Circuit Current Rating	

<u>Part VI. Motor-Compressor and Branch-Circuit</u>	445.1 Scope
<u>Overload Protection</u>	445.10 Location
440.51 General	445.11 Marking
440.52 Application and Selection	445.12 Overcurrent Protection
(A) Protection of Motor-Compressor	(A) Constant-Voltage Generators
(B) Protection of Motor-Compressor Control	(B) Two-Wire Generators
Apparatus and Branch-Circuit Conductors	(C) 65 Volts or Less
440.53 Overload Relays	(D) Balancer Sets
440.54 Motor-Compressors and Equipment on 15- or	(E) Three-Wire, Direct-Current Generators
20-Ampere Branch Circuits — Not Cord- and	445.13 Ampacity of Conductors
Attachment-Plug-Connected	(A) General
(A) Overload Protection	(B) Overcurrent Protection Provided
(B) Time Delay	445.14 Protection of Live Parts
440.55 Cord- and Attachment-Plug-Connected	445.15 Guards for Attendants
Motor-Compressors and Equipment on 15- or	445.16 Bushings
20-Ampere Branch Circuits	445.17 Generator Terminal Housings
(A) Overload Protection	445.18 Disconnecting Means and Shutdown of Prime
(B) Attachment Plug and Receptacle or Cord	Mover
Connector Rating	(A) Disconnecting Means
(C) Time Delay	(B) Shutdown of Prime Mover
<u>Part VII. Provisions for Room Air Conditioners</u>	(C) Generators Installed in Parallel
440.60 General	445.20 Ground-Fault Circuit-Interrupter Protection for
440.61 Grounding	Receptacles on 15-kW or Smaller Portable Generators
440.62 Branch-Circuit Requirements	(A) Unbonded (Floating Neutral) Generators
(A) Room Air Conditioner as a Single Motor	(B) Bonded Neutral Generators
Unit	Article 450 Transformers and Transformer Vaults
(B) Where No Other Loads Are Supplied	(Including Secondary Ties)
(C) Where Lighting Units or Other Appliances	<u>Part I. General Provisions</u>
Are Also Supplied	450.1 Scope
440.63 Disconnecting Means	450.2 Definition
440.64 Supply Cords	450.3 Overcurrent Protection
440.65 Protection Devices	(A) Transformers Over 1000 Volts, Nominal
Article 445 Generators	(B) Transformers 1000 Volts, Nominal, or Less

(C) Voltage (Potential) Transformers	Types of Transformers
450.4 Autotransformers 1000 Volts, Nominal, or Less	450.21 Dry-Type Transformers Installed Indoors
(A) Overcurrent Protection	(A) Not Over 1121/2 kVA
(B) Transformer Field-Connected as an Autotransformer	(B) Over 1121/2 kVA
450.5 Grounding Autotransformers	(C) Over 35,000 Volts
(A) Three-Phase, 4-Wire System	450.22 Dry-Type Transformers Installed Outdoors
(B) Ground Reference for Fault Protection Devices	450.23 Less-Flammable Liquid-Insulated Transformers
(C) Ground Reference for Damping Transitory	(A) Indoor Installations
Overvoltages	(B) Outdoor Installations
450.6 Secondary Ties	450.24 Nonflammable Fluid-Insulated Transformers
(A) Tie Circuits	450.25 Askarel-Insulated Transformers Installed Indoors
(B) Overcurrent Protection for Secondary	450.26 Oil-Insulated Transformers Installed Indoors
Connections	450.27 Oil-Insulated Transformers Installed Outdoors
(C) Grounding	450.28 Modification of Transformers
450.7 Parallel Operation	<u>Part III. Transformer Vaults</u>
450.8 Guarding	450.41 Location
(A) Mechanical Protection	450.42 Walls, Roofs, and Floors
(B) Case or Enclosure	450.43 Doorways
(C) Exposed Energized Parts	(A) Type of Door
(D) Voltage Warning	(B) Sills
450.9 Ventilation	(C) Locks
450.10 Grounding	450.45 Ventilation Openings
(A) Dry-Type Transformer Enclosures	(A) Location
(B) Other Metal Parts	(B) Arrangement
450.11 Marking	(C) Size
(A) General	(D) Covering
(B) Source Marking	(E) Dampers
450.12 Terminal Wiring Space	(F) Ducts
450.13 Accessibility	450.46 Drainage
(A) Open Installations	450.47 Water Pipes and Accessories
(B) Hollow Space Installations	450.48 Storage in Vaults
450.14 Disconnecting Means	Article 455 Phase Converters
<u>Part II. Specific Provisions Applicable to Different</u>	<u>Part I. General</u>

2017 NEC TABLE OF CONTENTS

455.1 Scope	(B) Means of Discharge
455.2 Definitions	460.8 Conductors
455.3 Other Articles	(A) Ampacity
455.4 Marking	(B) Overcurrent Protection
455.5 Equipment Grounding Connection	(C) Disconnecting Means
455.6 Conductors	460.9 Rating or Setting of Motor Overload Device
(A) Ampacity	460.10 Grounding
(B) Manufactured Phase Marking	460.12 Marking
455.7 Overcurrent Protection	<u>Part II. Over 1000 Volts, Nominal</u>
(A) Variable Loads	460.24 Switching
(B) Fixed Loads	(A) Load Current
455.8 Disconnecting Means	(B) Isolation
(A) Location	(C) Additional Requirements for Series Capacitors
(B) Type	460.25 Overcurrent Protection
(C) Rating	(A) Provided to Detect and Interrupt Fault Current
(D) Voltage Ratios	(B) Single Pole or Multipole Devices
455.9 Connection of Single-Phase Loads	(C) Protected Individually or in Groups
455.10 Terminal Housings	(D) Protective Devices Rated or Adjusted
<u>Part II. Specific Provisions Applicable to Different</u>	460.26 Identification
<u>Types of Phase Converters</u>	460.27 Grounding
455.20 Disconnecting Means	460.28 Means for Discharge
455.21 Start-Up	(A) Means to Reduce the Residual Voltage
455.22 Power Interruption	(B) Connection to Terminals
455.23 Capacitors	Article 470 Resistors and Reactors
Article 460 Capacitors	<u>Part I. 1000 Volts, Nominal, and Under</u>
460.1 Scope	470.1 Scope
460.2 Enclosing and Guarding	470.2 Location
(A) Containing More Than 11 L (3 gal) of	470.3 Space Separation
Flammable Liquid	470.4 Conductor Insulation
(B) Accidental Contact	<u>Part II. Over 1000 Volts, Nominal</u>
<u>Part I. 1000 Volts, Nominal, and Under</u>	470.18 General
460.6 Discharge of Stored Energy	(A) Protected Against Physical Damage
(A) Time of Discharge	(B) Isolated by Enclosure or Elevation

(C) Combustible Materials	(B) Sealed Cells
(D) Clearances	Article 490 Equipment Over 1000 Volts, Nominal
(E) Temperature Rise from Induced Circulating Currents	<u>Part I. General</u>
470.19 Grounding	490.1 Scope
470.20 Oil-Filled Reactors	490.2 Definition
Article 480 Storage Batteries	490.3 Other Articles
480.1 Scope	(A) Oil-Filled Equipment
480.2 Definitions	(B) Enclosures in Damp or Wet Locations
480.3 Equipment	<u>Part II. Equipment — Specific Provisions</u>
480.4 Battery and Cell Terminations	490.21 Circuit-Interrupting Devices
(A) Corrosion Prevention	(A) Circuit Breakers
(B) Intercell and Intertier Conductors and Connections	(B) Power Fuses and Fuseholders
(C) Battery Terminals	(C) Distribution Cutouts and Fuse Links — Expulsion Type
480.5 Wiring and Equipment Supplied from Batteries	(D) Oil-Filled Cutouts
480.6 Overcurrent Protection for Prime Movers	(E) Load Interrupters
480.7 DC Disconnect Methods	490.22 Isolating Means
(A) Disconnecting Means	490.23 Voltage Regulators
(B) Remote Actuation	490.24 Minimum Space Separation
(C) Busway	490.25 Backfeed
(D) Notification	<u>Part III. Equipment — Switchgear and Industrial Control Assemblies</u>
480.8 Insulation of Batteries	490.30 General
480.9 Battery Support Systems	490.31 Arrangement of Devices in Assemblies
480.10 Battery Locations	490.32 Guarding of High-Voltage Energized Parts Within a Compartment
(A) Ventilation	490.33 Guarding of Energized Parts Operating at 1000 Volts, Nominal, or Less Within Compartments
(B) Live Parts	490.34 Clearance for Cable Conductors Entering Enclosure
(C) Spaces About Battery Systems	490.35 Accessibility of Energized Parts
(D) Top Terminal Batteries	(A) High-Voltage Equipment
(E) Egress	(B) Control Equipment
(F) Piping in Battery Rooms	(C) High-Voltage Instruments or Control Transformers and Space Heaters
(G) Illumination	
480.11 Vents	
(A) Vented Cells	

490.36 Grounding	490.55 Power Cable Connections to Mobile Machines
490.37 Grounding of Devices	490.56 High-Voltage Portable Cable for Main Power Supply
490.38 Door Stops and Cover Plates	<u>Part V. Electrode-Type Boilers</u>
490.39 Gas Discharge from Interrupting Devices	490.70 General
490.40 Visual Inspection Windows	490.71 Electrical Supply System
490.41 Location of Industrial Control Equipment	490.72 Branch-Circuit Requirements
(A) Control and Instrument Transfer Switch	(A) Rating
Handles or Push Buttons	(B) Common-Trip Fault-Interrupting Device
(B) Infrequently Operated Devices	(C) Phase-Fault Protection
490.42 Interlocks — Interrupter Switches	(D) Ground Current Detection
490.43 Stored Energy for Opening	(E) Grounded Neutral Conductor
490.44 Fused Interrupter Switches	490.73 Pressure and Temperature Limit Control
(A) Supply Terminals	490.74 Bonding
(B) Backfeed	Article 500 Hazardous (Classified) Locations,
(C) Switching Mechanism	Classes I, II, and III, Divisions 1 and 2
490.45 Circuit Breakers — Interlocks	500.1 Scope — Articles 500 Through 504
(A) Circuit Breakers	500.3 Other Articles
(B) Mechanical Interlocks	500.4 General
490.46 Circuit Breaker Locking	(A) Documentation
490.47 Switchgear Used as Service Equipment	(B) Reference Standards
490.48 Substation Design, Documentation, and Required	500.5 Classifications of Locations
Diagram	(A) General
(A) Design and Documentation	(B) Class I Locations
(B) Diagram	(C) Class II Locations
<u>Part IV. Mobile and Portable Equipment</u>	(D) Class III Locations
490.51 General	500.6 Material Groups
(A) Covered	(A) Class I Group Classifications
(B) Other Requirements	(B) Class II Group Classifications
(C) Protection	500.7 Protection Techniques
(D) Disconnecting Means	(A) Explosionproof Equipment
490.52 Overcurrent Protection	(B) Dust Ignitionproof
490.53 Enclosures	(C) Dusttight
490.54 Collector Rings	(D) Purged and Pressurized

2017 NEC TABLE OF CONTENTS

(E) Intrinsic Safety	501.25 Uninsulated Exposed Parts, Class I, Divisions 1 and 2
(F) Nonincendive Circuit	
(G) Nonincendive Equipment	501.30 Grounding and Bonding, Class I, Divisions 1 and 2
(H) Nonincendive Component	
(I) Oil Immersion	(A) Bonding
(J) Hermetically Sealed	(B) Types of Equipment Grounding Conductors
(K) Combustible Gas Detection System	501.35 Surge Protection
(L) Other Protection Techniques	(A) Class I, Division 1
500.8 Equipment	(B) Class I, Division 2
(A) Suitability	<u>Part III. Equipment</u>
(B) Approval for Class and Properties	501.100 Transformers and Capacitors
(C) Marking	(A) Class I, Division 1
(D) Temperature	(B) Class I, Division 2
(E) Threading	501.105 Meters, Instruments, and Relays
(F) Optical Fiber Cables	(A) Class I, Division 1
500.9 Specific Occupancies	(B) Class I, Division 2
Article 501 Class I Locations	501.115 Switches, Circuit Breakers, Motor Controllers, and Fuses
<u>Part I. General</u>	(A) Class I, Division 1
501.1 Scope	(B) Class I, Division 2
501.5 Zone Equipment	
<u>Part II. Wiring</u>	501.120 Control Transformers and Resistors
501.10 Wiring Methods	(A) Class I, Division 1
(A) Class I, Division 1	(B) Class I, Division 2
(B) Class I, Division 2	501.125 Motors and Generators
501.15 Sealing and Drainage	(A) Class I, Division 1
(A) Conduit Seals, Class I, Division 1	(B) Class I, Division 2
(B) Conduit Seals, Class I, Division 2	501.130 Luminaires
(C) Class I, Divisions 1 and 2	(A) Class I, Division 1
(D) Cable Seals, Class I, Division 1	(B) Class I, Division 2
(E) Cable Seals, Class I, Division 2	501.135 Utilization Equipment
(F) Drainage	(A) Class I, Division 1
501.17 Process Sealing	(B) Class I, Division 2
501.20 Conductor Insulation, Class I, Divisions 1 and 2	501.140 Flexible Cords, Class I, Divisions 1 and 2

(A) Permitted Uses	(B) Class II, Division 2
(B) Installation	502.120 Control Transformers and Resistors
501.145 Receptacles and Attachment Plugs, Class I, Divisions 1 and 2	(A) Class II, Division 1
(A) Receptacles	(B) Class II, Division 2
(B) Attachment Plugs	502.125 Motors and Generators
501.150 Signaling, Alarm, Remote-Control, and Communications Systems	(A) Class II, Division 1
(A) Class I, Division 1	(B) Class II, Division 2
(B) Class I, Division 2	502.128 Ventilating Piping
Article 502 Class II Locations	(A) Class II, Division 1
<u>Part I. General</u>	(B) Class II, Division 2
502.1 Scope	502.130 Luminaires
502.5 Explosionproof Equipment	(A) Class II, Division 1
502.6 Zone Equipment	(B) Class II, Division 2
<u>Part II. Wiring</u>	502.135 Utilization Equipment
502.10 Wiring Methods	(A) Class II, Division 1
(A) Class II, Division 1	(B) Class II, Division 2
(B) Class II, Division 2	502.140 Flexible Cords — Class II, Divisions 1 and 2
502.15 Sealing, Class II, Divisions 1 and 2	(A) Permitted Uses
502.25 Uninsulated Exposed Parts, Class II, Divisions 1 and 2	(B) Installation
502.30 Grounding and Bonding, Class II, Divisions 1 and 2	502.145 Receptacles and Attachment Plugs
(A) Bonding	(A) Class II, Division 1
(B) Types of Equipment Grounding Conductors	(B) Class II, Division 2
502.35 Surge Protection — Class II, Divisions 1 and 2	502.150 Signaling, Alarm, Remote-Control, and Communications Systems; and Meters, Instruments, and Relays
<u>Part III. Equipment</u>	(A) Class II, Division 1
502.100 Transformers and Capacitors	(B) Class II, Division 2
(A) Class II, Division 1	Article 503 Class III Locations
(B) Class II, Division 2	<u>Part I. General</u>
502.115 Switches, Circuit Breakers, Motor Controllers, and Fuses	503.1 Scope
(A) Class II, Division 1	503.5 General
	503.6 Zone Equipment
	<u>Part II. Wiring</u>

503.10 Wiring Methods	503.150 Signaling, Alarm, Remote-Control, and Local Loudspeaker Intercommunications Systems — Class III, Divisions 1 and 2
(A) Class III, Division 1	
(B) Class III, Division 2	
503.25 Uninsulated Exposed Parts, Class III, Divisions 1 and 2	503.155 Electric Cranes, Hoists, and Similar Equipment — Class III, Divisions 1 and 2
503.30 Grounding and Bonding — Class III, Divisions 1 and 2	(A) Power Supply
(A) Bonding	(B) Contact Conductors
(B) Types of Equipment Bonding Conductors	(C) Current Collectors
<u>Part III. Equipment</u>	(D) Control Equipment
503.100 Transformers and Capacitors — Class III, Divisions 1 and 2	503.160 Storage Battery Charging Equipment — Class III, Divisions 1 and 2
503.115 Switches, Circuit Breakers, Motor Controllers, and Fuses — Class III, Divisions 1 and 2	Article 504 Intrinsically Safe Systems
503.120 Control Transformers and Resistors — Class III, Divisions 1 and 2	504.1 Scope
503.125 Motors and Generators — Class III, Divisions 1 and 2	504.2 Definitions
503.128 Ventilating Piping — Class III, Divisions 1 and 2	504.3 Application of Other Articles
503.130 Luminaires — Class III, Divisions 1 and 2	504.4 Equipment
(A) Fixed Lighting	504.10 Equipment Installation
(B) Physical Damage	(A) Control Drawing
(C) Pendant Luminaires	(B) Location
(D) Portable Lighting Equipment	(C) Enclosures
503.135 Utilization Equipment — Class III, Divisions 1 and 2	(D) Simple Apparatus
(A) Heaters	504.20 Wiring Methods
(B) Motors	504.30 Separation of Intrinsically Safe Conductors
(C) Switches, Circuit Breakers, Motor Controllers, and Fuses	(A) From Nonintrinsically Safe Circuit Conductors
503.140 Flexible Cords — Class III, Divisions 1 and 2	(B) From Different Intrinsically Safe Circuit Conductors
503.145 Receptacles and Attachment Plugs — Class III, Divisions 1 and 2	(C) From Grounded Metal
	504.50 Grounding
	(A) Intrinsically Safe Apparatus, Enclosures, and Raceways
	(B) Associated Apparatus and Cable Shields
	(C) Connection to Grounding Electrodes
	504.60 Bonding

(A) Intrinsically Safe Apparatus	(C) Intrinsic Safety “i”
(B) Metal Raceways	(D) Type of Protection “n”
504.70 Sealing	(E) Oil Immersion “o”
504.80 Identification	(F) Increased Safety “e”
(A) Terminals	(G) Encapsulation “m”
(B) Wiring	(H) Powder Filling “q”
(C) Color Coding	(I) Combustible Gas Detection System
Article 505 Zone 0, 1, and 2 Locations	505.9 Equipment
505.1 Scope	(A) Suitability
505.2 Definitions	(B) Listing
505.3 Other Articles	(C) Marking
505.4 General	(D) Class I Temperature
(A) Documentation for Industrial Occupancies	(E) Threading
(B) Reference Standards	(F) Optical Fiber Cables
505.5 Classifications of Locations	505.15 Wiring Methods
(A) General	(A) Class I, Zone 0
(B) Class I, Zone 0, 1, and 2 Locations	(B) Class I, Zone 1
505.6 Material Groups	(C) Class I, Zone 2
(A) Group IIC	505.16 Sealing and Drainage
(B) Group IIB	(A) Zone 0
(C) Group IIA	(B) Zone 1
505.7 Special Precaution	(C) Zone 2
(A) Implementation of Zone Classification System	(D) Class I, Zones 0, 1, and 2
(B) Dual Classification	(E) Drainage
(C) Reclassification Permitted	505.17 Flexible Cables, Cords and Connections
(D) Solid Obstacles	(A) Flexible Cords, Class I, Zones 1 and 2
(E) Simultaneous Presence of Flammable Gases and Combustible Dusts or Fibers/Flyings	(B) Instrumentation Connections for Zone 2
(F) Available Short-Circuit Current for Type of Protection “e”	505.18 Conductors and Conductor Insulation
505.8 Protection Techniques	(A) Conductors
(A) Flameproof “d”	(B) Conductor Insulation
(B) Pressurization “p”	505.19 Uninsulated Exposed Parts
	505.20 Equipment Requirements
	(A) Zone 0

(B) Zone 1	(C) Intrinsic Safety
(C) Zone 2	(D) Dusttight
(D) Materials	(E) Protection by Encapsulation “m”
(E) Manufacturer’s Instructions	(F) Nonincendive Equipment
505.22 Increased Safety “e” Motors and Generators	(G) Protection by Enclosure “t”
505.25 Grounding and Bonding	(H) Protection by Pressurization “pD”
(A) Bonding	(I) Protection by Intrinsic Safety “iD”
(B) Types of Equipment Grounding Conductors	506.9 Equipment Requirements
505.26 Process Sealing	(A) Suita
Article 506 Zone 20, 21, and 22 Locations for Combustible Dusts or Ignitable Fibers/Flyings	(B) Listing
506.1 Scope	(C) Marking
506.2 Definitions	(D) Temperature Classifications
506.3 Other Articles	(E) Threading
506.4 General	(F) Optical Fiber Cables
(A) Documentation for Industrial Occupancies	506.15 Wiring Methods
(B) Reference Standards	(A) Zone 20
506.5 Classification of Locations	(B) Zone 21
(A) Classifications of Locations	(C) Zone 22
(B) Zone 20, Zone 21, and Zone 22 Locations	506.16 Sealing
506.6 Material Groups	506.17 Flexible Cords
(A) Group IIIC	506.20 Equipment Installation
(B) Group IIIB	(A) Zone 20
(C) Group IIIA	(B) Zone 21
506.7 Special Precaution	(C) Zone 22
(A) Implementation of Zone Classification System	(D) Material Group
(B) Dual Classification	(E) Manufacturer’s Instructions
(C) Reclassification Permitted	(F) Temperature
(D) Simultaneous Presence of Flammable Gases and Combustible Dusts or Fibers/Flyings	506.25 Grounding and Bonding
506.8 Protection Techniques	(A) Bonding
(A) Dust Ignitionproof	(B) Types of Equipment Grounding Conductors
(B) Pressurized	Article 510 Hazardous (Classified) Locations — Specific
	510.1 Scope

510.2 General	(B) Areas Not Cut Off or Ventilated
Article 511 Commercial Garages, Repair and Storage	(C) Vicinity of Aircraft
511.1 Scope	(D) Areas Suitably Cut Off and Ventilated
511.2 Definitions	513.4 Wiring and Equipment in Class I Locations
511.3 Area Classification, General	(A) General
(A) Parking Garages	(B) Stanchions, Rostrums, and Docks
(B) Repair Garages, with Dispensing	513.7 Wiring and Equipment Not Installed in Class I
(C) Repair Garages, Major and Minor	Locations
(D) Repair Garages, Major	(A) Fixed Wiring
(E) Modifications to Classification	(B) Pendants
511.4 Wiring and Equipment in Class I Locations	(C) Arcing Equipment
(A) Wiring Located in Class I Locations	(D) Lampholders
(B) Equipment Located in Class I Locations	(E) Stanchions, Rostrums, or Docks
511.7 Wiring and Equipment Installed Above Class I	(F) Mobile Stanchions
Locations	513.8 Underground Wiring
(A) Wiring in Spaces Above Class I Locations	(A) Wiring and Equipment Embedded, Under Slab,
(B) Electrical Equipment Installed Above Class I Locations	or Underground
511.8 Underground Wiring	(B) Uninterrupted Raceways, Embedded, Under
511.9 Sealing	Slab, or Underground
511.10 Special Equipment	513.9 Sealing
(A) Battery Charging Equipment	513.10 Special Equipment
(B) Electric Vehicle Charging Equipment	(A) Aircraft Electrical Systems
511.12 Ground-Fault Circuit-Interrupter Protection for	(B) Aircraft Battery Charging and Equipment
Personnel	(C) External Power Sources for Energizing Aircraft
511.16 Grounding and Bonding Requirements	(D) Mobile Servicing Equipment with Electrical
(A) General Grounding Requirements	Components
(B) Supplying Circuits with Grounded and	(E) Portable Equipment
Grounding Conductors in Class I Locations	513.12 Ground-Fault Circuit-Interrupter Protection
Article 513 Aircraft Hangars	for Personnel
513.1 Scope	513.16 Grounding and Bonding Requirements
513.2 Definitions	(A) General Grounding Requirements
513.3 Classification of Locations	(B) Supplying Circuits with Grounded and
(A) Below Floor Level	Grounding Conductors in Class I Locations

Article 514 Motor Fuel Dispensing Facilities

- 514.1 Scope
- 514.2 Definition
- 514.3 Classification of Locations
 - (A) Unclassified Locations
 - (B) Classified Locations
 - (C) Motor Fuel Dispensing Stations in Boatyards and Marinas
 - (D) Closed Construction
 - (E) Open Construction
- 514.4 Wiring and Equipment Installed in Class I Locations
- 514.7 Wiring and Equipment Above Class I Locations
- 514.8 Underground Wiring
- 514.9 Sealing
 - (A) At Dispenser
 - (B) At Boundary
- 514.11 Circuit Disconnects
 - (A) Emergency Electrical Disconnects
 - (B) Attended Self-Service Motor Fuel Dispensing Facilities
 - (C) Unattended Self-Service Motor Fuel Dispensing Facilities
- 514.13 Provisions for Maintenance and Service of Dispensing Equipment
- 514.16 Grounding and Bonding

Article 515 Bulk Storage Plants

- 515.1 Scope
- 515.3 Class I Locations
- 515.4 Wiring and Equipment Located in Class I Locations
- 515.7 Wiring and Equipment Above Class I Locations
 - (A) Fixed Wiring
 - (B) Fixed Equipment
 - (C) Portable Luminaires or Other Utilization

- Equipment
- 515.8 Underground Wiring
 - (A) Wiring Method
 - (B) Insulation
 - (C) Nonmetallic Wiring
- 515.9 Sealing
- 515.10 Special Equipment — Gasoline Dispensers
- 515.16 Grounding and Bonding

Article 516 Spray Application, Dipping, Coating, and Printing Processes Using Flammable or Combustible Materials

Part I. General

- 516.1 Scope
- 516.2 Definitions

Part II. Open Containers

- 516.4 Area Classification

Part III. Spray Application Processes

- 516.5 Area Classification
 - (A) Zone Classification of Locations
 - (B) Class I, Division 1 or Class I, Zone 0 Locations
 - (C) Class I, Division 1; Class I, Zone 1; Class II, Division 1; or Zone 21 Locations
 - (D) Class I, Division 2; Class I, Zone 2; Class II, Division 2; or Zone 22 Locations
- 516.6 Wiring and Equipment in Class I Locations
 - (A) Wiring and Equipment — Vapors
 - (B) Wiring and Equipment — Vapors and Residues
 - (C) Illumination
 - (D) Portable Equipment
 - (E) Electrostatic Equipment
 - (F) Static Electric Discharges
- 516.7 Wiring and Equipment Not Within Classified

2017 NEC TABLE OF CONTENTS

Locations	517.12 Wiring Methods
(A) Wiring	517.13 Grounding of Receptacles and Fixed Electrical Equipment in Patient Care Spaces
(B) Equipment	(A) Wiring Methods
516.10 Special Equipment	(B) Insulated Equipment Grounding Conductors and Insulated Equipment Bonding Jumpers
(A) Fixed Electrostatic Equipment	517.14 Panelboard Bonding
(B) Hand-Spraying Electrostatic Equipment	517.16 Use of Isolated Ground Receptacles
(C) Powder Coating	(A) Inside of a Patient Care Vicinity
516.16 Grounding	(B) Outside of a Patient Care Vicinity
<u>Part IV. Spray Application Operations in Membrane Enclosures</u>	517.17 Ground-Fault Protection
516.18 Area Classification for Temporary Membrane Enclosures	(A) Applicability
516.23 Electrical and Other Sources of Ignition	(B) Feeders
<u>Part V. Printing, Dipping, and Coating Processes</u>	(C) Selectivity
516.29 Classification of Locations	(D) Testing
516.35 Areas Adjacent to Enclosed Dipping and Coating Processes	517.18 General Care (Category 2) Spaces
516.36 Equipment and Containers in Ventilated Areas	(A) Patient Bed Location
516.37 Luminaires	(B) Patient Bed Location Receptacles
516.38 Wiring and Equipment Not Within Classified Locations	(C) Designated General Care (Category 2) Pediatric Locations
(A) Wiring	517.19 Critical Care (Category 1) Spaces
(B) Equipment	(A) Patient Bed Location Branch Circuits
516.40 Static Electric Discharges	(B) Patient Bed Location Receptacles
Article 517 Health Care Facilities	(C) Operating Room Receptacles
<u>Part I. General</u>	(D) Patient Care Vicinity Grounding and Bonding (Optional)
517.1 Scope	(E) Equipment Grounding and Bonding
517.2 Definitions	(F) Additional Protective Techniques in Critical Care (Category 1) Spaces (Optional)
<u>Part II. Wiring and Protection</u>	(G) Isolated Power System Equipment Grounding
517.10 Applicability	(H) Special-Purpose Receptacle Grounding
(A) Applicability	517.20 Wet Procedure Locations
(B) Not Covered	(A) Receptacles and Fixed Equipment
517.11 General Installation — Construction Criteria	

(B) Isolated Power Systems	517.34 Critical Branch
517.21 Ground-Fault Circuit-Interrupter Protection for Personnel	(A) Task Illumination and Selected Receptacles
	(B) Switching
<u>Part III. Essential Electrical System</u>	(C) Subdivision of the Critical Branch
517.25 Scope	517.35 Equipment Branch Connection to Alternate Power Source
517.26 Application of Other Articles	(A) Equipment for Delayed Automatic Connection
517.29 Essential Electrical Systems for Hospitals and Other Health Care Facilities	(B) Equipment for Delayed Automatic or Manual Connection
(A) Applicability	(C) AC Equipment for Nondelayed Automatic Connection
(B) Critical Care (Category 1)	517.40 Type 2 Essential Electrical Systems for Nursing Homes and Limited Care Facilities
517.30 Sources of Power	(A) Applicability
(A) Two Independent Power Sources	(B) Inpatient Hospital Care Facilities
(B) Types of Power Sources	(C) Facilities Contiguous or Located on the Same Site with Hospitals
(C) Location of Essential Electrical System Components	517.41 Required Power Sources
517.31 Requirements for the Essential Electrical System	(A) Two Independent Power Sources
(A) Separate Branches	(B) Types of Power Sources
(B) Transfer Switches	(C) Location of Essential Electrical System Components
(C) Wiring Requirements	517.42 Essential Electrical Systems
(D) Capacity of Systems	(A) General
(E) Receptacle Identification	(B) Transfer Switches
(F) Feeders from Alternate Power Source	(C) Capacity of System
(G) Coordination	(D) Separation from Other Circuits
517.32 Branches Requiring Automatic Connection	(E) Receptacle Identification
517.33 Life Safety Branch	517.43 Automatic Connection to Life Safety Branch
(A) Illumination of Means of Egress	(A) Illumination of Means of Egress
(B) Exit Signs	(B) Exit Signs
(C) Alarm and Alerting Systems	(C) Alarm and Alerting Systems
(D) Communications Systems	
(E) Generator Set Locations	
(F) Generator Set Accessories	
(G) Elevators	
(H) Automatic Doors	

(D) Communications Systems	(D) Remote-Control Stations
(E) Dining and Recreation Areas	(E) Location of Isolated Power Systems
(F) Generator Set Location	(F) Circuits in Anesthetizing Locations
(G) Elevators	517.64 Low-Voltage Equipment and Instruments
517.44 Connection to Equipment Branch	(A) Equipment Requirements
(A) Delayed Automatic Connections to Equipment Branch	(B) Power Supplies
(B) Delayed Automatic or Manual Connection to the Equipment Branch	(C) Isolated Circuits
517.45 Essential Electrical Systems for Other Health Care Facilities	(D) Controls
(A) Essential Electrical Distribution	(E) Battery-Powered Appliances
(B) Electrical Life Support Equipment	(F) Receptacles or Attachment Plugs
(C) Critical Care (Category 1) Patient Care Spaces	<u>Part V. X-Ray Installations</u>
(D) General Care (Category 2) Patient Care Spaces	517.70 Applicability
(E) Power Systems	517.71 Connection to Supply Circuit
<u>Part IV. Inhalation Anesthetizing Locations</u>	(A) Fixed and Stationary Equipment
517.60 Anesthetizing Location Classification	(B) Portable, Mobile, and Transportable Equipment
(A) Hazardous (Classified) Location	(C) Over 1000-Volt Supply
(B) Other-Than-Hazardous (Classified) Location	517.72 Disconnecting Means
517.61 Wiring and Equipment	(A) Capacity
(A) Within Hazardous (Classified) Anesthetizing Locations	(B) Location
(B) Above Hazardous (Classified) Anesthetizing Locations	(C) Portable Equipment
(C) Other-Than-Hazardous (Classified) Anesthetizing Locations	517.73 Rating of Supply Conductors and Overcurrent Protection
517.62 Grounding	(A) Diagnostic Equipment
517.63 Grounded Power Systems in Anesthetizing Locations	(B) Therapeutic Equipment
(A) Battery-Powered Lighting Units	517.74 Control Circuit Conductors
(B) Branch-Circuit Wiring	(A) Number of Conductors in Raceway
(C) Fixed Lighting Branch Circuits	(B) Minimum Size of Conductors
	517.75 Equipment Installations
	517.76 Transformers and Capacitors
	517.77 Installation of High-Tension X-Ray Cables
	517.78 Guarding and Grounding
	(A) High-Voltage Parts
	(B) Low-Voltage Cables

2017 NEC TABLE OF CONTENTS

(C) Non-Current-Carrying Metal Parts	520.1 Scope
<u>Part VI. Communications, Signaling Systems, Data Systems, Fire Alarm Systems, and Systems Less Than 120 Volts, Nominal</u>	520.2 Definitions
517.80 Patient Care Spaces	520.3 Motion Picture Projectors
517.81 Other-Than-Patient-Care Areas	520.4 Audio Signal Processing, Amplification, and Reproduction Equipment
517.82 Signal Transmission Between Appliances	520.5 Wiring Methods
(A) General	(A) General
(B) Common Signal Grounding Wire	(B) Portable Equipment
<u>Part VII. Isolated Power Systems</u>	(C) Nonrated Construction
517.160 Isolated Power Systems	520.6 Number of Conductors in Raceway
(A) Installations	520.7 Enclosing and Guarding Live Parts
(B) Line Isolation Monitor	520.8 Emergency Systems
Article 518 Assembly Occupancies	520.9 Branch Circuits
518.1 Scope	520.10 Portable Equipment Used Outdoors
518.2 General Classification	<u>Part II. Fixed Stage Switchboards</u>
(A) Examples	520.21 General
(B) Multiple Occupancies	520.25 Dimmers
(C) Theatrical Areas	(A) Disconnection and Overcurrent Protection
518.3 Other Articles	(B) Resistance- or Reactor-Type Dimmers
(A) Hazardous (Classified) Areas	(C) Autotransformer-Type Dimmers
(B) Temporary Wiring	(D) Solid-State-Type Dimmers
(C) Emergency Systems	520.26 Type of Switchboard
518.4 Wiring Methods	(A) Manual
(A) General	(B) Remotely Controlled
(B) Nonrated Construction	(C) Intermediate
(C) Spaces with Finish Rating	(D) Constant Power
518.5 Supply	520.27 Stage Switchboard Feeders
Article 520 Theaters, Audience Areas of Motion Picture and Television Studios, Performance Areas, and Similar Locations	(A) Type of Feeder
<u>Part I. General</u>	(B) Neutral Conductor
	(C) Supply Capacity
	<u>Part III. Fixed Stage Equipment Other Than Switchboards</u>
	520.40 Stage Lighting Hoists

520.41 Circuit Loads	(D) Supply Feed-Through
(A) Circuits Rated 20 Amperes or Less	(E) Interior Conductors
(B) Circuits Rated Greater Than 20 Amperes	520.54 Supply Conductors
520.42 Conductor Insulation	(A) General
520.43 Footlights	(B) Conductor Sizing
(A) Metal Trough Construction	(C) Single-Conductor Cables
(B) Other-Than-Metal Trough Construction	(D) Supply Conductors Not Over 3 m (10 ft) Long
(C) Disappearing Footlights	(E) Supply Conductors Not Over 6 m (20 ft) Long
520.44 Borders, Proscenium Sidelights, Drop Boxes, and Connector Strips	(F) Supply Conductors Not Reduced in Size
(A) General	(G) Protection of Supply Conductors and Connectors
(B) Connector Strips and Drop Boxes	(H) Number of Supply Interconnections
(C) Cords and Cables for Border Lights, Drop Boxes, and Connector Strips	(I) Single-Pole Separable Connectors
520.45 Receptacles	(J) Supply Neutral Conductor
520.46 Connector Strips, Drop Boxes, Floor Pockets, and Other Outlet Enclosures	(K) Qualified Personnel
520.47 Backstage Lamps (Bare Bulbs)	<u>Part V. Portable Stage Equipment Other Than</u>
520.48 Curtain Machines	<u>Switchboards</u>
520.49 Smoke Ventilator Control	520.61 Arc Lamps
<u>Part IV. Portable Switchboards on Stage</u>	520.62 Portable Power Distribution Units
520.50 Road Show Connection Panel (A Type of Patch Panel)	(A) Enclosure
(A) Load Circuits	(B) Receptacles and Overcurrent Protection
(B) Circuit Transfer	(C) Busbars and Terminals
(C) Overcurrent Protection	(D) Flanged Surface Inlets
(D) Enclosure	(E) Cable Arrangement
520.51 Supply	(F) Single-Conductor Feeders
520.52 Overcurrent Protection for Branch Circuits	520.63 Bracket Fixture Wiring
520.53 Construction	(A) Bracket Wiring
(A) Pilot Light	(B) Mounting
(B) Neutral Terminal	520.64 Portable Strips
(C) Single-Pole Separable Connectors	520.65 Festoons
	520.66 Special Effects
	520.67 Multipole Branch-Circuit Cable Connectors
	520.68 Conductors for Portables
	(A) Conductor Type

(B) Conductor Ampacity	or Operator Station
(C) Overcurrent Protection	522.22 Conductor Ampacity
520.69 Adapters	522.23 Overcurrent Protection for Conductors
(A) No Reduction in Current Rating	522.24 Conductors of Different Circuits in the Same Cable, Cable Tray, Enclosure, or Raceway
(B) Connectors	(A) Two or More Control Circuits
(C) Conductor Type	(B) Control Circuits with Power Circuits
<u>Part VI. Dressing Rooms, Dressing Areas, and Makeup Areas</u>	522.25 Ungrounded Control Circuits
520.71 Pendant Lampholders	522.28 Control Circuits in Wet Locations
520.72 Lamp Guards	Article 525 Carnivals, Circuses, Fairs, and Similar Events
520.73 Switches Required	<u>Part I. General Requirements</u>
520.74 Pilot Lights Required	525.1 Scope
<u>Part VII. Grounding</u>	525.2 Definitions
520.81 Grounding	525.3 Other Articles
Article 522 Control Systems for Permanent Amusement Attractions	(A) Portable Wiring and Equipment
<u>Part I. General</u>	(B) Permanent Structures
522.1 Scope	(C) Audio Signal Processing, Amplification, and Reproduction Equipment
522.2 Definitions	(D) Attractions Utilizing Pools, Fountains, and Similar Installations with Contained Volumes of Water
522.5 Voltage Limitations	525.5 Overhead Conductor Clearances
522.7 Maintenance	(A) Vertical Clearances
<u>Part II. Control Circuits</u>	(B) Clearance to Portable Structures
522.10 Power Sources for Control Circuits	525.6 Protection of Electrical Equipment
(A) Power-Limited Control Circuits	<u>Part II. Power Sources</u>
(B) Non–Power-Limited Control Circuits	525.10 Services
<u>Part III. Control Circuit Wiring Methods</u>	(A) Guarding
522.20 Conductors, Busbars, and Slip Rings	(B) Mounting and Location
522.21 Conductor Sizing	525.11 Multiple Sources of Supply
(A) Conductors Within a Listed Component or Assembly	<u>Part III. Wiring Methods</u>
(B) Conductors Within an Enclosure or Operator Station	525.20 Wiring Methods
(C) Conductors Outside of an Enclosure	

2017 NEC TABLE OF CONTENTS

(A) Type (B) Single-Conductor (C) Open Conductors (D) Splices (E) Cord Connectors (F) Support (G) Protection (H) Boxes and Fittings 525.21 Rides, Tents, and Concessions (A) Disconnecting Means (B) Portable Wiring Inside Tents and Concessions 525.22 Portable Distribution or Termination Boxes (A) Construction (B) Busbars and Terminals (C) Receptacles and Overcurrent Protection (D) Single-Pole Connectors 525.23 Ground-Fault Circuit-Interrupter (GFCI) Protection (A) Where GFCI Protection Is Required (B) Where GFCI Protection Is Not Required (C) Where GFCI Protection Is Not Permitted (D) Receptacles Supplied by Portable Cords Part IV. Grounding and Bonding 525.30 Equipment Bonding 525.31 Equipment Grounding 525.32 Equipment Grounding Conductor Continuity Assurance Article 530 Motion Picture and Television Studios and Similar Locations <u>Part I. General</u> 530.1 Scope 530.2 Definitions	530.6 Portable Equipment <u>Part II. Stage or Set</u> 530.11 Permanent Wiring 530.12 Portable Wiring (A) Stage Set Wiring (B) Stage Effects and Electrical Equipment Used as Stage Properties (C) Other Electrical Equipment 530.13 Stage Lighting and Effects Control 530.14 Plugging Boxes 530.15 Enclosing and Guarding Live Parts (A) Live Parts (B) Switches (C) Rheostats (D) Current-Carrying Parts 530.16 Portable Luminaires 530.17 Portable Arc Lamps (A) Portable Carbon Arc Lamps (B) Portable Noncarbon Arc Electric-Discharge Lamps 530.18 Overcurrent Protection — General (A) Stage Cables (B) Feeders (C) Cable Protection (D) Location Boards (E) Plugging Boxes (F) Alternating-Current Power Distribution Boxes (G) Lighting 530.19 Sizing of Feeder Conductors for Television Studio Sets (A) General (B) Portable Feeders
---	---

530.20 Grounding	Rectifiers, Rheostats, and Similar Equipment
530.21 Plugs and Receptacles	(B) Switches, Overcurrent Devices, or Other Equipment
(A) Rating	(C) Emergency Systems
(B) Interchangeability	540.12 Work Space
530.22 Single-Pole Separable Connectors	540.13 Conductor Size
(A) General	540.14 Conductors on Lamps and Hot Equipment
(B) Interchangeability	540.15 Flexible Cords
530.23 Branch Circuits	540.20 Listing Requirements
<u>Part III. Dressing Rooms</u>	540.21 Marking
530.31 Dressing Rooms	<u>Part III. Nonprofessional Projectors</u>
<u>Part IV. Viewing, Cutting, and Patching Tables</u>	540.31 Motion Picture Projection Room Not Required
530.41 Lamps at Tables	540.32 Listing Requirements
<u>Part V. Cellulose Nitrate Film Storage Vaults</u>	<u>Part IV. Audio Signal Processing, Amplification, and Reproduction Equipment</u>
530.51 Lamps in Cellulose Nitrate Film Storage Vaults	540.50 Audio Signal Processing, Amplification, and Reproduction Equipment
530.52 Electrical Equipment in Cellulose Nitrate Film Storage Vaults	Article 545 Manufactured Buildings
Part VI. Substations	545.1 Scope
530.61 Substations	545.2 Definitions
530.62 Portable Substations	545.4 Wiring Methods
530.63 Overcurrent Protection of Direct-Current Generators	(A) Methods Permitted
530.64 Direct-Current Switchboards	(B) Securing Cables
(A) General	545.5 Supply Conductors
(B) Circuit Breaker Frames	545.6 Installation of Service-Entrance Conductors
Article 540 Motion Picture Projection Rooms	545.7 Service Equipment
<u>Part I. General</u>	545.8 Protection of Conductors and Equipment
540.1 Scope	545.9 Boxes
540.2 Definitions	(A) Other Dimensions
<u>Part II. Equipment and Projectors of the Professional Type</u>	(B) Not Over 1650 cm ³ (100 in. ³)
540.10 Motion Picture Projection Room Required	545.10 Receptacle or Switch with Integral Enclosure
540.11 Location of Associated Electrical Equipment	545.11 Bonding and Grounding
(A) Motor Generator Sets, Transformers,	545.12 Grounding Electrode Conductor

545.13 Component Interconnections	Planes
Article 547 Agricultural Buildings	(A) Where Required
547.1 Scope	(B) Bonding
(A) Excessive Dust and Dust with Water	Article 550 Mobile Homes, Manufactured Homes,
(B) Corrosive Atmosphere	and Mobile Home Parks
547.2 Definitions	<u>Part I. General</u>
547.3 Other Articles	550.1 Scope
547.4 Surface Temperatures	550.2 Definitions
547.5 Wiring Methods	550.4 General Requirements
(A) Wiring Systems	(A) Mobile Home Not Intended as a Dwelling Unit
(B) Mounting	(B) In Other Than Mobile Home Parks
(C) Equipment Enclosures, Boxes, Conduit	(C) Connection to Wiring System
Bodies, and Fittings	(D) Listed and Labeled
(D) Flexible Connections	<u>Part II. Mobile and Manufactured Homes</u>
(E) Physical Protection	550.10 Power Supply
(F) Separate Equipment Grounding Conductor	(A) Feeder
(G) Receptacles	(B) Power-Supply Cord
547.6 Switches, Receptacles, Circuit Breakers,	(C) Attachment Plug Cap
Controllers, and Fuses	(D) Overall Length of a Power-Supply Cord
547.7 Motors	(E) Marking
547.8 Luminaires	(F) Point of Entrance
(A) Minimize the Entrance of Dust	(G) Protected
(B) Exposed to Physical Damage	(H) Protection Against Corrosion and Mechanical
(C) Exposed to Water	Damage
547.9 Electrical Supply to Building(s) or Structure(s)	(I) Mast Weatherhead or Raceway
from a Distribution Point	550.11 Disconnecting Means and Branch-Circuit
(A) Site-Isolating Device	Protective Equipment
(B) Service Disconnecting Means and Overcurrent	(A) Disconnecting Means
Protection at the Building(s) or Structure(s)	(B) Branch-Circuit Protective Equipment
(C) Service Disconnecting Means and Overcurrent	(C) Two-Pole Circuit Breakers
Protection at the Distribution Point	(D) Electrical Nameplates
(D) Identification	550.12 Branch Circuits
547.10 Equipotential Planes and Bonding of Equipotential	(A) Lighting

2017 NEC TABLE OF CONTENTS

(B) Small Appliances	(C) Bonding of Non–Current-Carrying Metal Parts
(C) Laundry Area	550.17 Testing
(D) General Appliances	(A) Dielectric Strength Test
(E) Bathrooms	(B) Continuity and Operational Tests and Polarity Checks
550.13 Receptacle Outlets	550.18 Calculations
(A) Grounding-Type Receptacle Outlets	(A) Lighting, Small-Appliance, and Laundry Load
(B) Ground-Fault Circuit Interrupters (GFCI)	(B) Total Load for Determining Power Supply
(C) Cord-Connected Fixed Appliance	(C) Optional Method of Calculation for Lighting and Appliance Load
(D) Receptacle Outlets Required	550.19 Interconnection of Multiple-Section Mobile or Manufactured Home Units
(E) Pipe Heating Cable(s) Outlet	(A) Wiring Methods
(F) Receptacle Outlets Not Permitted	(B) Disconnecting Means
(G) Receptacle Outlets Not Required	550.20 Outdoor Outlets, Luminaires, Air-Cooling Equipment, and So Forth
550.14 Luminaires and Appliances	(A) Listed for Outdoor Use
(A) Fasten Appliances in Transit	(B) Outside Heating Equipment, Air-Conditioning Equipment, or Both
(B) Accessibility	550.25 Arc-Fault Circuit-Interrupter Protection
(C) Pendants	(A) Definition
(D) Bathtub and Shower Luminaires	(B) Mobile Homes and Manufactured Homes
550.15 Wiring Methods and Materials	<u>Part III. Services and Feeders</u>
(A) Nonmetallic Boxes	550.30 Distribution System
(B) Nonmetallic Cable Protection	550.31 Allowable Demand Factors
(C) Metal-Covered and Nonmetallic Cable Protection	550.32 Service Equipment
(D) Metal Faceplates	(A) Mobile Home Service Equipment
(E) Installation Requirements	(B) Manufactured Home Service Equipment
(F) Raceways	(C) Rating
(G) Switches	(D) Additional Outside Electrical Equipment
(H) Under-Chassis Wiring (Exposed to Weather)	(E) Additional Receptacles
(I) Boxes, Fittings, and Cabinets	(F) Mounting Height
(J) Appliance Terminal Connections	
(K) Component Interconnections	
550.16 Grounding	
(A) Grounded Conductor	
(B) Equipment Grounding Means	

(G) Marking	(C) Alternate Power Sources Exceeding 30 Amperes
550.33 Feeder	(D) Power-Supply Assembly Not Less Than
(A) Feeder Conductors	30 Amperes
(B) Feeder Capacity	551.32 Other Sources
Article 551 Recreational Vehicles and	551.33 Alternate Source Restrictions
Recreational Vehicle Parks	<u>Part IV. Nominal 120-Volt or 120/240-Volt Systems</u>
<u>Part I. General</u>	551.40 120-Volt or 120/240-Volt, Nominal, Systems
551.1 Scope	(A) General Requirements
551.2 Definitions	(B) Materials and Equipment
551.4 General Requirements	(C) Ground-Fault Circuit-Interrupter Protection
(A) Not Covered	551.41 Receptacle Outlets Required
(B) Systems	(A) Spacing
(C) Labels	(B) Location
<u>Part II. Combination Electrical Systems</u>	(C) Ground-Fault Circuit-Interrupter Protection
551.20 Combination Electrical Systems	(D) Face-Up Position
(A) General	551.42 Branch Circuits Required
(B) Voltage Converters (120-Volt Alternating Current to Low-Voltage Direct Current)	(A) One 15-Ampere Circuit
(C) Bonding Voltage Converter Enclosures	(B) One 20-Ampere Circuit
(D) Dual-Voltage Fixtures, Including Luminaires or Appliances	(C) Two to Five 15- or 20-Ampere Circuits
(E) Autotransformers	(D) More Than Five Circuits Without a Listed Energy Management System
(F) Receptacles and Plug Caps	551.43 Branch-Circuit Protection
<u>Part III. Other Power Sources</u>	(A) Rating
551.30 Generator Installations	(B) Protection for Smaller Conductors
(A) Mounting	(C) Fifteen-Ampere Receptacles Considered Protected by 20 Amperes
(B) Generator Protection	551.44 Power-Supply Assembly
(C) Installation of Storage Batteries and Generators	(A) Fifteen-Ampere Main Power-Supply Assembly
(D) Ventilation of Generator Compartments	(B) Twenty-Ampere Main Power-Supply Assembly
(E) Supply Conductors	(C) Thirty-Ampere Main Power-Supply Assembly
551.31 Multiple Supply Source	(D) Fifty-Ampere Power-Supply Assembly
(A) Multiple Supply Sources	551.45 Panelboard
(B) Multiple Supply Sources Capacity	(A) Listed and Appropriately Rated

2017 NEC TABLE OF CONTENTS

(B) Location	(B) Location
(C) Dead-Front Type	551.52 Receptacles
551.46 Means for Connecting to Power Supply	551.53 Luminaires and Other Equipment
(A) Assembly	(A) General
(B) Cord	(B) Shower Luminaires
(C) Attachment Plugs	(C) Outdoor Outlets, Luminaires, Air-Cooling Equipment, and So On
(D) Labeling at Electrical Entrance	551.54 Grounding
(E) Location	(A) Power-Supply Grounding
551.47 Wiring Methods	(B) Panelboard
(A) Wiring Systems	(C) Insulated Grounded Conductor (Neutral Conductor)
(B) Conduit and Tubing	551.55 Interior Equipment Grounding
(C) Nonmetallic Boxes	(A) Exposed Metal Parts
(D) Boxes	(B) Equipment Grounding and Bonding Conductors
(E) Mounting	(C) Grounding of Electrical Equipment
(F) Raceway and Cable Continuity	(D) Grounding Connection in Nonmetallic Box
(G) Protected	(E) Grounding Continuity
(H) Bends	(F) Cord-Connected Appliances
(I) Cable Supports	551.56 Bonding of Non-Current-Carrying Metal Parts
(J) Nonmetallic Box Without Cable Clamps	(A) Required Bonding
(K) Physical Damage	(B) Bonding Chassis
(L) Receptacle Faceplates	(C) Bonding Conductor Requirements
(M) Metal Faceplates Grounded	(D) Metallic Roof and Exterior Bonding
(N) Moisture or Physical Damage	(E) Gas, Water, and Waste Pipe Bonding
(O) Component Interconnections	(F) Furnace and Metal Air Duct Bonding
(P) Method of Connecting Expandable Units	551.57 Appliance Accessibility and Fastening
(Q) Prewiring for Air-Conditioning Installation	<u>Part V. Factory Tests</u>
(R) Prewiring for Generator Installation	551.60 Factory Tests (Electrical)
(S) Prewiring for Other Circuits	Part VI. Recreational Vehicle Parks
551.48 Conductors and Boxes	551.71 Type Receptacles Provided
551.49 Grounded Conductors	(A) 20-Ampere
551.50 Connection of Terminals and Splices	
551.51 Switches	
(A) Rating	

(B) 30-Ampere	(B) Meters
(C) 50-Ampere	551.79 Clearance for Overhead Conductors
(D) Tent Sites	551.80 Underground Service, Feeder, Branch-Circuit, and Recreational Vehicle Site Feeder-Circuit Conductors
(E) Additional Receptacles	(A) General
(F) GFCI Protection	(B) Protection Against Physical Damage
551.72 Distribution System	551.81 Receptacles
(A) Systems	Article 552 Park Trailers
(B) Three-Phase Systems	<u>Part I. General</u>
(C) Receptacles	552.1 Scope
(D) Neutral Conductors	552.2 Definition
551.73 Calculated Load	552.4 General Requirements
(A) Basis of Calculations	552.5 Labels
(B) Demand Factors	<u>Part II. Low-Voltage Systems</u>
551.74 Overcurrent Protection	552.10 Low-Voltage Systems
551.75 Grounding	(A) Low-Voltage Circuits
(A) General	(B) Low-Voltage Wiring
(B) Grounding Electrode	(C) Low-Voltage Wiring Methods
551.76 Grounding — Recreational Vehicle Site Supply Equipment	(D) Battery Installations
(A) Exposed Non-Current-Carrying Metal Parts	(E) Overcurrent Protection
(B) Secondary Distribution System	(F) Switches
(C) Grounded Conductor Not to Be Used as an Equipment Ground	(G) Luminaires
(D) No Connection on the Load Side	<u>Part III. Combination Electrical Systems</u>
551.77 Recreational Vehicle Site Supply Equipment	552.20 Combination Electrical Systems
(A) Location	(A) General
(B) Disconnecting Means	(B) Voltage Converters (120-Volt Alternating Current to Low-Voltage Direct Current)
(C) Access	(C) Bonding Voltage Converter Enclosures
(D) Mounting Height	(D) Dual-Voltage Fixtures Including Luminaires or Appliances
(E) Working Space	(E) Autotransformers
(F) Marking	(F) Receptacles and Plug Caps
551.78 Protection of Outdoor Equipment	
(A) Wet Locations	

2017 NEC TABLE OF CONTENTS

Part IV. Nominal 120-Volt or 120/240-Volt Systems

552.40 120-Volt or 120/240-Volt, Nominal, Systems

- (A) General Requirements
- (B) Materials and Equipment

552.41 Receptacle Outlets Required

- (A) Spacing
- (B) Location
- (C) Ground-Fault Circuit-Interrupter Protection
- (D) Pipe Heating Cable Outlet
- (E) Outdoor Receptacle Outlets
- (F) Receptacle Outlets Not Permitted

552.42 Branch-Circuit Protection

- (A) Rating
- (B) Protection for Smaller Conductors
- (C) Fifteen-Ampere Receptacle Considered

Protected by 20 Amperes

552.43 Power Supply

- (A) Feeder
- (B) Power-Supply Cord
- (C) Mast Weatherhead or Raceway

552.44 Cord

- (A) Permanently Connected
- (B) Cord Length
- (C) Attachment Plugs
- (D) Labeling at Electrical Entrance
- (E) Location

552.45 Panelboard

- (A) Listed and Appropriately Rated
- (B) Location
- (C) Dead-Front Type

552.46 Branch Circuits

- (A) Two to Five 15- or 20-Ampere Circuits
- (B) More Than Five Circuits

552.47 Calculations

- (A) Lighting and Small-Appliance Load
- (B) Total Load for Determining Power Supply
- (C) Optional Method of Calculation for Lighting and Appliance Load

552.48 Wiring Methods

- (A) Wiring Systems
- (B) Conduit and Tubing
- (C) Nonmetallic Boxes
- (D) Boxes
- (E) Mounting
- (F) Cable Sheath
- (G) Protected
- (H) Cable Supports
- (I) Nonmetallic Box Without Cable Clamps
- (J) Physical Damage
- (K) Receptacle Faceplates
- (L) Metal Faceplates Grounded
- (M) Moisture or Physical Damage
- (N) Component Interconnections
- (O) Method of Connecting Expandable Units
- (P) Prewiring for Air-Conditioning Installation
- (Q) Prewiring for Other Circuits

552.49 Maximum Number of Conductors in Boxes

552.50 Grounded Conductors

552.51 Connection of Terminals and Splices

552.52 Switches

- (A) Lighting Circuits
- (B) Motors or Other Loads
- (C) Location

552.53 Receptacles

552.54 Luminaires

- (A) General

(B) Shower Luminaires	553.1 Scope
(C) Outdoor Outlets, Luminaires, Air-Cooling Equipment, and So On	553.2 Definition
552.55 Grounding	<u>Part II. Services and Feeders</u>
(A) Power-Supply Grounding	553.4 Location of Service Equipment
(B) Panelboard	553.5 Service Conductors
(C) Insulated Grounded Conductor	553.6 Feeder Conductors
552.56 Interior Equipment Grounding	553.7 Installation of Services and Feeders
(A) Exposed Metal Parts	(A) Flexibility
(B) Equipment Grounding Conductors	(B) Wiring Methods
(C) Grounding of Electrical Equipment	<u>Part III. Grounding</u>
(D) Grounding Connection in Nonmetallic Box	553.8 General Requirements
(E) Grounding Continuity	(A) Grounding of Electrical and Nonelectrical Parts
(F) Cord-Connected Appliances	(B) Installation and Connection of Equipment Grounding Conductor
552.57 Bonding of Non-Current-Carrying Metal Parts	(C) Identification of Equipment Grounding Conductor
(A) Required Bonding	(D) Grounding Electrode Conductor Connection
(B) Bonding Chassis	553.9 Insulated Neutral
(C) Bonding Conductor Requirements	553.10 Equipment Grounding
(D) Metallic Roof and Exterior Bonding	(A) Electrical Systems
(E) Gas, Water, and Waste Pipe Bonding	(B) Cord-Connected Appliances
(F) Furnace and Metal Air Duct Bonding	553.11 Bonding of Non-Current-Carrying Metal Parts
552.58 Appliance Accessibility and Fastening	Article 555 Marinas, Boatyards, and Commercial and Noncommercial Docking Facilities
552.59 Outdoor Outlets, Fixtures, Including Luminaires, Air-Cooling Equipment, and So On	555.1 Scope
(A) Listed for Outdoor Use	555.2 Definitions
(B) Outside Heating Equipment, Air-Conditioning Equipment, or Both	555.3 Ground-Fault Protection
<u>Part V. Factory Tests</u>	555.4 Distribution System
552.60 Factory Tests (Electrical)	555.5 Transformers
(A) Circuits of 120 Volts or 120/240 Volts	555.7 Location of Service Equipment
(B) Low-Voltage Circuits	555.9 Electrical Connections
Article 553 Floating Buildings	555.10 Electrical Equipment Enclosures
<u>Part I. General</u>	(A) Securing and Supporting
	(B) Location

555.11 Circuit Breakers, Switches, Panelboards, and Marine Power Outlets	(B) 90 Days
555.12 Load Calculations for Service and Feeder Conductors	(C) Emergencies and Tests
555.13 Wiring Methods and Installation	(D) Removal
(A) Wiring Methods	590.4 General
(B) Installation	(A) Services
555.15 Grounding	(B) Feeders
(A) Equipment to Be Grounded	(C) Branch Circuits
(B) Type of Equipment Grounding Conductor	(D) Receptacles
(C) Size of Equipment Grounding Conductor	(E) Disconnecting Means
(D) Branch-Circuit Equipment Grounding Conductor	(F) Lamp Protection
(E) Feeder Equipment Grounding Conductors	(G) Splices
555.17 Disconnecting Means for Shore Power Connection(s)	(H) Protection from Accidental Damage
(A) Type	(I) Termination(s) at Devices
(B) Location	(J) Support
555.19 Receptacles	590.5 Listing of Decorative Lighting
(A) Shore Power Receptacles	590.6 Ground-Fault Protection for Personnel
(B) Other Than Shore Power	(A) Receptacle Outlets
555.21 Motor Fuel Dispensing Stations — Hazardous (Classified) Locations	(B) Use of Other Outlets
555.22 Repair Facilities — Hazardous (Classified) Locations	590.7 Guarding
555.23 Marine Hoists, Railways, Cranes, and Monorails	Article 600 Electric Signs and Outline Lighting
555.24 Signage	<u>Part I. General</u>
Article 590 Temporary Installations	600.1 Scope
590.1 Scope	600.2 Definitions
590.2 All Wiring Installations	600.3 Listing
(A) Other Articles	(A) Field-Installed Skeleton Tubing
(B) Approval	(B) Outline Lighting
590.3 Time Constraints	600.4 Markings
(A) During the Period of Construction	(A) Signs and Outline Lighting Systems
	(B) Signs with a Retrofitted Illumination System
	(C) Signs with Lampholders for Incandescent Lamps
	(D) Visibility
	(E) Durability
	(F) Installation Instructions

2017 NEC TABLE OF CONTENTS

600.5 Branch Circuits	(C) Wet Location
(A) Required Branch Circuit	(D) Working Space
(B) Rating	(E) Attic and Soffit Locations
(C) Wiring Methods	(F) Suspended Ceilings
600.6 Disconnects	600.22 Ballasts
(A) Location	(A) Type
(B) Control Switch Rating	(B) Thermal Protection
600.7 Grounding and Bonding	600.23 Transformers and Electronic Power Supplies
(A) Grounding	(A) Type
(B) Bonding	(B) Secondary-Circuit Ground-Fault Protection
600.8 Enclosures	(C) Voltage
(A) Strength	(D) Rating
(B) Material	(E) Secondary Connections
(C) Minimum Thickness of Enclosure Metal	(F) Marking
(D) Protection of Metal	600.24 Class 2 Power Sources
600.9 Location	(A) Listing
(A) Vehicles	(B) Grounding
(B) Pedestrians	(C) Wiring Methods on the Supply Side of the Class 2 Power Supply
(C) Adjacent to Combustible Materials	(D) Secondary Wiring
(D) Wet Location	<u>Part II. Field-Installed Skeleton Tubing, Outline Lighting, and Secondary Wiring</u>
600.10 Portable or Mobile Signs	600.30 Applicability
(A) Support	600.31 Neon Secondary-Circuit Wiring, 1000 Volts or Less, Nominal
(B) Attachment Plug	(A) Wiring Method
(C) Wet or Damp Location	(B) Insulation and Size
(D) Dry Location	(C) Number of Conductors in Raceway
600.12 Field-Installed Secondary Wiring	(D) Installation
(A) 1000 Volts or Less	(E) Protection of Leads
(B) Over 1000 Volts	600.32 Neon Secondary-Circuit Wiring, over 1000 Volts, Nominal
(C) Class 2	
600.21 Ballasts, Transformers, Electronic Power Supplies, and Class 2 Power Sources	
(A) Accessibility	
(B) Location	

2017 NEC TABLE OF CONTENTS

(A) Wiring Methods	(D) Support
(B) Insulation and Size	(E) Receptacles
(C) Installation	(F) Bushings
(D) Bends in Conductors	(G) Wet Locations
(E) Spacing	(H) Electrode Enclosures
(F) Insulators and Bushings	Article 604 Manufactured Wiring Systems
(G) Conductors in Raceways	604.1 Scope
(H) Between Neon Tubing and Midpoint Return	604.2 Definition
(I) Dwelling Occupancies	604.6 Listing Requirements
(J) Length of Secondary Circuit Conductors	604.7 Installation
(K) Splices	604.10 Uses Permitted
600.33 Class 2 Sign Illumination Systems, Secondary Wiring	604.12 Uses Not Permitted
(A) Insulation and Sizing of Class 2 Conductors	604.100 Construction
(B) Installation	(A) Cable or Conduit Types
(C) Protection Against Physical Damage	(B) Marking
(D) Grounding and Bonding	(C) Receptacles and Connectors
600.34 Photovoltaic (PV) Powered Sign	(D) Other Component Parts
(A) Equipment	Article 605 Office Furnishings
(B) Wiring	605.1 Scope
(C) Flexible Cords and Cables	605.2 Definition
(D) Grounding	605.3 General
(E) Disconnecting Means	(A) Use
(F) Battery Compartments	(B) Hazardous (Classified) Locations
600.41 Neon Tubing	605.4 Wireways
(A) Design	605.5 Office Furnishing Interconnections
(B) Support	605.6 Lighting Accessories
(C) Spacing	(A) Support
(D) Protection	(B) Connection
600.42 Electrode Connections	(C) Receptacle Outlet
(A) Points of Transition	605.7 Fixed-Type Office Furnishings
(B) Accessibility	605.8 Freestanding-Type Office Furnishings
(C) Electrode Connections	605.9 Freestanding-Type Office Furnishings, Cordand Plug-Connected

(A) Flexible Power-Supply Cord

(B) Receptacle Supplying Power

(C) Receptacle, Maximum

(D) Multiwire Circuits, Not Permitted

Article 610 Cranes and Hoists

Part I. General

610.1 Scope

610.2 Definition

610.3 Special Requirements for Particular Locations

(A) Hazardous (Classified) Locations

(B) Combustible Materials

(C) Electrolytic Cell Lines

Part II. Wiring

610.11 Wiring Method

(A) Contact Conductor

(B) Exposed Conductors

(C) Flexible Connections to Motors and Similar Equipment

(D) Pushbutton Station Multiconductor Cable

(E) Flexibility to Moving Parts

610.12 Raceway or Cable Terminal Fittings

(A) Separately Bushed Hole

(B) Bushing in Lieu of a Box

610.13 Types of Conductors

(A) Exposed to External Heat or Connected to Resistors

(B) Contact Conductors

(C) Flexibility

(D) Class 1, Class 2, and Class 3 Circuits

610.14 Rating and Size of Conductors

(A) Ampacity

(B) Secondary Resistor Conductors

(C) Minimum Size

(D) Contact Conductors

(E) Calculation of Motor Load

(F) Other Loads

(G) Nameplate

610.15 Common Return

Part III. Contact Conductors

610.21 Installation of Contact Conductors

(A) Locating or Guarding Contact Conductors

(B) Contact Wires

(C) Supports Along Runways

(D) Supports on Bridges

(E) Supports for Rigid Conductors

(F) Track as Circuit Conductor

(G) Electrical Continuity of Contact Conductors

(H) Not to Supply Other Equipment

610.22 Collectors

Part IV. Disconnecting Means

610.31 Runway Conductor Disconnecting Means

610.32 Disconnecting Means for Cranes and Monorail Hoists

610.33 Rating of Disconnecting Means

Part V. Overcurrent Protection

610.41 Feeders, Runway Conductors

(A) Single Feeder

(B) More Than One Feeder Circuit

610.42 Branch-Circuit Short-Circuit and Ground-Fault Protection

(A) Fuse or Circuit Breaker Rating

(B) Taps

610.43 Overload Protection

(A) Motor and Branch-Circuit Overload Protection

(B) Manually Controlled Motor

(C) Multimotor	620.12 Minimum Size of Conductors
(D) Hoists and Monorail Hoists	(A) Traveling Cables
<u>Part VI. Control</u>	(B) Other Wiring
610.51 Separate Controllers	620.13 Feeder and Branch-Circuit Conductors
(A) Motions with More Than One Motor	(A) Conductors Supplying Single Motor
(B) Multiple Motion Controller	(B) Conductors Supplying a Single Motor Controller
610.53 Overcurrent Protection	(C) Conductors Supplying a Single Power Transformer
(A) Taps to Control Transformers	(D) Conductors Supplying More Than One Motor, Motor Controller, or Power Transformer
(B) Continuity of Power	
610.57 Clearance	620.14 Feeder Demand Factor
<u>Part VII. Grounding</u>	620.15 Motor Controller Rating
610.61 Grounding	620.16 Short-Circuit Current Rating
Article 620 Elevators, Dumbwaiters, Escalators, Moving Walks, Platform Lifts, and Stairway Chairlifts	(A) Marking
<u>Part I. General</u>	(B) Installation
620.1 Scope	<u>Part III. Wiring</u>
620.2 Definitions	620.21 Wiring Methods
620.3 Voltage Limitations	(A) Elevators
(A) Power Circuits	(B) Escalators
(B) Lighting Circuits	(C) Platform Lifts and Stairway Chairlift Raceways
(C) Heating and Air-Conditioning Circuits	620.22 Branch Circuits for Car Lighting, Receptacle(s), Ventilation, Heating, and Air-Conditioning
620.4 Live Parts Enclosed	(A) Car Light Source
620.5 Working Clearances	(B) Air-Conditioning and Heating Source
(A) Flexible Connections to Equipment	620.23 Branch Circuits for Machine Room or Control Room/Machinery Space or Control Space Lighting and Receptacle(s)
(B) Guards	(A) Separate Branch Circuits
(C) Examination, Adjusting, and Servicing	(B) Lighting Switch
(D) Low Voltage	(C) Duplex Receptacle
<u>Part II. Conductors</u>	620.24 Branch Circuit for Hoistway Pit Lighting
620.11 Insulation of Conductors	
(A) Hoistway Door Interlock Wiring	
(B) Traveling Cables	
(C) Other Wiring	
(D) Insulation	

and Receptacles	(E) Surge Protection
(A) Separate Branch Circuits	620.52 Power from More Than One Source
(B) Lighting Switch	(A) Single-Car and Multicar Installations
(C) Duplex Receptacle	(B) Warning Sign for Multiple Disconnecting Means
620.25 Branch Circuits for Other Utilization Equipment	(C) Interconnection Multicar Controllers
(A) Additional Branch Circuits	620.53 Car Light, Receptacle(s), and Ventilation
(B) Overcurrent Devices	Disconnecting Means
<u>Part IV. Installation of Conductors</u>	620.54 Heating and Air-Conditioning Disconnecting
620.32 Metal Wireways and Nonmetallic Wireways	Means
620.33 Number of Conductors in Raceways	620.55 Utilization Equipment Disconnecting Means
620.34 Supports	<u>Part VII. Overcurrent Protection</u>
620.35 Auxiliary Gutters	620.61 Overcurrent Protection
620.36 Different Systems in One Raceway or Traveling	(A) Operating Devices and Control and Signaling Circuits
Cable	(B) Overload Protection for Motors
620.37 Wiring in Hoistways, Machine Rooms,	(C) Motor Feeder Short-Circuit and Ground-Fault
Control Rooms, Machinery Spaces,	Protection
and Control Spaces	(D) Motor Branch-Circuit Short-Circuit
(A) Uses Permitted	and Ground-Fault Protection
(B) Lightning Protection	620.62 Selective Coordination
(C) Main Feeders	<u>Part VIII. Machine Rooms, Control Rooms,</u>
620.38 Electrical Equipment in Garages and Similar	<u>Machinery Spaces, and Control Spaces</u>
Occupancies	620.71 Guarding Equipment
<u>Part V. Traveling Cables</u>	(A) Motor Controllers
620.41 Suspension of Traveling Cables	(B) Driving Machines
620.42 Hazardous (Classified) Locations	<u>Part IX. Grounding</u>
620.43 Location of and Protection for Cables	620.81 Metal Raceways Attached to Cars
620.44 Installation of Traveling Cables	620.82 Electric Elevators
<u>Part VI. Disconnecting Means and Control</u>	620.83 Nonelectric Elevators
620.51 Disconnecting Means	620.84 Escalators, Moving Walks, Platform Lifts,
(A) Type	and Stairway Chairlifts
(B) Operation	620.85 Ground-Fault Circuit-Interrupter Protection
(C) Location	for Personnel
(D) Identification and Signs	<u>Part X. Emergency and Standby Power Systems</u>

620.91 Emergency and Standby Power Systems

(A) Regenerative Power

(B) Other Building Loads

(C) Disconnecting Means

Article 625 Electric Vehicle Charging System

Part I. General

625.1 Scope

625.2 Definitions

625.4 Voltages

625.5 Listed

Part II. Equipment Construction

625.10 Electric Vehicle Coupler

(A) Construction and Installation

(B) Unintentional Disconnection

(C) Grounding Pole

(D) Grounding Pole Requirements

625.15 Markings

(A) General

(B) Ventilation Not Required

(C) Ventilation Required

625.16 Means of Coupling

625.17 Cords and Cables

(A) Power-Supply Cord

(B) Output Cable

(C) Overall Cord and Cable Length

625.18 Interlock

625.19 Automatic De-Energization of Cable

625.22 Personnel Protection System

Part III. Installation

625.40 Electric Vehicle Branch Circuit

625.41 Overcurrent Protection

625.42 Rating

625.43 Disconnecting Means

625.44 Equipment Connection

(A) Portable Equipment

(B) Stationary Equipment

(C) Fixed Equipment

625.46 Loss of Primary Source

625.47 Multiple Feeder or Branch Circuits

625.48 Interactive Systems

625.50 Location

625.52 Ventilation

(A) Ventilation Not Required

(B) Ventilation Required

Part IV. Wireless Power Transfer Equipment

625.101 Grounding

625.102 Construction

(A) Type

(B) Installation

(C) Primary Pad

(D) Protection of the Output Cable

(E) Other Wiring Systems

Article 626 Electrified Truck Parking Spaces

Part I. General

626.1 Scope

626.2 Definitions

626.3 Other Articles

(A) Vehicle Repair and Storage Facilities

(B) Motor Fuel Dispensing Stations

626.4 General Requirements

(A) Not Covered

(B) Distribution System Voltages

(C) Connection to Wiring System

Part II. Electrified Truck Parking Space Electrical

Wiring Systems

626.10 Branch Circuits

626.11 Feeder and Service Load Calculations
 (A) Parking Space Load
 (B) Demand Factors
 (C) Two or More Electrified Truck Parking Spaces
 (D) Conductor Rating
Part III. Electrified Truck Parking Space Supply Equipment
 626.22 Wiring Methods and Materials
 (A) Electrified Truck Parking Space Supply Equipment Type
 (B) Mounting Height
 (C) Access to Working Space
 (D) Disconnecting Means
 626.23 Overhead Gantry or Cable Management System
 (A) Cable Management
 (B) Strain Relief
 626.24 Electrified Truck Parking Space Supply Equipment
 Connection Means
 (A) General
 (B) Receptacle
 (C) Disconnecting Means, Parking Space
 (D) Ground-Fault Circuit-Interrupter Protection for Personnel
 626.25 Separable Power-Supply Cable Assembly
 (A) Rating(s)
 (B) Power-Supply Cord
 626.26 Loss of Primary Power
 626.27 Interactive Systems
Part IV. Transport Refrigerated Units (TRUs)
 626.30 Transport Refrigerated Units
 (A) Branch Circuits
 (B) Electrified Truck Parking Space Supply Equipment
 626.31 Disconnecting Means and Receptacles
 (A) Disconnecting Means

(B) Location
 (C) Receptacles
 626.32 Separable Power Supply Cable Assembly
 (A) Rating(s)
 (B) Cord Assemblies
 (C) Attachment Plug(s) and Cord Connector(s)

Article 630 Electric Welders

Part I. General

630.1 Scope

630.6 Listing

Part II. Arc Welders

630.11 Ampacity of Supply Conductors

(A) Individual Welders

(B) Group of Welders

630.12 Overcurrent Protection

(A) For Welders

(B) For Conductors

630.13 Disconnecting Means

630.14 Marking

630.15 Grounding of Welder Secondary Circuit

Part III. Resistance Welders

630.31 Ampacity of Supply Conductors

(A) Individual Welders

(B) Groups of Welders

630.32 Overcurrent Protection

(A) For Welders

(B) For Conductors

630.33 Disconnecting Means

630.34 Marking

Part IV. Welding Cable

630.41 Conductors

630.42 Installation

(A) Cable Support

(B) Spread of Fire and Products of Combustion

(C) Signs

Article 640 Audio Signal Processing, Amplification, and Reproduction Equipment

Part I. General

640.1 Scope

(A) Covered

(B) Not Covered

640.2 Definitions

640.3 Locations and Other Articles

(A) Spread of Fire or Products of Combustion

(B) Ducts, Plenums, and Other Air-Handling Spaces

(C) Cable Trays

(D) Hazardous (Classified) Locations

(E) Assembly Occupancies

(F) Theaters, Audience Areas of Motion Picture and Television Studios, and Similar Locations

(G) Carnivals, Circuses, Fairs, and Similar Events

(H) Motion Picture and Television Studios

(I) Swimming Pools, Fountains, and Similar Locations

(J) Combination Systems

(K) Antennas

(L) Generators

(M) Organ Pipes

640.4 Protection of Electrical Equipment

640.5 Access to Electrical Equipment Behind Panels Designed to Allow Access

640.6 Mechanical Execution of Work

(A) Installation of Audio Distribution Cables

(B) Abandoned Audio Distribution Cables

(C) Installed Audio Distribution Cable Identified

for Future Use

640.7 Grounding

(A) General

(B) Separately Derived Systems with 60 Volts to Ground

(C) Isolated Ground Receptacles

640.8 Grouping of Conductors

640.9 Wiring Methods

(A) Wiring to and Between Audio Equipment

(B) Auxiliary Power Supply Wiring

(C) Output Wiring and Listing of Amplifiers

(D) Use of Audio Transformers and Autotransformers

640.10 Audio Systems Near Bodies of Water

(A) Equipment Supplied by Branch-Circuit Power

(B) Equipment Not Supplied by Branch-Circuit Power

Part II. Permanent Audio System Installations

640.21 Use of Flexible Cords and Cables

(A) Between Equipment and Branch-Circuit Power

(B) Between Loudspeakers and Amplifiers or Between Loudspeakers

(C) Between Equipment

(D) Between Equipment and Power Supplies Other Than Branch-Circuit Power

(E) Between Equipment Racks and Premises Wiring System

640.22 Wiring of Equipment Racks and Enclosures

640.23 Conduit or Tubing

(A) Number of Conductors

(B) Nonmetallic Conduit or Tubing and Insulating Bushings

2017 NEC TABLE OF CONTENTS

640.24 Wireways, Gutters, and Auxiliary Gutters	(I) Cables Not in Information Technology Equipment Room
640.25 Loudspeaker Installation in Fire Resistance–Rated Partitions, Walls, and Ceilings	645.4 Special Requirements for Information Technology Equipment Room
<u>Part III. Portable and Temporary Audio System Installations</u>	645.5 Supply Circuits and Interconnecting Cables
640.41 Multipole Branch-Circuit Cable Connectors	(A) Branch-Circuit Conductors
640.42 Use of Flexible Cords and Cables	(B) Power-Supply Cords
(A) Between Equipment and Branch-Circuit Power	(C) Interconnecting Cables
(B) Between Loudspeakers and Amplifiers, or Between Loudspeakers	(D) Physical Protection
(C) Between Equipment and/or Between Equipment Racks	(E) Under Raised Floors
(D) Between Equipment, Equipment Racks, and Power Supplies Other Than Branch Circuit Power	(F) Securing in Place
(E) Between Equipment Racks and Branch-Circuit Power	(G) Abandoned Supply Circuits and Interconnecting Cables
640.43 Wiring of Equipment Racks	(H) Installed Supply Circuits and Interconnecting Cables Identified for Future Use
640.44 Environmental Protection of Equipment	645.10 Disconnecting Means
640.45 Protection of Wiring	(A) Remote Disconnect Controls
640.46 Equipment Access	(B) Critical Operations Data Systems
Article 645 Information Technology Equipment	645.11 Uninterruptible Power Supplies (UPSs)
645.1 Scope	645.14 System Grounding
645.2 Definitions	645.15 Equipment Grounding and Bonding
645.3 Other Articles	645.16 Marking
(A) Spread of Fire or Products of Combustion	645.17 Power Distribution Units
(B) Wiring and Cabling in Other Spaces Used for Environmental Air (Plenums)	645.18 Surge Protection for Critical Operations Data Systems
(C) Bonding and Grounding	645.25 Engineering Supervision
(D) Electrical Classification of Data Circuits	645.27 Selective Coordination
(E) Fire Alarm Cables and Equipment	Article 646 Modular Data Centers
(F) Cable Routing Assemblies, Communications Wires, Cables, Raceways, and Equipment	<u>Part I. General</u>
(G) Community Antenna Television and Radio Distribution Systems Cables and Equipment	646.1 Scope
(H) Optical Fiber Cables	646.2 Definitions
	646.3 Other Articles
	(A) Spread of Fire or Products of Combustion

(B) Wiring and Cabling in Other Spaces Used for Environmental Air (Plenums)	(B) Uses Not Permitted
(C) Grounding	(C) Listing
(D) Electrical Classification of Data Circuits	(D) Single-Conductor Cable
(E) Fire Alarm Equipment	<u>Part II. Equipment</u>
(F) Cable Routing Assemblies and Communications Wires, Cables, Raceways, and Equipment	646.10 Electrical Supply and Distribution
(G) Community Antenna Television and Radio Distribution Systems Cables and Equipment	646.11 Distribution Transformers
(H) Storage Batteries	(A) Utility-Owned Transformers
(I) Surge-Protective Devices (SPDs)	(B) Non-Utility-Owned Premises Transformers
(J) Lighting	(C) Power Transformers
(K) Power Distribution Wiring and Wiring Protection	646.12 Receptacles
(L) Wiring Methods and Materials	646.13 Other Electrical Equipment
(M) Service Equipment	646.14 Installation and Use
(N) Disconnecting Means	<u>Part III. Lighting</u>
646.4 Applicable Requirements	646.15 General Illumination
646.5 Nameplate Data	646.16 Emergency Lighting
646.6 Supply Conductors and Overcurrent Protection	646.17 Emergency Lighting Circuits
(A) Size	<u>Part IV. Workspace</u>
(B) Overcurrent Protection	646.18 General
646.7 Short-Circuit Current Rating	646.19 Entrance to and Egress from Working Space
(A) Service Equipment	(A) Unobstructed Egress
(B) MDCs Connected to Branch Circuits and Feeders	(B) Extra Working Space
(C) MDCs Powered from Separate MDC System Enclosures	646.20 Working Space for ITE
646.8 Field-Wiring Compartments	(A) Low-Voltage Circuits
646.9 Flexible Power Cords and Cables for Connecting Equipment Enclosures of an MDC System	(B) Other Circuits
(A) Uses Permitted	646.21 Work Areas and Working Space About Batteries
	646.22 Workspace for Routine Service and Maintenance
	Article 647 Sensitive Electronic Equipment
	647.1 Scope
	647.3 General
	647.4 Wiring Methods
	(A) Panelboards and Overcurrent Protection
	(B) Junction Boxes

2017 NEC TABLE OF CONTENTS

(C) Conductor Identification	660.2 Definitions
(D) Voltage Drop	660.3 Hazardous (Classified) Locations
647.5 Three-Phase Systems	660.4 Connection to Supply Circuit
647.6 Grounding	(A) Fixed and Stationary Equipment
(A) General	(B) Portable, Mobile, and Transportable Equipment
(B) Grounding Conductors Required	(C) Over 1000 Volts, Nominal
647.7 Receptacles	660.5 Disconnecting Means
(A) General	660.6 Rating of Supply Conductors and Overcurrent Protection
(B) Isolated Ground Receptacles	(A) Branch-Circuit Conductors
647.8 Lighting Equipment	(B) Feeder Conductors
(A) Disconnecting Means	660.7 Wiring Terminals
(B) Luminaires	660.9 Minimum Size of Conductors
(C) Screw Shell	660.10 Equipment Installations
Article 650 Pipe Organs	<u>Part II. Control</u>
650.1 Scope	660.20 Fixed and Stationary Equipment
650.2 Definitions	(A) Separate Control Device
650.3 Other Articles	(B) Protective Device
(A) Electronic Organ Equipment	660.21 Portable and Mobile Equipment
(B) Optical Fiber Cable	660.23 Industrial and Commercial Laboratory Equipment
650.4 Source of Energy	(A) Radiographic and Fluoroscopic Types
650.5 Grounding or Double Insulation of the DC Power Supply	(B) Diffraction and Irradiation Types
650.6 Conductors	660.24 Independent Control
(A) Size	<u>Part III. Transformers and Capacitors</u>
(B) Insulation	660.35 General
(C) Conductors to Be Cabled	660.36 Capacitors
(D) Cable Covering	<u>Part IV. Guarding and Grounding</u>
650.7 Installation of Conductors	660.47 General
650.8 Overcurrent Protection	(A) High-Voltage Parts
650.9 Protection from Accidental Contact	(B) Low-Voltage Cables
Article 660 X-Ray Equipment	660.48 Grounding
<u>Part I. General</u>	Article 665 Induction and Dielectric Heating
660.1 Scope	

EquipmentPart I. General

665.1 Scope

665.2 Definitions

665.4 Hazardous (Classified) Locations

665.5 Output Circuit

665.7 Remote Control

(A) Multiple Control Points

(B) Foot Switches

665.10 Ampacity of Supply Conductors

(A) Nameplate Rating

(B) Motor-Generator Equipment

665.11 Overcurrent Protection

665.12 Disconnecting Means

Part II. Guarding, Grounding, and Labeling

665.19 Component Interconnection

665.20 Enclosures

665.21 Control Panels

665.22 Access to Internal Equipment

665.23 Warning Labels or Signs

665.24 Capacitors

665.25 Dielectric Heating Applicator Shielding

665.26 Grounding and Bonding

665.27 Marking

Article 668 Electrolytic Cells

668.1 Scope

668.2 Definitions

668.3 Other Articles

(A) Lighting, Ventilating, Material Handling

(B) Systems Not Electrically Connected

(C) Electrolytic Cell Lines

668.10 Cell Line Working Zone

(A) Area Covered

(B) Area Not Covered

668.11 Direct-Current Cell Line Process Power Supply

(A) Not Grounded

(B) Metal Enclosures Grounded

(C) Grounding Requirements

668.12 Cell Line Conductors

(A) Insulation and Material

(B) Size

(C) Connections

668.13 Disconnecting Means

(A) More Than One Process Power Supply

(B) Removable Links or Conductors

668.14 Shunting Means

(A) Partial or Total Shunting

(B) Shunting One or More Cells

668.15 Grounding

668.20 Portable Electrical Equipment

(A) Portable Electrical Equipment Not
to Be Grounded

(B) Isolating Transformers

(C) Marking

668.21 Power-Supply Circuits and Receptacles for Portable
Electrical Equipment

(A) Isolated Circuits

(B) Noninterchangeability

(C) Marking

668.30 Fixed and Portable Electrical Equipment

(A) Electrical Equipment Not Required
to Be Grounded(B) Exposed Conductive Surfaces Not Required
to Be Grounded

(C) Wiring Methods

(D) Circuit Protection

(E) Bonding	Article 675 Electrically Driven or Controlled
668.31 Auxiliary Nonelectrical Connections	Irrigation Machines
668.32 Cranes and Hoists	<u>Part I. General</u>
(A) Conductive Surfaces to Be Insulated from Ground	675.1 Scope
(B) Hazardous Electrical Conditions	675.2 Definitions
668.40 Enclosures	675.4 Irrigation Cable
Article 669 Electroplating	(A) Construction
669.1 Scope	(B) Alternate Wiring Methods
669.3 General	(C) Supports
669.5 Branch-Circuit Conductors	(D) Fittings
669.6 Wiring Methods	675.5 More Than Three Conductors in a Raceway or Cable
(A) Systems Not Exceeding 60 Volts Direct Current	675.6 Marking on Main Control Panel
(B) Systems Exceeding 60 Volts Direct Current	675.7 Equivalent Current Ratings
669.7 Warning Signs	(A) Continuous-Current Rating
669.8 Disconnecting Means	(B) Locked-Rotor Current
(A) More Than One Power Supply	675.8 Disconnecting Means
(B) Removable Links or Conductors	(A) Main Controller
669.9 Overcurrent Protection	(B) Main Disconnecting Means
Article 670 Industrial Machinery	(C) Disconnecting Means for Individual Motors and Controllers
670.1 Scope	675.9 Branch-Circuit Conductors
670.2 Definition	675.10 Several Motors on One Branch Circuit
670.3 Machine Nameplate Data	(A) Protection Required
(A) Permanent Nameplate	(B) Individual Protection Not Required
(B) Overcurrent Protection	675.11 Collector Rings
670.4 Supply Conductors and Overcurrent Protection	(A) Transmitting Current for Power Purposes
(A) Size	(B) Control and Signal Purposes
(B) Disconnecting Means	(C) Grounding
(C) Overcurrent Protection	(D) Protection
670.5 Short-Circuit Current Rating	675.12 Grounding
670.6 Surge Protection	675.13 Methods of Grounding
	675.14 Bonding
	675.15 Lightning Protection

2017 NEC TABLE OF CONTENTS

<p>675.16 Energy from More Than One Source</p> <p>675.17 Connectors</p> <p><u>Part II. Center Pivot Irrigation Machines</u></p> <p>675.21 General</p> <p>675.22 Equivalent Current Ratings</p> <p>(A) Continuous-Current Rating</p> <p>(B) Locked-Rotor Current</p> <p>Article 680 Swimming Pools, Fountains, and Similar Installations</p> <p><u>Part I. General</u></p> <p>680.1 Scope</p> <p>680.2 Definitions</p> <p>680.4 Approval of Equipment</p> <p>680.5 Ground-Fault Circuit Interrupters</p> <p>680.6 Grounding</p> <p>680.7 Grounding and Bonding Terminals</p> <p>680.8 Cord-and-Plug-Connected Equipment</p> <p>(A) Length</p> <p>(B) Equipment Grounding</p> <p>(C) Construction</p> <p>680.9 Overhead Conductor Clearances</p> <p>(A) Power</p> <p>(B) Communications Systems</p> <p>(C) Network-Powered Broadband Communications Systems</p> <p>680.10 Electric Pool Water Heaters</p> <p>680.11 Underground Wiring Location</p> <p>680.12 Equipment Rooms and Pits</p> <p>680.13 Maintenance Disconnecting Means</p> <p>680.14 Corrosive Environment</p> <p>(A) General</p> <p>(B) Wiring Methods</p> <p><u>Part II. Permanently Installed Pools</u></p>	<p>680.20 General</p> <p>680.21 Motors</p> <p>(A) Wiring Methods</p> <p>(B) Double Insulated Pool Pumps</p> <p>(C) GFCI Protection</p> <p>680.22 Lighting, Receptacles, and Equipment</p> <p>(A) Receptacles</p> <p>(B) Luminaires, Lighting Outlets, and CeilingSuspended (Paddle) Fans</p> <p>(C) Switching Devices</p> <p>(D) Other Outlets</p> <p>680.23 Underwater Luminaires</p> <p>(A) General</p> <p>(B) Wet-Niche Luminaires</p> <p>(C) Dry-Niche Luminaires</p> <p>(D) No-Niche Luminaires</p> <p>(E) Through-Wall Lighting Assembly</p> <p>(F) Branch-Circuit Wiring</p> <p>680.24 Junction Boxes and Electrical Enclosures for Transformers or Ground-Fault Circuit Interrupters</p> <p>(A) Junction Boxes</p> <p>(B) Other Enclosures</p> <p>(C) Protection</p> <p>(D) Grounding Terminals</p> <p>(E) Strain Relief</p> <p>(F) Grounding</p> <p>680.25 Feeders</p> <p>(A) Feeders</p> <p>(B) Aluminum Conduit</p> <p>680.26 Equipotential Bonding</p> <p>(A) Performance</p> <p>(B) Bonded Parts</p>
---	---

2017 NEC TABLE OF CONTENTS

(C) Pool Water	(A) Listed Units
680.27 Specialized Pool Equipment	(B) Other Units
(A) Underwater Audio Equipment	<u>Part V. Fountains</u>
(B) Electrically Operated Pool Covers	680.50 General
(C) Deck Area Heating	680.51 Luminaires, Submersible Pumps, and Other Submersible Equipment
680.28 Gas-Fired Water Heater	(A) Ground-Fault Circuit Interrupter
<u>Part III. Storable Pools, Storable Spas, and Storable Hot Tubs</u>	(B) Operating Voltage
680.30 General	(C) Luminaire Lenses
680.31 Pumps	(D) Overheating Protection
680.32 Ground-Fault Circuit Interrupters Required	(E) Wiring
680.33 Luminaires	(F) Servicing
(A) Within the Low Voltage Contact Limit	(G) Stability
(B) Over the Low Voltage Contact Limit But Not over 150 Volts	680.52 Junction Boxes and Other Enclosures
680.34 Receptacle Locations	(A) General
<u>Part IV. Spas and Hot Tubs</u>	(B) Underwater Junction Boxes and Other Underwater Enclosures
680.40 General	680.53 Bonding
680.41 Emergency Switch for Spas and Hot Tubs	680.54 Grounding
680.42 Outdoor Installations	680.55 Methods of Grounding
(A) Flexible Connections	(A) Applied Provisions
(B) Bonding	(B) Supplied by a Flexible Cord
(C) Interior Wiring to Outdoor Installations	680.56 Cord-and-Plug-Connected Equipment
680.43 Indoor Installations	(A) Ground-Fault Circuit Interrupter
(A) Receptacles	(B) Cord Type
(B) Installation of Luminaires, Lighting Outlets, and Ceiling-Suspended (Paddle) Fans	(C) Sealing
(C) Switches	(D) Terminations
(D) Bonding	680.57 Signs
(E) Methods of Bonding	(A) General
(F) Grounding	(B) Ground-Fault Circuit-Interrupter Protection for Personnel
(G) Underwater Audio Equipment	(C) Location
680.44 Protection	(D) Disconnect

2017 NEC TABLE OF CONTENTS

(E) Bonding and Grounding	682.11 Location of Service Equipment
680.58 GFCI Protection for Adjacent Receptacle Outlets	682.12 Electrical Connections
<u>Part VI. Pools and Tubs for Therapeutic Use</u>	682.13 Wiring Methods and Installation
680.60 General	682.14 Submersible or Floating Equipment Power Connection(s)
680.61 Permanently Installed Therapeutic Pools	(A) Type and Marking
680.62 Therapeutic Tubs (Hydrotherapeutic Tanks)	(B) Location
(A) Protection	682.15 Ground-Fault Circuit-Interrupter (GFCI) Protection
(B) Bonding	<u>Part III. Grounding and Bonding</u>
(C) Methods of Bonding	682.30 Grounding
(D) Grounding	682.31 Equipment Grounding Conductors
(E) Receptacles	(A) Type
(F) Luminaires	(B) Feeders
<u>Part VII. Hydromassage Bathtubs</u>	(C) Branch Circuits
680.70 General	(D) Cord-and-Plug-Connected Appliances
680.71 Protection	682.32 Bonding of Non–Current-Carrying Metal Parts
680.72 Other Electrical Equipment	682.33 Equipotential Planes and Bonding of Equipotential Planes
680.73 Accessibility	(A) Areas Requiring Equipotential Planes
680.74 Bonding	(B) Areas Not Requiring Equipotential Planes
(A) General	(C) Bonding
<u>Part VIII. Electrically Powered Pool Lifts</u>	Article 685 Integrated Electrical Systems
680.80 General	<u>Part I. General</u>
680.81 Equipment Approval	685.1 Scope
680.82 Protection	685.3 Application of Other Articles
680.83 Bonding	<u>Part II. Orderly Shutdown</u>
680.84 Switching Devices	685.10 Location of Overcurrent Devices in or on Premises
680.85 Nameplate Marking	685.12 Direct-Current System Grounding
Article 682 Natural and Artificially Made Bodies of Water	685.14 Ungrounded Control Circuits
<u>Part I. General</u>	Article 690 Solar Photovoltaic (PV) Systems
682.1 Scope	<u>Part I. General</u>
682.2 Definitions	690.1 Scope
682.3 Other Articles	
<u>Part II. Installation</u>	
682.10 Electrical Equipment and Transformers	

690.2 Definitions	<u>Part III. Disconnecting Means</u>
690.4 General Requirements	690.13 Photovoltaic System Disconnecting Means
(A) Photovoltaic Systems	(A) Location
(B) Equipment	(B) Marking
(C) Qualified Personnel	(C) Suitable for Use
(D) Multiple PV Systems	(D) Maximum Number of Disconnects
(E) Locations Not Permitted	(E) Ratings
690.6 Alternating-Current (ac) Modules	(F) Type of Disconnect
(A) Photovoltaic Source Circuits	690.15 Disconnection of Photovoltaic Equipment
(B) Inverter Output Circuit	(A) Location
<u>Part II. Circuit Requirements</u>	(B) Interrupting Rating
690.7 Maximum Voltage	(C) Isolating Device
(A) Photovoltaic Source and Output Circuits	(D) Equipment Disconnecting Means
(B) DC-to-DC Converter Source and Output Circuits	<u>Part IV. Wiring Methods</u>
(C) Bipolar Source and Output Circuits	690.31 Methods Permitted
690.8 Circuit Sizing and Current	(A) Wiring Systems
(A) Calculation of Maximum Circuit Current	(B) Identification and Grouping
(B) Conductor Ampacity	(C) Single-Conductor Cable
(C) Systems with Multiple Direct-Current Voltages	(D) Multiconductor Cable
(D) Sizing of Module Interconnection Conductors	(E) Flexible Cords and Cables Connected to Tracking PV Arrays
690.9 Overcurrent Protection	(F) Small-Conductor Cables
(A) Circuits and Equipment	(G) Photovoltaic System DC Circuits on or in a Building
(B) Overcurrent Device Ratings	(H) Flexible, Fine-Stranded Cables
(C) Photovoltaic Source and Output Circuits	(I) Bipolar Photovoltaic Systems
(D) Power Transformers	690.32 Component Interconnections
690.10 Stand-Alone Systems	690.33 Connectors
690.11 Arc-Fault Circuit Protection (Direct Current)	(A) Configuration
690.12 Rapid Shutdown of PV Systems on Buildings	(B) Guarding
(A) Controlled Conductors	(C) Type
(B) Controlled Limits	(D) Grounding Member
(C) Initiation Device	(E) Interruption of Circuit
(D) Equipment	

690.34 Access to Boxes

Part V. Grounding and Bonding

690.41 System Grounding

(A) PV System Grounding Configurations

(B) Ground-Fault Protection

690.42 Point of System Grounding Connection

690.43 Equipment Grounding and Bonding

(A) Photovoltaic Module Mounting Systems and Devices

(B) Equipment Secured to Grounded Metal Supports

(C) With Circuit Conductors

690.45 Size of Equipment Grounding Conductors

690.46 Array Equipment Grounding Conductors

690.47 Grounding Electrode System

(A) Buildings or Structures Supporting a PV Array

(B) Additional Auxiliary Electrodes for Array Grounding

690.50 Equipment Bonding Jumpers

Part VI. Marking

690.51 Modules

690.52 Alternating-Current Photovoltaic Modules

690.53 Direct-Current Photovoltaic Power Source

690.54 Interactive System Point of Interconnection

690.55 Photovoltaic Systems Connected to Energy Storage Systems

690.56 Identification of Power Sources

(A) Facilities with Stand-Alone Systems

(B) Facilities with Utility Services and Photovoltaic Systems

(C) Buildings with Rapid Shutdown

Part VII. Connection to Other Sources

690.59 Connection to Other Sources

Part VIII. Energy Storage Systems

690.71 General

690.72 Self-regulated PV Charge Control

Article 691 Large-Scale Photovoltaic (PV) Electric Power Production Facility

691.1 Scope

691.2 Definitions

691.4 Special Requirements for Large-Scale PV Electric Supply Stations

691.5 Equipment Approval

691.6 Engineered Design

691.7 Conformance of Construction to Engineered Design

691.8 Direct Current Operating Voltage

691.9 Disconnection of Photovoltaic Equipment

691.10 Arc-Fault Mitigation

691.11 Fence Grounding

Article 692 Fuel Cell Systems

Part I. General

692.1 Scope

692.2 Definitions

692.4 Installation

(A) Fuel Cell System

(B) Identification

(C) System Installation

692.6 Listing Requirement

Part II. Circuit Requirements

692.8 Circuit Sizing and Current

(A) Nameplate Rated Circuit Current

(B) Conductor Ampacity and Overcurrent Device Ratings

(C) Ampacity of Grounded or Neutral Conductor

692.9 Overcurrent Protection

2017 NEC TABLE OF CONTENTS

(A) Circuits and Equipment	694.1 Scope
(B) Accessibility	694.2 Definitions
692.10 Stand-Alone Systems	694.7 Installation
(A) Fuel Cell System Output	(A) Wind Electric Systems
(B) Sizing and Protection	(B) Equipment
(C) Single 120-Volt Nominal Supply	(C) Diversion Load Controllers
<u>Part III. Disconnecting Means</u>	(D) Surge Protective Devices (SPD)
692.13 All Conductors	(E) Receptacles
692.17 Switch or Circuit Breaker	(F) Poles or Towers Supporting Wind Turbines Used as a Raceway
<u>Part IV. Wiring Methods</u>	(G) Working Clearances
692.31 Wiring Systems	<u>Part II. Circuit Requirements</u>
<u>Part V. Grounding</u>	694.10 Maximum Voltage
692.41 System Grounding	(A) Wind Turbine Output Circuits
(A) AC Systems	(B) Direct-Current Utilization Circuits
(B) DC Systems	(C) Circuits over 150 Volts to Ground
(C) Systems with Alternating-Current and Direct-Current Grounding Requirements	694.12 Circuit Sizing and Current
692.44 Equipment Grounding Conductor	(A) Calculation of Maximum Circuit Current
692.45 Size of Equipment Grounding Conductor	(B) Ampacity and Overcurrent Device Ratings
692.47 Grounding Electrode System	694.15 Overcurrent Protection
<u>Part VI. Marking</u>	(A) Circuits and Equipment
692.53 Fuel Cell Power Sources	(B) Power Transformers
692.54 Fuel Shut-Off	(C) Direct-Current Rating
692.56 Stored Energy	<u>Part III. Disconnecting Means</u>
<u>Part VII. Connection to Other Circuits</u>	694.20 All Conductors
692.59 Transfer Switch	694.22 Additional Provisions
692.60 Identified Interactive Equipment	(A) Disconnecting Means
692.61 Output Characteristics	(B) Equipment
692.62 Loss of Interactive System Power	(C) Requirements for Disconnecting Means
692.64 Unbalanced Interconnections	(D) Equipment That Is Not Readily Accessible
692.65 Utility-Interactive Point of Connection	694.23 Turbine Shutdown
Article 694 Wind Electric Systems	
<u>Part I. General</u>	

(A) Manual Shutdown	695.2 Definitions
(B) Shutdown Procedure	695.3 Power Source(s) for Electric Motor-Driven Fire Pumps
694.24 Disconnection of Wind Electric System Equipment	(A) Individual Sources
694.26 Fuses	(B) Multiple Sources
694.28 Installation and Service of a Wind Turbine	(C) Multibuilding Campus-Style Complexes
<u>Part IV. Wiring Methods</u>	(D) On-Site Standby Generator as Alternate Source
694.30 Permitted Methods	(E) Arrangement
(A) Wiring Systems	(F) Transfer of Power
(B) Flexible Cords and Cables	(G) Power Source Selection
(C) Direct-Current Turbine Output Circuits Inside a Building	(H) Overcurrent Device Selection
<u>Part V. Grounding and Bonding</u>	(I) Phase Converters
694.40 Equipment Grounding and Bonding	695.4 Continuity of Power
(A) General	(A) Direct Connection
(B) Tower Grounding and Bonding	(B) Connection Through Disconnecting Means and Overcurrent Device
<u>Part VI. Marking</u>	695.5 Transformers
694.50 Interactive System Point of Interconnection	(A) Size
694.52 Power Systems Employing Energy Storage	(B) Overcurrent Protection
694.54 Identification of Power Sources	(C) Feeder Source
(A) Facilities with Stand-Alone Systems	695.6 Power Wiring
(B) Facilities with Utility Services and Wind Electric Systems	(A) Supply Conductors
694.56 Instructions for Disabling Turbine	(B) Conductor Size
<u>Part VII. Connection to Other Sources</u>	(C) Overload Protection
694.60 Identified Interactive Equipment	(D) Pump Wiring
694.62 Installation	(E) Loads Supplied by Controllers and Transfer Switches
694.66 Operating Voltage Range	(F) Mechanical Protection
694.68 Point of Connection	(G) Ground-Fault Protection of Equipment
Article 695 Fire Pumps	(H) Listed Electrical Circuit Protective System to Controller Wiring
695.1 Scope	(I) Junction Boxes
(A) Covered	(J) Raceway Terminations
(B) Not Covered	

695.7 Voltage Drop	(B) Selective Load Pickup, Load Shedding, and Peak Load Shaving
(A) Starting	
(B) Running	
695.10 Listed Equipment	700.5 Transfer Equipment
695.12 Equipment Location	(A) General
(A) Controllers and Transfer Switches	(B) Bypass Isolation Switches
(B) Engine-Drive Controllers	(C) Automatic Transfer Switches
(C) Storage Batteries	(D) Use
(D) Energized Equipment	(E) Documentation
(E) Protection Against Pump Water	700.6 Signals
(F) Mounting	(A) Malfunction
695.14 Control Wiring	(B) Carrying Load
(A) Control Circuit Failures	(C) Not Functioning
(B) Sensor Functioning	(D) Ground Fault
(C) Remote Device(s)	700.7 Signs
(D) Engine-Drive Control Wiring	(A) Emergency Sources
(E) Electric Fire Pump Control Wiring Methods	(B) Grounding
(F) Generator Control Wiring Methods	700.8 Surge Protection
695.15 Surge Protection	<u>Part II. Circuit Wiring</u>
Article 700 Emergency Systems	700.10 Wiring, Emergency System
<u>Part I. General</u>	(A) Identification
700.1 Scope	(B) Wiring
700.2 Definitions	(C) Wiring Design and Location
700.3 Tests and Maintenance	(D) Fire Protection
(A) Conduct or Witness Test	<u>Part III. Sources of Power</u>
(B) Tested Periodically	700.12 General Requirements
(C) Maintenance	(A) Storage Battery
(D) Written Record	(B) Generator Set
(E) Testing Under Load	(C) Uninterruptible Power Supplies
(F) Temporary Source of Power for Maintenance or Repair of the Alternate Source of Power	(D) Separate Service
700.4 Capacity	(E) Fuel Cell System
(A) Capacity and Rating	(F) Unit Equipment
	<u>Part IV. Emergency System Circuits for Lighting and Power</u>
	700.15 Loads on Emergency Branch Circuits

2017 NEC TABLE OF CONTENTS

700.16 Emergency Illumination	(A) Malfunction
700.17 Branch Circuits for Emergency Lighting	(B) Carrying Load
700.18 Circuits for Emergency Power	(C) Not Functioning
700.19 Multiwire Branch Circuits	(D) Ground Fault
<u>Part V. Control — Emergency Lighting Circuits</u>	701.7 Signs
700.20 Switch Requirements	(A) Mandated Standby
700.21 Switch Location	(B) Grounding
700.22 Exterior Lights	<u>Part II. Circuit Wiring</u>
700.23 Dimmer and Relay Systems	701.10 Wiring Legally Required Standby Systems
700.24 Directly Controlled Luminaires	<u>Part III. Sources of Power</u>
700.25 Branch Circuit Emergency Lighting Transfer Switch	701.12 General Requirements
700.26 Automatic Load Control Relay	(A) Storage Battery
<u>Part VI. Overcurrent Protection</u>	(B) Generator Set
700.30 Accessibility	(C) Uninterruptible Power Supplies
700.31 Ground-Fault Protection of Equipment	(D) Separate Service
700.32 Selective Coordination	(E) Connection Ahead of Service Disconnecting Means
Article 701 Legally Required Standby Systems	(F) Fuel Cell System
<u>Part I. General</u>	(G) Unit Equipment
701.1 Scope	<u>Part IV. Overcurrent Protection</u>
701.2 Definition	701.25 Accessibility
701.3 Tests and Maintenance	701.26 Ground-Fault Protection of Equipment
(A) Conduct or Witness Test	701.27 Selective Coordination
(B) Tested Periodically	Article 702 Optional Standby Systems
(C) Maintenance	<u>Part I. General</u>
(D) Written Record	702.1 Scope
(E) Testing Under Load	702.2 Definition
701.4 Capacity and Rating	702.4 Capacity and Rating
701.5 Transfer Equipment	(A) Available Short-Circuit Current
(A) General	(B) System Capacity
(B) Bypass Isolation Switches	702.5 Transfer Equipment
(C) Automatic Transfer Switches	702.6 Signals
(D) Documentation	(A) Malfunction
701.6 Signals	

(B) Carrying Load	705.23 Interactive System Disconnecting Means
702.7 Signs	705.30 Overcurrent Protection
(A) Standby	(A) Solar Photovoltaic Systems
(B) Grounding	(B) Transformers
(C) Power Inlet	(C) Fuel Cell Systems
<u>Part II. Wiring</u>	(D) Interactive Inverters
702.10 Wiring Optional Standby Systems	(E) Generators
702.11 Portable Generator Grounding	705.31 Location of Overcurrent Protection
(A) Separately Derived System	705.32 Ground-Fault Protection
(B) Nonseparately Derived System	705.40 Loss of Primary Source
702.12 Outdoor Generator Sets	705.42 Loss of 3-Phase Primary Source
(A) Portable Generators Greater Than 15 kW and Permanently Installed Generators	705.50 Grounding
(B) Portable Generators 15 kW or Less	Part II. Interactive Inverters
(C) Power Inlets Rated at 100 Amperes or Greater, for Portable Generators	705.60 Circuit Sizing and Current
Article 705 Interconnected Electric Power	(A) Calculation of Maximum Circuit Current
Production Sources	(B) Ampacity and Overcurrent Device Ratings
<u>Part I. General</u>	705.65 Overcurrent Protection
705.1 Scope	(A) Circuits and Equipment
705.2 Definitions	(B) Power Transformers
705.3 Other Articles	(C) Conductor Ampacity
705.6 Equipment Approval	705.70 Interactive Inverters Mounted in Not Readily Accessible Locations
705.8 System Installation	705.80 Utility-Interactive Power Systems Employing Energy Storage
705.10 Directory	705.82 Hybrid Systems
705.12 Point of Connection	705.95 Ampacity of Neutral Conductor
(A) Supply Side	(A) Neutral Conductor for Single Phase, 2-Wire Inverter Output
(B) Load Side	(B) Neutral Conductor for Instrumentation, Voltage, Detection or Phase Detection
705.14 Output Characteristics	705.100 Unbalanced Interconnections
705.16 Interrupting and Short-Circuit Current Rating	(A) Single Phase
705.20 Disconnecting Means, Sources	(B) Three Phase
705.21 Disconnecting Means, Equipment	
705.22 Disconnect Device	

Part III. Generators	(E) Illumination
705.130 Overcurrent Protection	706.11 Directory
705.143 Synchronous Generators	(A) Directory
Part IV. Microgrid Systems	(B) Facilities with Stand-Alone Systems
705.150 System Operation	<u>Part II. Circuit Requirements</u>
705.160 Primary Power Source Connection	706.20 Circuit Sizing and Current
705.165 Reconnection to Primary Power Source	(A) Maximum Rated Current for a Specific
705.170 Microgrid Interconnect Devices (MID)	Circuit
Article 706 Energy Storage Systems	(B) Conductor Ampacity and Overcurrent Device
<u>Part I. General</u>	Ratings
706.1 Scope	(C) Ampacity of Grounded or Neutral Conductor
706.2 Definitions	706.21 Overcurrent Protection
706.3 Other Articles	(A) Circuits and Equipment
706.4 System Classification	(B) Overcurrent Device Ampere Ratings
706.5 Equipment	(C) Direct Current Rating
706.6 Multiple Systems	(D) Current Limiting
706.7 Disconnecting Means	(E) Fuses
(A) ESS Disconnecting Means	(F) Location
(B) Remote Actuation	706.23 Charge Control
(C) Busway	(A) General
(D) Notification	(B) Diversion Charge Controller
(E) Partitions and Distance	(C) Charge Controllers and DC-to-DC Converters
706.8 Connection to Other Energy Sources	<u>Part III. Electrochemical Energy Storage Systems</u>
(A) Load Disconnect	706.30 Installation of Batteries
(B) Identified Interactive Equipment	(A) Dwelling Units
(C) Loss of Interactive System Power	(B) Disconnection of Series Battery Circuits
(D) Unbalanced Interconnections	(C) Storage System Maintenance Disconnecting
(E) Point of Connection	Means
706.10 Energy Storage System Locations	(D) Storage Systems of More Than 100 Volts
(A) Ventilation	706.31 Battery and Cell Terminations
(B) Guarding of Live Parts	(A) Corrosion Prevention
(C) Spaces About ESS Components	(B) Intercell and Intertier Conductors and Connections
(D) Egress	(C) Battery Terminals

706.32 Battery Interconnections	(B) Component and System Tests
706.33 Accessibility	(C) Baseline Test Results
706.34 Battery Locations	(D) Functional Performance Tests
(A) Live Parts	<u>Part II. Circuit Wiring and Equipment</u>
(B) Top Terminal Batteries	708.10 Feeder and Branch Circuit Wiring
(C) Gas Piping	(A) Identification
<u>Part IV. Flow Battery Energy Storage Systems</u>	(B) Wiring
706.40 General	(C) COPS Feeder Wiring Requirements
706.41 Electrolyte Classification	(D) COPS Branch Circuit Wiring
706.42 Electrolyte Containment	708.11 Branch Circuit and Feeder Distribution Equipment
706.43 Flow Controls	(A) Branch Circuit Distribution Equipment
706.44 Pumps and Other Fluid Handling Equipment	(B) Feeder Distribution Equipment
<u>Part V. Other Energy Storage Technologies</u>	708.12 Feeders and Branch Circuits Supplied by COPS
706.50 General	708.14 Wiring of HVAC, Fire Alarm, Security, Emergency Communications, and Signaling Systems
Article 708 Critical Operations Power Systems (COPS)	<u>Part III. Power Sources and Connection</u>
<u>Part I. General</u>	708.20 Sources of Power
708.1 Scope	(A) General Requirements
708.2 Definitions	(B) Fire Protection
708.4 Risk Assessment	(C) Grounding
(A) Conducting Risk Assessment	(D) Surge Protection Devices
(B) Identification of Hazards	(E) Storage Battery
(C) Developing Mitigation Strategy	(F) Generator Set
708.5 Physical Security	(G) Uninterruptible Power Supplies
(A) Risk Assessment	(H) Fuel Cell System
(B) Restricted Access	708.21 Ventilation
708.6 Testing and Maintenance	708.22 Capacity of Power Sources
(A) Conduct or Witness Test	(A) Capacity and Rating
(B) Tested Periodically	(B) Selective Load Pickup, Load Shedding, and Peak Load Shaving
(C) Maintenance	(C) Duration of COPS Operation
(D) Written Record	708.24 Transfer Equipment
(E) Testing Under Load	(A) General
708.8 Commissioning	
(A) Commissioning Plan	

(B) Bypass Isolation Switches	<u>Part II. Circuit Requirements</u>
(C) Automatic Transfer Switches	712.25 Identification of Circuit Conductors
(D) Use	712.30 System Voltage
(E) Documentation	<u>Part III. Disconnecting Means</u>
708.30 Branch Circuits Supplied by COPS	712.34 DC Source Disconnecting Means
<u>Part IV. Overcurrent Protection</u>	712.35 Disconnection of Ungrounded Conductors
708.50 Accessibility	712.37 Directional Current Devices
708.52 Ground-Fault Protection of Equipment	<u>Part IV. Wiring Methods</u>
(A) Applicability	712.52 System Grounding
(B) Feeders	(A) General
(C) Testing	(B) Over 300 Volts
(D) Selectivity	712.55 Ground Fault Detection Equipment
708.54 Selective Coordination	712.57 Arc Fault Protection
<u>Part V. System Performance and Analysis</u>	<u>Part V. Marking</u>
708.64 Emergency Operations Plan	712.62 Distribution Equipment and Conductors
Article 710 Stand-Alone Systems	712.65 Available DC Short-Circuit Current
710.1 Scope	(A) Field Marking
710.6 Equipment Approval	(B) Modifications
710.15 General	<u>Part VI. Protection</u>
(A) Supply Output	712.70 Overcurrent Protection
(B) Sizing and Protection	712.72 Interrupting and Short-Circuit Current Ratings
(C) Single 120-Volt Supply	<u>Part VII. Systems over 1000 Volts</u>
(D) Energy Storage or Backup Power System Requirements	712.80 General
(E) Back-Fed Circuit Breakers	Article 720 Circuits and Equipment Operating at Less Than 50 Volts
(F) Voltage and Frequency Control	720.1 Scope
Article 712 Direct Current Microgrids	720.2 Other Articles
<u>Part I. General</u>	720.3 Hazardous (Classified) Locations
712.1 Scope	720.4 Conductors
712.2 Definitions	720.5 Lampholders
712.3 Other Articles	720.6 Receptacle Rating
712.4 Listing and Labeling	720.7 Receptacles Required
712.10 Directory	720.9 Batteries

720.11 Mechanical Execution of Work	725.41 Class 1 Circuit Classifications and Power Source Requirements
Article 725 Class 1, Class 2, and Class 3	
Remote-Control, Signaling, and Power-Limited Circuits	
<u>Part I. General</u>	(A) Class 1 Power-Limited Circuits
725.1 Scope	(B) Class 1 Remote-Control and Signaling Circuits
725.2 Definitions	725.43 Class 1 Circuit Overcurrent Protection
725.3 Other Articles	725.45 Class 1 Circuit Overcurrent Device Location
(A) Number and Size of Conductors in Raceway	(A) Point of Supply
(B) Spread of Fire or Products of Combustion	(B) Feeder Taps
(C) Ducts, Plenums, and Other Air-Handling Spaces	(C) Branch-Circuit Taps
(D) Hazardous (Classified) Locations	(D) Primary Side of Transformer
(E) Cable Trays	(E) Input Side of Electronic Power Source
(F) Motor Control Circuits	725.46 Class 1 Circuit Wiring Methods
(G) Instrumentation Tray Cable	725.48 Conductors of Different Circuits in the Same Cable, Cable Tray, Enclosure, or Raceway
(H) Raceways Exposed to Different Temperatures	(A) Two or More Class 1 Circuits
(I) Vertical Support for Fire-Rated Cables and Conductors	(B) Class 1 Circuits with Power-Supply Circuits
(J) Bushing	725.49 Class 1 Circuit Conductors
(K) Installation of Conductors with Other Systems	(A) Sizes and Use
(L) Corrosive, Damp, or Wet Locations	(B) Insulation
(M) Cable Routing Assemblies	725.51 Number of Conductors in Cable Trays and Raceway, and Ampacity Adjustment
(N) Communications Raceways	(A) Class 1 Circuit Conductors
725.21 Access to Electrical Equipment Behind Panels Designed to Allow Access	(B) Power-Supply Conductors and Class 1 Circuit Conductors
725.24 Mechanical Execution of Work	(C) Class 1 Circuit Conductors in Cable Trays
725.25 Abandoned Cables	725.52 Circuits Extending Beyond One Building
725.30 Class 1, Class 2, and Class 3 Circuit Identification	<u>Part III. Class 2 and Class 3 Circuits</u>
725.31 Safety-Control Equipment	725.121 Power Sources for Class 2 and Class 3 Circuits
(A) Remote-Control Circuits	(A) Power Source
(B) Physical Protection	(B) Interconnection of Power Sources
725.35 Class 1, Class 2, and Class 3 Circuit Requirements	(C) Marking
<u>Part II. Class 1 Circuits</u>	725.124 Circuit Marking
	725.127 Wiring Methods on Supply Side of the Class 2

or Class 3 Power Source	(D) Associated Systems Within Enclosures
725.130 Wiring Methods and Materials on Load Side	(E) Enclosures with Single Opening
of the Class 2 or Class 3 Power Source	(F) Manholes
(A) Class 1 Wiring Methods and Materials	(G) Cable Trays
(B) Class 2 and Class 3 Wiring Methods	(H) In Hoistways
725.133 Installation of Conductors and Equipment	(I) Other Applications
in Cables, Compartments, Cable Trays,	725.139 Installation of Conductors of Different Circuits
Enclosures, Manholes, Outlet Boxes, Device	in the Same Cable, Enclosure, Cable Tray,
Boxes, Raceways, and Cable Routing Assemblies	Raceway, or Cable Routing Assembly
for Class 2 and Class 3 Circuits	(A) Two or More Class 2 Circuits
725.135 Installation of Class 2, Class 3, and PLTC Cables	(B) Two or More Class 3 Circuits
(A) Listing	(C) Class 2 Circuits with Class 3 Circuits
(B) Ducts Specifically Fabricated for	(D) Class 2 and Class 3 Circuits with
Environmental Air	Communications Circuits
(C) Other Spaces Used for Environmental Air	(E) Class 2 or Class 3 Cables with Other Circuit
(Plenums)	Cables
(D) Risers — Cables in Vertical Runs	(F) Class 2 or Class 3 Conductors or Cables
(E) Risers — Cables in Metal Raceways	and Audio System Circuits
(F) Risers — Cables in Fireproof Shafts	725.141 Installation of Circuit Conductors Extending
(G) Risers — One- and Two-Family Dwellings	Beyond One Building
(H) Cable Trays	725.143 Support of Conductors
(I) Cross-Connect Arrays	725.144 Transmission of Power and Data
(J) Industrial Establishments	(A) Use of Class 2 or Class 3 Cables to Transmit
(K) Other Building Locations	Power and Data
(L) Multifamily Dwellings	(B) Use of Class 2-LP or Class 3-LP Cables
(M) One- and Two-Family Dwellings	to Transmit Power and Data
725.136 Separation from Electric Light, Power, Class 1,	725.154 Applications of Listed Class 2, Class 3, and PLTC
Non-Power-Limited Fire Alarm Circuit	Cables
Conductors, and Medium-Power Network Powered	(A) Class 2 and Class 3 Cable Substitutions
Broadband Communications Cables	(B) Class 2, Class 3, PLTC Circuit Integrity (CI)
(A) General	Cable or Electrical Circuit Protective System
(B) Separated by Barriers	(C) Thermocouple Circuits
(C) Raceways Within Enclosures	<u>Part IV. Listing Requirements</u>

725.170 Listing and Marking of Equipment for Power and Data Transmission	(B) Supports
725.179 Listing and Marking of Class 2, Class 3, and Type PLTC Cables	(C) Raceways and Couplings
(A) Types CL2P and CL3P	(D) Cable Trays
(B) Types CL2R and CL3R	(E) Boxes
(C) Types CL2 and CL3	(F) Pulling Lubricants
(D) Types CL2X and CL3X	(G) Vertical Supports
(E) Type PLTC	(H) Splices
(F) Circuit Integrity (CI) Cable or Electrical Circuit Protective System	728.60 Grounding
(G) Class 2 and Class 3 Cable Voltage Ratings	728.120 Marking
(H) Class 3 Single Conductors	Article 750 Energy Management Systems
(I) Limited Power (LP) Cables	750.1 Scope
(J) Marking	750.2 Definitions
Article 727 Instrumentation Tray Cable: Type ITC	750.20 Alternate Power Sources
727.1 Scope	750.30 Load Management
727.2 Definition	(A) Load Shedding Controls
727.3 Other Articles	(B) Disconnection of Power
727.4 Uses Permitted	(C) Capacity of Branch Circuit, Feeder, or Service
727.5 Uses Not Permitted	750.50 Field Markings
727.6 Construction	Article 760 Fire Alarm Systems
727.7 Marking	<u>Part I. General</u>
727.8 Allowable Ampacity	760.1 Scope
727.9 Overcurrent Protection	760.2 Definitions
727.10 Bends	760.3 Other Articles
Article 728 Fire-Resistive Cable Systems	(A) Spread of Fire or Products of Combustion
728.1 Scope	(B) Ducts, Plenums, and Other Air-Handling Spaces
728.2 Definition	(C) Hazardous (Classified) Locations
728.3 Other Articles	(D) Corrosive, Damp, or Wet Locations
728.4 General	(E) Building Control Circuits
728.5 Installations	(F) Optical Fiber Cables
(A) Mounting	(G) Installation of Conductors with Other Systems
	(H) Raceways or Sleeves Exposed to Different Temperatures
	(I) Vertical Support for Fire Rated Cables and

2017 NEC TABLE OF CONTENTS

Conductors	760.51 Number of Conductors in Cable Trays and Raceways, and Ampacity Adjustment Factors
(J) Number and Size of Cables and Conductors in Raceway	(A) NPLFA Circuits and Class 1 Circuits
(K) Bushing	(B) Power-Supply Conductors and NPLFA Circuit Conductors
(L) Cable Routing Assemblies	(C) Cable Trays
(M) Communications Raceways	760.53 Multiconductor NPLFA Cables
760.21 Access to Electrical Equipment Behind Panels Designed to Allow Access	(A) NPLFA Wiring Method
760.24 Mechanical Execution of Work	(B) Applications of Listed NPLFA Cables
(A) General	<u>Part III. Power-Limited Fire Alarm (PLFA) Circuits</u>
(B) Circuit Integrity (CI) Cable	760.121 Power Sources for PLFA Circuits
760.25 Abandoned Cables	(A) Power Source
760.30 Fire Alarm Circuit Identification	(B) Branch Circuit
760.32 Fire Alarm Circuits Extending Beyond One Building	760.124 Circuit Marking
760.35 Fire Alarm Circuit Requirements	760.127 Wiring Methods on Supply Side of the PLFA Power Source
(A) Non–Power-Limited Fire Alarm (NPLFA) Circuits	760.130 Wiring Methods and Materials on Load Side of the PLFA Power Source
(B) Power-Limited Fire Alarm (PLFA) Circuits	(A) NPLFA Wiring Methods and Materials
<u>Part II. Non–Power-Limited Fire Alarm (NPLFA) Circuits</u>	(B) PLFA Wiring Methods and Materials
760.41 NPLFA Circuit Power Source Requirements	760.133 Installation of Conductors and Equipment in Cables, Compartments, Cable Trays, Enclosures, Manholes, Outlet Boxes, Device Boxes, Raceways, and Cable Routing Assemblies for Power-Limited Fire Alarm Circuits
(A) Power Source	760.135 Installation of PLFA Cables in Buildings
(B) Branch Circuit	(A) Listing
760.43 NPLFA Circuit Overcurrent Protection	(B) Ducts Specifically Fabricated for Environmental Air
760.45 NPLFA Circuit Overcurrent Device Location	(C) Other Spaces Used For Environmental Air (Plenums)
760.46 NPLFA Circuit Wiring	(D) Risers — Cables in Vertical Runs
760.48 Conductors of Different Circuits in Same Cable, Enclosure, or Raceway	
(A) Class 1 with NPLFA Circuits	
(B) Fire Alarm with Power-Supply Circuits	
760.49 NPLFA Circuit Conductors	
(A) Sizes and Use	
(B) Insulation	
(C) Conductor Materials	

(E) Risers — Cables in Metal Raceways	760.154 Applications of Listed PLFA Cables
(F) Risers — Cables in Fireproof Shafts	(A) Fire Alarm Cable Substitutions
(G) Risers — One- and Two-Family Dwellings	<u>Part IV. Listing Requirements</u>
(H) Other Building Locations	760.176 Listing and Marking of NPLFA Cables
(I) Nonconcealed Spaces	(A) NPLFA Conductor Materials
(J) Portable Fire Alarm System	(B) Insulated Conductors
760.136 Separation from Electric Light, Power, Class 1, NPLFA, and Medium-Power Network-Powered Broadband Communications Circuit Conductors	(C) Type NPLFP
(A) General	(D) Type NPLFR
(B) Separated by Barriers	(E) Type NPLF
(C) Raceways Within Enclosures	(F) Fire Alarm Circuit Integrity (CI) Cable or Electrical Circuit Protective System
(D) Associated Systems Within Enclosures	(G) NPLFA Cable Markings
(E) Enclosures with Single Opening	760.179 Listing and Marking of PLFA Cables and Insulated Continuous Line-Type Fire Detectors
(F) In Hoistways	(A) Conductor Materials
(G) Other Applications	(B) Conductor Size
760.139 Installation of Conductors of Different PLFA Circuits, Class 2, Class 3, and Communications Circuits in the Same Cable, Enclosure, Cable Tray, Raceway, or Cable Routing Assembly	(C) Ratings
(A) Two or More PLFA Circuits	(D) Type FPLP
(B) Class 2 Circuits with PLFA Circuits	(E) Type FPLR
(C) Low-Power Network-Powered Broadband Communications Cables and PLFA Cables	(F) Type FPL
(D) Audio System Circuits and PLFA Circuits	(G) Fire Alarm Circuit Integrity (CI) Cable or Electrical Circuit Protective System
760.142 Conductor Size	(H) Coaxial Cables
760.143 Support of Conductors	(I) Cable Marking
760.145 Current-Carrying Continuous Line-Type Fire Detectors	(J) Insulated Continuous Line-Type Fire Detectors
(A) Application	Article 770 Optical Fiber Cables
(B) Installation	<u>Part I. General</u>
	770.1 Scope
	770.2 Definitions
	770.3 Other Articles
	(A) Hazardous (Classified) Locations
	(B) Cables in Ducts for Dust, Loose Stock,

or Vapor Removal	(C) Electrode Connection
(C) Composite Cables	(D) Bonding of Electrodes
770.21 Access to Electrical Equipment Behind Panels Designed to Allow Access	770.106 Grounding and Bonding of Entrance Cables at Mobile Homes
770.24 Mechanical Execution of Work	(A) Grounding
770.25 Abandoned Cables	(B) Bonding
770.26 Spread of Fire or Products of Combustion	<u>Part V. Installation Methods Within Buildings</u>
<u>Part II. Cables Outside and Entering Buildings</u>	770.110 Raceways and Cable Routing Assemblies for Optical Fiber Cables
770.44 Overhead (Aerial) Optical Fiber Cables	(A) Types of Raceways
(A) On Poles and In-Span	(B) Raceway Fill for Optical Fiber Cables
(B) Above Roofs	(C) Cable Routing Assemblies
770.47 Underground Optical Fiber Cables Entering Buildings	770.113 Installation of Optical Fiber Cables
(A) Underground Systems with Electric Light, Power, Class 1, or Non–Power-Limited Fire Alarm Circuit Conductors	(A) Listing
(B) Direct-Buried Cables and Raceways	(B) Ducts Specifically Fabricated for Environmental Air
770.48 Unlisted Cables Entering Buildings	(C) Other Spaces Used for Environmental Air (Plenums)
(A) Conductive and Nonconductive Cables	(D) Risers — Cables in Vertical Runs
(B) Nonconductive Cables in Raceway	(E) Risers — Cables and Innerducts in Metal Raceways
770.49 Metallic Entrance Conduit Grounding	(F) Risers — Cables in Fireproof Shafts
<u>Part III. Protection</u>	(G) Risers — One- and Two-Family Dwellings
770.93 Grounding or Interruption of Non–Current-Carrying Metallic Members of Optical Fiber Cables	(H) Cable Trays
(A) Entering Buildings	(I) Distributing Frames and Cross-Connect Arrays
(B) Terminating on the Outside of Buildings	(J) Other Building Locations
<u>Part IV. Grounding Methods</u>	770.114 Grounding
770.100 Entrance Cable Bonding and Grounding	770.133 Installation of Optical Fibers and Electrical Conductors
(A) Bonding Conductor or Grounding Electrode Conductor	(A) With Conductors for Electric Light, Power, Class 1, Non–Power-Limited Fire Alarm, or Medium Power Network-Powered Broadband Communications Circuits
(B) Electrode	

(B) With Other Circuits	800.24 Mechanical Execution of Work
(C) Support of Optical Fiber Cables	800.25 Abandoned Cables
770.154 Applications of Listed Optical Fiber Cables	800.26 Spread of Fire or Products of Combustion
<u>Part VI. Listing Requirements</u>	<u>Part II. Wires and Cables Outside and Entering Buildings</u>
770.179 Optical Fiber Cables	800.44 Overhead (Aerial) Communications Wires and Cables
(A) Types OFNP and OFCP	(A) On Poles and In-Span
(B) Types OFNR and OFCR	(B) Above Roofs
(C) Types OFNG and OFCG	800.47 Underground Communications Wires and Cables Entering Buildings
(D) Types OFN and OFC	(A) Underground Systems with Electric Light, Power, Class 1, or Non–Power-Limited Fire Alarm Circuit Conductors
(E) Circuit Integrity (CI) Cable or Electrical Circuit Protective System	(B) Underground Block Distribution
(F) Field-Assembled Optical Fiber Cables	800.48 Unlisted Cables Entering Buildings
770.180 Grounding Devices	800.49 Metallic Entrance Conduit Grounding
Article 800 Communications Circuits	800.50 Circuits Requiring Primary Protectors
<u>Part I. General</u>	(A) Insulation, Wires, and Cables
800.1 Scope	(B) On Buildings
800.2 Definitions	(C) Entering Buildings
800.3 Other Articles	800.53 Lightning Conductors
(A) Hazardous (Classified) Locations	<u>Part III. Protection</u>
(B) Wiring in Ducts for Dust, Loose Stock, or Vapor Removal	800.90 Protective Devices
(C) Equipment in Other Space Used for Environmental Air	(A) Application
(D) Installation and Use	(B) Location
(E) Network-Powered Broadband Communications Systems	(C) Hazardous (Classified) Locations
(F) Premises-Powered Broadband Communications Systems	(D) Secondary Protectors
(G) Optical Fiber Cable	800.93 Grounding or Interruption of Non–Current-Carrying Metallic Sheath Members of Communications Cables
(H) Temperature Limitation of Conductors	(A) Entering Buildings
800.18 Installation of Equipment	(B) Terminating on the Outside of Buildings
800.21 Access to Electrical Equipment Behind Panels Designed to Allow Access	<u>Part IV. Grounding Methods</u>

800.100 Cable and Primary Protector Bonding and Grounding	800.133 Installation of Communications Wires, Cables, and Equipment
(A) Bonding Conductor or Grounding Electrode Conductor	(A) Separation from Other Conductors
(B) Electrode	(B) Support of Communications Wires and Cables
(C) Electrode Connection	800.154 Applications of Listed Communications Wires, Cables, and Raceways, and Listed Cable Routing Assemblies
(D) Bonding of Electrodes	800.156 Dwelling Unit Communications Outlet
800.106 Primary Protector Grounding and Bonding at Mobile Homes	<u>Part VI. Listing Requirements</u>
(A) Grounding	800.170 Equipment
(B) Bonding	(A) Primary Protectors
<u>Part V. Installation Methods Within Buildings</u>	(B) Secondary Protectors
800.110 Raceways and Cable Routing Assemblies for Communications Wires and Cables	(C) Plenum Grade Cable Ties
(A) Types of Raceways	800.173 Drop Wire and Cable
(B) Raceway Fill for Communications Wires and Cables	800.179 Communications Wires and Cables
(C) Cable Routing Assemblies	(A) Type CMP
800.113 Installation of Communications Wires, Cables and Raceways, and Cable Routing Assemblies	(B) Type CMR
(A) Listing	(C) Type CMG
(B) Ducts Specifically Fabricated for Environmental Air	(D) Type CM
(C) Other Spaces Used for Environmental Air (Plenums)	(E) Type CMX
(D) Risers — Cables, Raceways, and Cable Routing Assemblies in Vertical Runs	(F) Type CMUC Undercarpet Wires and Cables
(E) Risers — Cables and Innerducts in Metal Raceways	(G) Circuit Integrity (CI) Cable or Electrical Circuit Protective System
(F) Risers — Cables, Raceways, and Cable Routing Assemblies in Fireproof Shafts	(H) Communications Wires
(G) Risers — One- and Two-Family Dwellings	(I) Hybrid Power and Communications Cables
(H) Cable Trays	800.180 Grounding Devices
(I) Distributing Frames and Cross-Connect Arrays	800.182 Cable Routing Assemblies and Communications Raceways
(J) Other Building Locations	(A) Plenum Cable Routing Assemblies and Plenum Communications Raceways
(K) Multifamily Dwellings	(B) Riser Cable Routing Assemblies and Riser Communications Raceways
(L) One- and Two-Family Dwellings	(C) General-Purpose Cable Routing Assemblies

and General-Purpose Communication Raceways

Article 810 Radio and Television Equipment

Part I. General

810.1 Scope

810.2 Definitions

810.3 Other Articles

810.4 Community Television Antenna

810.5 Radio Noise Suppressors

810.6 Antenna Lead-In Protectors

810.7 Grounding Devices

Part II. Receiving Equipment — Antenna Systems

810.11 Material

810.12 Supports

810.13 Avoidance of Contacts with Conductors of Other Systems

810.14 Splices

810.15 Grounding

810.16 Size of Wire-Strung Antenna — Receiving Station

(A) Size of Antenna Conductors

(B) Self-Supporting Antennas

810.17 Size of Lead-in — Receiving Station

810.18 Clearances — Receiving Stations

(A) Outside of Buildings

(B) Antennas and Lead-ins — Indoors

(C) In Boxes or Other Enclosures

810.19 Electrical Supply Circuits Used in Lieu of Antenna — Receiving Stations

810.20 Antenna Discharge Units — Receiving Stations

(A) Where Required

(B) Location

(C) Grounding

810.21 Bonding Conductors and Grounding Electrode

Conductors — Receiving Stations

(A) Material

(B) Insulation

(C) Supports

(D) Physical Protection

(E) Run in Straight Line

(F) Electrode

(G) Inside or Outside Building

(H) Size

(I) Common Ground

(J) Bonding of Electrodes

(K) Electrode Connection

Part III. Amateur and Citizen Band Transmitting

and Receiving Stations — Antenna Systems

810.51 Other Sections

810.52 Size of Antenna

810.53 Size of Lead-in Conductors

810.54 Clearance on Building

810.55 Entrance to Building

810.56 Protection Against Accidental Contact

810.57 Antenna Discharge Units — Transmitting Stations

810.58 Bonding Conductors and Grounding Electrode

Conductors — Amateur and Citizen Band

Transmitting and Receiving Stations

(A) Other Sections

(B) Size of Protective Bonding Conductor or Grounding Electrode Conductor

(C) Size of Operating Bonding Conductor or Grounding Electrode Conductor

Part IV. Interior Installation — Transmitting Stations

810.70 Clearance from Other Conductors

810.71 General

(A) Enclosing

(B) Grounding of Controls	(D) Between Buildings
(C) Interlocks on Doors	(E) On Buildings
Article 820 Community Antenna Television and Radio Distribution Systems	820.47 Underground Coaxial Cables Entering Buildings
<u>Part I. General</u>	(A) Underground Systems with Electric Light, Power, Class 1, or Non-Power-Limited Fire Alarm Circuit Conductors
820.1 Scope	(B) Direct-Buried Cables and Raceways
820.2 Definitions	820.48 Unlisted Cables Entering Buildings
820.3 Other Articles	820.49 Metallic Entrance Conduit Grounding
(A) Hazardous (Classified) Locations	<u>Part III. Protection</u>
(B) Wiring in Ducts for Dust, Loose Stock, or Vapor Removal	820.93 Grounding of the Outer Conductive Shield of Coaxial Cables
(C) Equipment in Other Space Used for Environmental Air	(A) Entering Buildings
(D) Installation and Use	(B) Terminating Outside of the Building
(E) Installations of Conductive and Nonconductive Optical Fiber Cables	(C) Location
(F) Communications Circuits	(D) Hazardous (Classified) Locations
(G) Network-Powered Broadband Communications Systems	<u>Part IV. Grounding Methods</u>
(H) Premises-Powered Broadband Communications Systems	820.100 Cable Bonding and Grounding
(I) Alternate Wiring Methods	(A) Bonding Conductor or Grounding Electrode Conductor
820.15 Power Limitations	(B) Electrode
820.21 Access to Electrical Equipment Behind Panels Designed to Allow Access	(C) Electrode Connection
820.24 Mechanical Execution of Work	(D) Bonding of Electrodes
820.25 Abandoned Cables	(E) Shield Protection Devices
820.26 Spread of Fire or Products of Combustion	820.103 Equipment Grounding
<u>Part II. Coaxial Cables Outside and Entering Buildings</u>	820.106 Grounding and Bonding at Mobile Homes
820.44 Overhead (Aerial) Coaxial Cables	(A) Grounding
(A) On Poles and In-Span	(B) Bonding
(B) Above Roofs	<u>Part V. Installation Methods Within Buildings</u>
(C) On Masts	820.110 Raceways and Cable Routing Assemblies for Coaxial Cables
	(A) Types of Raceways
	(B) Raceway Fill for Coaxial Cables

2017 NEC TABLE OF CONTENTS

(C) Cable Routing Assemblies	<u>Part I. General</u>
820.113 Installation of Coaxial Cables	830.1 Scope
(A) Listing	830.2 Definitions
(B) Ducts Specifically Fabricated for Environmental Air	830.3 Other Articles
(C) Other Spaces Used For Environmental Air (Plenums)	(A) Hazardous (Classified) Locations
(D) Risers — Cables in Vertical Runs	(B) Wiring in Ducts for Dust, Loose Stock, or Vapor Removal
(E) Risers — Cables and Innerducts in Metal Raceways	(C) Equipment in Other Space Used for Environmental Air
(F) Risers — Cables in Fireproof Shafts	(D) Installation and Use
(G) Risers — One- and Two-Family Dwellings	(E) Output Circuits
(H) Cable Trays	(F) Protection Against Physical Damage
(I) Distributing Frames and Cross-Connect Arrays	830.15 Power Limitations
(J) Other Building Locations	830.21 Access to Electrical Equipment Behind Panels Designed to Allow Access
(K) One- and Two-Family and Multifamily Dwellings	830.24 Mechanical Execution of Work
820.133 Installation of Coaxial Cables and Equipment	830.25 Abandoned Cables
(A) Separation from Other Conductors	830.26 Spread of Fire or Products of Combustion
(B) Support of Coaxial Cables	<u>Part II. Cables Outside and Entering Buildings</u>
820.154 Applications of Listed CATV Cables	830.40 Entrance Cables
<u>Part VI. Listing Requirements</u>	(A) Medium-Power Circuits
820.179 Coaxial Cables	(B) Low-Power Circuits
(A) Type CATVP	830.44 Overhead (Aerial) Cables
(B) Type CATVR	(A) On Poles and In-Span
(C) Type CATV	(B) Above Roofs
(D) Type CATVX	(C) Clearance from Ground
820.180 Grounding Devices	(D) Over Pools
Article 830 Network-Powered Broadband Communications Systems	(E) Final Spans
	(F) Between Buildings
	(G) On Buildings
	830.47 Underground Network-Powered Broadband Communications Cables Entering Buildings
	(A) Underground Systems with Electric Light

and Power, Class 1, or Non–Power-Limited	Broadband Communications Cables
Fire Alarm Circuit Conductors	(C) Cable Routing Assemblies
(B) Direct-Buried Cables and Raceways	830.113 Installation of Network-Powered Broadband
(C) Mechanical Protection	Communications Cables
(D) Pools	(A) Listing
830.49 Metallic Entrance Conduit Grounding	(B) Ducts Specifically Fabricated for
<u>Part III. Protection</u>	Environmental Air
830.90 Primary Electrical Protection	(C) Other Spaces Used For Environmental Air
(A) Application	(Plenums)
(B) Location	(D) Risers — Cables in Vertical Runs
(C) Hazardous (Classified) Locations	(E) Risers — Cables and Innerducts in Metal
830.93 Grounding or Interruption of Metallic	Raceways
Members of Network-Powered Broadband	(F) Risers — Cables in Fireproof Shafts
Communications Cables	(G) Risers — One- and Two-Family Dwellings
(A) Entering Buildings	(H) Cable Trays
(B) Terminating Outside of the Building	(I) Other Building Locations
<u>Part IV. Grounding Methods</u>	830.133 Installation of Network-Powered Broadband
830.100 Cable, Network Interface Unit, and Primary	Communications Cables and Equipment
Protector Bonding and Grounding	(A) Separation of Conductors
(A) Bonding Conductor or Grounding Electrode	(B) Support of Network-Powered Broadband
Conductor	Communications Cables
(B) Electrode	830.154 Applications of Network-Powered Broadband
(C) Electrode Connection	Communications System Cables
(D) Bonding of Electrodes	830.160 Bends
830.106 Grounding and Bonding at Mobile Homes	<u>Part VI. Listing Requirements</u>
(A) Grounding	830.179 Network-Powered Broadband Communications
(B) Bonding	Equipment and Cables
<u>Part V. Installation Methods Within Buildings</u>	(A) Network-Powered Broadband
830.110 Raceways and Cable Routing Assemblies	Communications Medium-Power Cables
for Network-Powered Broadband	(B) Network-Powered Broadband
Communications Cables	Communication Low-Power Cables
(A) Types of Raceways	830.180 Grounding Devices
(B) Raceway Fill for Network-Powered	Article 840 Premises-Powered Broadband

Communications SystemsPart I. General

840.1 Scope

840.2 Definitions

840.3 Other Articles

(A) Hazardous (Classified) Locations

(B) Cables in Ducts for Dust, Loose Stock,
or Vapor Removal

(C) Equipment in Other Space Used

for Environmental Air

(D) Installation and Use

(E) Output Circuits

(F) Other Communications Systems

(G) Electrical Classification of Data Circuits
and Cables840.21 Access to Electrical Equipment Behind Panels
Designed to Allow Access

840.24 Mechanical Execution of Work

840.25 Abandoned Cables

840.26 Spread of Fire or Products of Combustion

Part II. Cables Outside and Entering Buildings

840.44 Overhead (Aerial) Optical Fiber Cables

(A) On Poles and In-Span

(B) Above Roofs

840.45 Overhead (Aerial) Communications Wires
and Cables

840.46 Overhead (Aerial) Coaxial Cables

840.47 Underground Wires and Cables Entering
Buildings

(A) Optical Fiber Cables

(B) Communications Wires and Cables

(C) Coaxial Cables

840.48 Unlisted Wires and Cables Entering Buildings

(A) Optical Fiber Cables

(B) Communications Wires and Cables

(C) Coaxial Cables

840.49 Metallic Entrance Conduit Grounding

Part III. Protection

840.90 Protective Devices

840.93 Grounding or Interruption

(A) Non-Current-Carrying Metallic Members
of Optical Fiber Cables

(B) Communications Cables

(C) Coaxial Cables

Part IV. Grounding Methods

840.100 Network Terminal and Cable Grounding

840.101 Premises Circuits Not Leaving the Building

(A) Coaxial Cable Shield Grounding

(B) Communications Circuit Grounding

(C) Network Terminal Grounding

840.106 Grounding and Bonding at Mobile Homes

(A) Grounding

(B) Bonding

Part V. Installation Methods Within Buildings

840.110 Raceways and Cable Routing Assemblies

(A) Optical Fiber Cables

(B) Multipair Communications Cables

(C) Coaxial Cables

840.113 Installation on the Customer Premises Side
of the Network Terminal

(A) Premises Communications Circuits

(B) Premises Community Antenna Television
(CATV) Circuits840.133 Installation of Optical Fibers and Electrical
Conductors

840.154 Applications of Listed Optical Fiber Cables

<u>Part VI. Premises Powering of Communications Equipment over Communications Cables</u>	Table 11(A) Class 2 and Class 3 Alternating-Current Power Source Limitations
840.160 Powering Circuits	Table 11(B) Class 2 and Class 3 Direct-Current Power Source Limitations
<u>Part VII. Listing Requirements</u>	Table 12(A) PLFA Alternating-Current Power Source Limitations
840.170 Equipment and Cables	Table 12(B) PLFA Direct-Current Power Source Limitations
(A) Network Terminal	
(B) Optical Fiber Cables	
(C) Communications Equipment	
(D) Cable Routing Assemblies and Communications Raceways	
(E) Premises Communications Wires and Cables	
(F) Premises Community Antenna Television (CATV) Circuits	
(G) Power Source	
(H) Accessory Equipment	
840.180 Grounding Devices	
Chapter 9 Tables	
Table 1 Percent of Cross Section of Conduit and Tubing for Conductors and Cables	
Table 2 Radius of Conduit and Tubing Bends	
Table 4 Dimensions and Percent Area of Conduit and Tubing (Areas of Conduit or Tubing for the Combinations of Wires Permitted in Table 1, Chapter 9)	
Table 5 Dimensions of Insulated Conductors and Fixture Wires	
Table 5A Compact Copper and Aluminum Building Wire Nominal Dimensions and Areas	
Table 8 Conductor Properties	
Table 9 Alternating-Current Resistance and Reactance for 600-Volt Cables, 3-Phase, 60 Hz, 75°C (167°F) — Three Single Conductors in Conduit	
Table 10 Conductor Stranding	